

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/School/2014/W2/1161

Dated: 10/09/2014

FIRE SAFETY CERTIFICATE

Certified that the **Guru Nanak Public School, West Avenue, Punjabi Bagh, New Delhi-110026**, comprised of Ground + three upper floors, owned occupied by **Guru Nanak Public School**, has already been issued FSC vide letter no. **F6/MS/DFS/2011/652 dated 13-04-2011**. The premises was re-inspected by the officer concerned of Fire Service on **22/08/2014** in the presence of **Sh. S.S. Bhandari (Addl. Manager)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the **Director of Education circular no. F6/Estate/CC/Fire/Safety/2011/3298-3398 dated 01/03/2011** and the building /premises is it for occupancy **Class-B (Educational)** with effect from 10/09/14 for a period of three years in accordance with rule 36 unless renewal under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the /construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The Class rooms shall not have more than 45 students in any case.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

Issued on 10/09/14 at New Delhi by



(Dr. G.C. Mitra)
Chief Fire Officer
Ph: 011-23414333
Email: cfhq.dlfire@nic.in

Copy to:

1. Sh. S.S. Bhandari (Addl. Manager),
Guru Nanak Public School, West Avenue, Punjabi Bagh, New Delhi-110026
2. The Director of Education, Old Secretariat, Delhi.

dc


1. Name & address of the building : **Guru Nanak Public School, West Avenue, Punjabi Bagh, New Delhi-110026 (building comprised of Ground+03 upper floors)**
2. Type of Occupancy : **Class -B (Educational)**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F6/MS/DFS/2011/652 dated 13-04-2011**
5. Fire Safety directives letter No. : **N.A.**
6. Date of inspection : **22/08/2014**
7. Name of the Inspecting Officers : **Sunil Chawdhary D.O. (MN)**
8. Name and designation of officers
From the building side : **Sh. S.S. Bhandari (Addl. Manager)**
9. Year of Construction : **1979**
10. Applicant's letter No. : **1155 dated 26/06/2014**

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building	Required	Provided	M/R
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mtrs	25 mtr	M/R
		4.5 mtrs	6 mtr	M/R
		N.R.	3 mtrs.	M.R.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basement 	04	04	M/R
		N.A.	N.A.	N.A.
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basement 	1.5 mtr	2 staircase width 1.53 mtr each 2 staircase width 0.75 mtr each	M/R
		N.A.	N.A.	N.A.
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	Old case	Old case	Old case
	f. Door size	1 mtr	provided	M.R.
3.	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/R	N/R	N/R
		N/R	N/R	N/R
		N/R	N/R	N/R
		N/R	N/R	N/R
		N/R	N/R	N/R
4.	Smoke Management System.			

	<ul style="list-style-type: none"> Basements Upper floors 	N/R	N/R	N/R
		N/R	N/R	N/R
5.	Fire Extinguishers	Required	Provided	MR
	<ul style="list-style-type: none"> Total numbers Types IS marking 	20 nos. ISI marked ABC & CO ² type Yes	32 provided provided	M/R M/R M/R
6.	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	03 30 m 5 mm required	Provided provided Provided	M/R M/R M/R
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's Location 	N/R N/R N/R N/R N/R	N/R N/R N/R N/R N/R	N/R N/R N/R N/R N/R
8.	MOEFA	Required	Provided	M/R
9.	Public Address System.	Required	Provided	M/R
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	N.A. N.A. N.A.	N.A. N.A. N.A.	N.A. N.A. N.A.
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 m.m 03 03	Provided. Provided Provided	M/R M/R M/R
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/R N/R	N/R N/R	N/R N/R
13.	Pumping Arrangements.			
	Ground Level			
	<ul style="list-style-type: none"> ➤ Discharge of main pump ➤ Head of Main pump ➤ Number of main pumps 	N/R N/R N/R	N/R N/R N/R	N/R N/R N/R

	<ul style="list-style-type: none"> ➤ Standby pump out put ➤ Standby pump Head ➤ Auto Starting/Manual stopping ➤ Pump Hose Access 	N/R	N/R	N/R
		N/R	N/R	N/R
		N/R	N/R	N/R
		N/R	N/R	N/R
	Terrace level			
	<ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto Starting of pump 	450 LPM	900 LPM, 450 LPM	M/R
		40 mtr	40 mtr	M/R
		Required	Provided	M.R.
		N/R	Provided	M.R.
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity			
	<ul style="list-style-type: none"> ➤ Draw -off connection ➤ Fire service inlet ➤ Access to tank ➤ Overhead Tank Capacity 	N/R	N/R	N/R
		N/R	N/R	N/R
		N/R	N/R	N/R
		5,000 ltrs	15000 ltrs	M.R.
15	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply			
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/R	N/R	N/R
		N/R	N/R	N/R
19.	Fire Control Room			
	<ul style="list-style-type: none"> ➤ Detector System Panel ➤ Flow Switch Panel ➤ PA system Panel ➤ Batter backup ➤ Building Floor plans 	N/R	N/R	N/R
		N/R	N/R	N/R
		N/R	N/R	N/R
		N/R	N/R	N/R
		N/R	N/R	N/R
20.	Special Fire Protection Systems for	N/R	N/R	N/R
	Protection of special Risks			

The fire protection systems provided in the building were test checked and found functional at the time of inspection. In view of the deemed compliance of the minimum standard of fire prevention and fire safety measure as required under the rules the NOC issued vide letter no. F6/MS/DFS/2011/652 dated 13-04-2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspection Officer

Name Sunil Chawdhary

Designation D.O. (M.N.)

Signature of the Inspection Officer

Name

Designation

2657 Dcofo (M.N.)