

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/SCHOOL/ 2014/W2/1175

Dated: 12/09/2014


**FIRE SAFETY CERTIFICATE**

Certified that the H.D Sehrawat Public School at Plot no71-72, Satyam vihar, Chanchal park, Najafgarh Road Dlehi-110043 comprised of Ground floor only owned / occupied by H.D Sehrawat Public School, has already been issued Fire Safety Certificate vide letter No.F6/DFS/MS/School/2012/188 dated 20.01.2012. The premises was re-inspected by the officer from this department on dated 05.07.2014 in presence of Smt. Neelam (Head Mistress) and observed that school is now comprised of Ground + two upper floors. The fire prevention & fire safety requirement as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of NBC part -IV and that the building / premise is fit for occupancy class Educational (Group-B) with effect from 12/09/2014 for a period of three years subject to compliance of the conditions mentioned below.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**Issued on 12/09/14 at New Delhi by.**



(Dr. G.C. Mishra)  
**CHIEF FIRE OFFICER**  
Phone:-011-23414333

olc 

Copy to :-

1. The Principal  
H.D Sehrawat Public School  
Plot no71-72, Satyam vihar, Chanchal park, Najafgarh Road Dlehi-110043
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

# INSPECTION REPORT

- 19/116
1. Name & address of the building: HD Sehrawat Public School  
71,72 Satyambihar chaurhal Park
  2. Type of Occupancy: Educational (NMF-NGLR). Delhi-43
  3. Type of Case: New (Earlier it was GF only, Now  
1st & 2nd Floor has been added.
  4. Details of previous NOC: Letter No F6/DFS/MS (School/2012/188  
Dated 20/01/12 (For GF only)
  5. Fire Safety directives Letter No.: NBC Part IV
  6. Date of inspection: 5/7/2014
  7. Name of the Inspecting Officer: Ashok Kumar Jaiswal
  8. Name and designation of Officer  
from the building side: Neelam (Head Mistress)
  9. Year of Construction: 2013-14
  10. Applicant's letter No.: HDSPS/01/2014/2015/12.06.2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/ NBC IV Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	Not Applicable	Not Applicable	Not Applicable
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	3	3	MR
	• Basements	No Basement	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.50 Mtr.	1.50x2 1.25x1	MR
	• Basements	No Basement	N/A	N/A
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	1.50 Mtr.	1.50 Mtr.	MR
	f. Door Size	1.00 Mtr.	1.00 Mtr.	MR
3.	Compartmentation			
	• Fire check door			NR
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	30 a/c per hour		NR
	• Upper floors	12 a/c per hour		

N/17				
6.	First - Aid Hose Reels			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	5 mm	5 mm.	MR
7.	Automatic fire detection and alarming system			
	• Type of detector			
	• Location of Main Panel			
	• Location of Repeater			
	• Panel		NR	
	• Alternate source of power			
	• Hooters' Location			
8.	MOEFA	NR	NR	NR
9.	Public Address System	NR	NR	NR
10.	Automatic Sprinkler System			
	• Basements			
	• Upper Floor			
	• Sprinkler above false ceiling		NR	
11.	Internal Hydrants			
	• Size of riser/down-comer			
	• Number of hydrants per floor		NR	
	• Hose Box			
12.	Yard Hydrants			
	• Total number of hydrants	NR	NP	NR
	• Hose Box	NR	NP	NR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump			
	➤ Head of main pump			
	➤ Number of main pumps			
	➤ Jockey pump out put			
	➤ Jockey pump head		NR	
	➤ Standby Pump out put			
	➤ Standby Pump Head			
	➤ Auto Staring/Manual stopping			
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 MH	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank			

N/18

15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft			
	➤ Pressurization of lift lobby			
	➤ Communication in lift Car		NR	
	➤ Fireman's Grounding Switch			
	➤ Lift Signage			
17.	Standby power supply	NR	NP	NR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel			
	➤ Flow Switch Panel			
	➤ PA System Panel		NR	
	➤ Batter backup			
	➤ Building Floor Plans			
20.	Special Fire Protection Systems for Protection of special Risks, if any;		NR	

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service rules 2010.

*Ashok Kumar Jaiswal*

Signature of the Inspecting Officer  
 Name : Ashok Kumar Jaiswal  
 Designation : A.D.O. (Jwala Puri)