

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

Fax:- 011-23412593

E-mail ID: cfhq.dlfire@nic.in

No F6/DFS/MS/School/2014/M02/1125 Dated: 03/09/14

**FIRE SAFETY CERTIFICATE**

Certified that the **Jain Happy School at Sec-II, DIZ Area, Gole Market, New Delhi** comprises of Basement + Ground + 2 upper floors was granted NOC by this department vide letter No. F6/DFS/MS/2011/1068 dated 02-06-2011. The premises was re-inspected by the officer concerned of this department on 07-08-2014 in the presence of Mrs. Urnile Jain and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class Group B “**Educational Building**” Sub-Division B-I Schools up to Sr.Sec. Level with effect from ~~02/06/2011~~ 03/09/2014 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on ..... 03/09/14 ..... at New Delhi by.

  
(Dr. G. C. Mishra)  
Chief Fire Officer  
Delhi Fire Service  
Ph -011-23414333

Copy to:-

1. Mrs. Urnile Jain, Jain Happy School at Sec-II, DIZ Area, Gole Market, New Delhi.
2. Atul Jain Joint Secretary Jain Sabha New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. “The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry”.

## INSPECTION REPORT

1. Name & address of the building : Jain Happy School at Sec-II, DIZ Area, Gole Market, New Delhi.
2. Type of Occupancy : Educational (B+Gr.+2 upper floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2011/1068 dated 02/06/2011
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 07/08/2014
- 7 Name of the Inspecting Officer : M. K. Sharma (Assistant Divisional Officer)
- 8 Name and designation of Officer  
from the building side : Mrs. Urnile jain
- 9 Year of Construction : 2011
10. Applicant's letter No. : Letter No.- 888 dated 04/07/2014.

S No	Minimum standards on fire prevention and fire safety U/R 33	Existing Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	9 Mtr.	MR
	• Gate width	4.5 Mtr.	4.5 Mtr.	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	3 Nos.	MR
	• Basements	1 No.	1 No.	MR
	b. Width of staircases			
	• Upper floors	1.50 Mtr.	1.35 & 1.50 Mtr.2nos	MR
	• Basements	1.0 Mtr.	1.35 Mtr.	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
		NA	NA	NA

	d. No of continuous staircase to terrace	1 No.	1 No.	MR
	e. Width Of Corridor	1.50 Mtr.	1.50 Mtr.	MR
	f. Door Size	1.0 Mtr.	1.0 Mtr.	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	30 ACPH	Machanical	MR
	• Upper floors	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	• Total numbers	6 Nos.	8 Nos.	MR
	• Types	ABC & Co <sub>2</sub>	ABC & Co <sub>2</sub>	MR
	• IS marking	Required	Provided	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	05 MM	05 MM	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			
		NA	NA	NA
9	Public Address System			
		Required	Provided	MR
10	Automatic Sprinkler			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA

11	Internal Hydrants		NA	NA	NA
	<ul style="list-style-type: none"> <li>• Size of riser/down- comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	NA	NA	NA	NA
12	Yard Hydrants		NA	NA	NA
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	NA	NA	NA	NA
13	Pumping Arrangements				
	<ul style="list-style-type: none"> <li>○ Ground Level</li> <li>• Discharge of main pump</li> <li>• Head of main pump</li> <li>• Number of main pumps</li> <li>• Jockey pump out put</li> <li>• Jockey pump head</li> <li>• Standby Pump out put</li> <li>• Standby Pump Head</li> <li>• auto Starting/Manual stopping</li> <li>• Pump House Access</li> <li>○ Terrace level</li> <li>• Discharge of pump</li> <li>• Head of the pump</li> <li>• Power supply</li> <li>• Auto starting of pump</li> </ul>	NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		450 LPM	450 LPM		MR
		30 Mtr.	30 Mtr.		MR
		Required	Provided		MR
		Required	Provided		MR
14	Captive water Storage for fire fighting	NA	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> <li>• Draw of connection</li> <li>• Fire service inlet</li> <li>• Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA	NA	NA	NA
		NA	NA	NA	NA
		NA	NA	NA	NA
		Required	Provided		MR
		10,000 Ltr.	10,000 Ltr.		MR
15	Exit Signage	NA	NA	NA	NA
16	Provision of Lifts				

	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of lift lobby</li> <li>• Communication in lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	<ul style="list-style-type: none"> <li>• Total area</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location</li> </ul>	NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> <li>• Detector system panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Flow Switch Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• PA System Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Batter backup</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Building Floor Plans</li> </ul>	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no F6/DFS/MS/2011/1068 dated 02/06/2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended please.

Signature of the Inspecting Officer

*Mensho*  
25/2/14

Name :- M.K. Sharma

Designation :- A. D.O. (CC)

DO (CD) - M1R