

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/2014 / *School/w2/1155*

Dated: *08/08* /2014

**FIRE SAFETY CERTIFICATE**

Certified that M C Pry. Co-ed School, State Bank Colony, Delhi-110009 comprised of Ground Floor Only (Hutments) owned/occupied by M C Pry. Co-ed School has already been issued fire safety certificate vide letter no. F-6/DFS/MS/2008/957 dated 04/04/2008. The premises was re-inspected by the officer from this department on dated 20/08/2014 in the presence of Sh. K C Gupta (Principal) and observed that the premise now comprised of Ground (hutments) and a new block Ground + one upper floor only. All the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of circular issued by Director of Education letter no 262-362 dated 17/01/2005 and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 08/08/2014 for a period of three years, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 08/08/14 at New Delhi by

  
**(Dr. G.C. Mishra)**  
**Chief Fire Officer**  
**Ph: 011-23414333**

**Copy to:**

1. The Principal, M C D Co-ed School, State Bank Colony, Delhi-110009
2. The Addl. Director of Education, North MCD, Civic Centre, Delhi.

*aca*

N/7

TOTAL Two Blocks - one - Pota Cabin GF. 2nd Block - GF + FF.

### INSPECTION REPORT

1. Name & address of the building : MC Pary Co-ed School, State Bank Colony
2. Type of Occupancy : Delhi-9. Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F-6/DPS/ms/2008/957 Dated: 04-11-08  
for GF only.
5. Fire Safety directives letter No : cis of Div'n of Edn
6. Date of inspection : 20-8-14
7. Name of the Inspecting Officers : N. P. Sharma
8. Name and designation of officers  
from the building side : Sh. K. C. Gupta Principal
9. Year of Construction : 2009
10. Applicant's letter No. : 172

PA - 7027m<sup>2</sup>. CA - 1432.8m<sup>2</sup>. No. S-256. NO/CR-17

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	cis NBC of Division Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible	Accessible	MR
		-	-	-
		-	-	-
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	R	P	MR
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases	R	P	MR
	• Upper Floors	1.5m <sup>th</sup>	1.8m <sup>th</sup> + 1.8m <sup>th</sup>	MR ✓
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	g. Width of Corridor	NA	NA	NA
	h. Door Size	1m <sup>th</sup> x 2	P	MR ✓



3	<b>Compartmentation.</b>	NA		
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	<b>Smoke Management System.</b>	NA		
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour	NA	NA
		12 a/c per hour	NA	NA
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	one @ 300 m <sup>2</sup> 06	06	MR
		ISI marked	ABC	MR
			yes	MR
6	<b>First-Aid Hose Reels.</b>	NA		
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	_____	NA	NA
		30 m	NA	NA
		5 mm	NA	NA
7	<b>Automatic fire detection and alarming system.</b>	NA		
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>	NA		
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA

11

**Internal Hydrants**

- Size of riser/down-comer
- Number of hydrants per floor
- Hose Box

NA

NA

NA

NA

NA

NA

NA

NA

NA

NA

12

**Yard Hydrants.**

- Total number of hydrants
- Hose Box

NA

NA

NA

NA

NA

NA

NA

13

**Pumping Arrangements.**

- Ground Level
  - Discharge of main Pump
  - Head of Main pump
  - Number of main pumps
  - Jockey Pump out put
  - Jockey pump head
  - Standby Pump out put
  - Standby Pump Head
  - Auto Starting/ Manual stopping
  - Pump House Access
- Terrace level
  - Discharge of pump
  - Head of the pump
  - Power Supply
  - Auto Starting of pump

NA

NA

14

**Captive Water Storage for fire fighting.**

- Underground tank capacity
  - Draw-off connection
  - Fire service inlet
  - Access to tank
- Overhead Tank capacity

NA

NA



15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.	NA		
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	NA		
17	Standby power supply	NA	NA	NA
18	Refuge Area.	NA		
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room	NA		
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	NA		
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. P-6/DFSS/mkt/2008/957 (For G.P. only) dated 09-04-2008..... Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

\* one Hall at GF provided with two nos of Exit of 1.5 mtr each.

Signature of the Inspecting Officer *[Signature]* 20/8/14

Signature of the Inspecting Officer

Name N.P. SHARMA

Name

Designation ADO R

Designation

