

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. f6/ofs/ans/school/2014/w2/1143

Dated: 05/09/2014

FIRE SAFETY CERTIFICATE

Certified that M C Primary Girls School, E-1, Mangol Puri, Delhi-110083 comprised of Three Blocks, (Two Blocks Ground Floors Only, One Block Ground + First Floor) owned/occupied by M C Primary Girls School have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 23/08/2014 in the presence of Mrs. Rajni Anand and that the building / premises is fit for occupancy of Educational building with effect from 05/09/2014 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 05/09/14 at New Delhi


(Dr. G.C. Mishra)
Chief Fire Officer
Ph: 011-23414333

Copy to:

1. The Principal, M C Primary Girls School, E-1, Mangol Puri, Delhi-110083
2. The Addl. Director of Education, NMCD, Civic Centre, Delhi.

N/1

Total Three blocks. Two blocks - GF only. one Block GF + FF

INSPECTION REPORT

1. Name & address of the building: MC by Girls school, E-1, Mangal Puri
Delhi 83.
2. Type of Occupancy: Educational
3. Type of Case: New Case / ~~Renewal~~
4. Details of previous NOC: -
5. Fire Safety directives letter No: Circular of the director of Edm. 01-3-11
6. Date of inspection: 23-8-14
7. Name of the Inspecting Officers: N.P. Sharma
8. Name and designation of officers from the building side: Mrs. Rajni Arora (Principal)
9. Year of Construction: 1978, 1983, 2001
10. Applicant's letter No: -

PA - 4503 m². CA - 3000 m². Nobs - 443 Nobs CR - 21

	Minimum Standards on fire prevention and fire safety U/R 33	Min. NBC of Requirement Dir of Edm	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	-	-	-
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	P	MR
	• Upper Floors	01	01	MR
	• Basements	-	-	-
	b. Width of staircases	R	P	MR
	• Upper Floors	1.5 mtr	1.5 mtr	MR
	• Basements	-	-	-
	c. Protection of exits	-	-	-
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	One meter	One mtr x 2	MR
3	Compartmentation.	NA		
	• Fire check door	-	-	-

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	—	—	—
4	Smoke Management System.	NA		
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour	—	—
		12 a/c per hour	—	—
5	Fire Extinguishers	one @ 300 m ²		
	<ul style="list-style-type: none"> Total numbers Types IS marking 	10 ISI marked	10 ABC yes	MR MR MR
6	First-Aid Hose Reels.	NA		
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm	—	—
7	Automatic fire detection and alarming system.	NA		
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	—	—	—
8	MOEFA	—	—	—
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.	NA		
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	—	—	—
		—	—	—
		—	—	—
11	Internal Hydrants	NA		
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	—	—	—
		—	—	—
		—	—	—
12	Yard Hydrants.	NA		
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	—	—	—
		—	—	—

13	Pumping Arrangements.	NA		
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pum 			
14	Captive Water Storage for fire fighting.	NA		
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.			
16	Provision of Lifts.	NA		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply			
18	Refuge Area.	NA		
	<ul style="list-style-type: none"> ➤ Total Area 			
	<ul style="list-style-type: none"> ➤ Location 			
19	Fire Control Room	NA		
	<ul style="list-style-type: none"> • Detector System Panel 			

21/4

	<ul style="list-style-type: none"> • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer 
23-8-14

Name N.P. Sharma

Designation ADO R.

Signature of the Inspecting Officer

Name

Designation