

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F6/DFS/MS/EH/2014/S2/1118

Dated: 03/08/14

FIRE SAFETY CERTIFICATE

Certified that the M/S McDonald's Restaurant at (Ground, Mezzanine and first floor only) 47, Basant Lok, Vasant Vihar, New Delhi-57, comprised of basement (Storage), ground, mezzanine plus three upper floors was granted NOC by this department vide letter No. F6/DFS/MS/EH/2011/2037, dated 19-08-2011. The premises was re-inspected by the officer concerned of this department on 22-08-2014 in the presence of Sh. Champak Kumar (Manager) and found that the said restaurant building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Business" (Restaurant) with effect from .03/08/...2014 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/08/14 at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
T.No.011-23414333

Copy to:-

1. The Dy. Health Officer, Health Department,
SMCD, Green Park, New Delhi.
2. M/S McDonald's Restaurant at 47, Basant Lok, Vasant Vihar, New Delhi-57 .

Conditions for the validity of fire safety certificate are overleaf:-

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/S McDonald's Restaurant at 47, Basant Lok, Vasant Vihar, New Delhi-57.
2. Building is comprised of : B+G+M+3, (Restaurant at B+G+M+1) 2nd & 3rd floors others property.
3. Type of Occupancy : Restaurant.
4. Type of Case : Old Case
5. Details of Previous NOC : No.F.6/DFS/MS/EH/2011/2037, dated-19.08.11.
6. Fire Safety direction letter No : Circular NO.F6/DFS/EH/MS/2005/718, Dated 04.04.2005.
7. Date of Inspection : 22.08.2014
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of Officer from the building side : Sh. Champak Kumar (Manager)
10. Year of Construction : 1990.
11. Applicant's letter No : No.Nil, dated 13.08.14.

S.No	Minimum Standards on fire prevention and fire safety U/R33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6m	9m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	.		
	Basement	02nos.	02nos.	MR
	B. Width of Staircases			
	Upper Floor			
	Basement	1.08m&1.18m	1.08m&1.18m	MR
	c. Protection of exits			
	Fire check door	1.08m &1m	1.08m&1m	MR
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	g. Width of Corridor	01no.	01no.	MR
h. Door Size	N.A.	N.A.	N.A.	
	N.A.	N.A.	N.A.	
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	Exhaust Fan Provided	MR
	Upper floor(in restaurant only)	12 a/c per hour	Exhaust Fan Provided	MR

4

5.	Fire Extinguisher			
	Total numbers	08 nos.	08 nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers at each floor	01no.	01no.	MR
	Length of hose reel hose	30m	30m.	MR
	Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	Required	Provided	MR
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement	Required	Provided	MR
	upper floor	Required	Provided	MR
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100mm.	100mm	MR
	Number of hydrants per floor	01no.	01no.	MR
	Hose Box	01no.	01no.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450LPM	450LPM	MR
	➤ Head of the Pump	35m	35m.	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

M/S McDonald's Restaurant at 47, Basant Lok, Vasant Vihar, New Delhi-57.

14	Captive Water Storage for Fire Fighting.		
	Underground tank capacity	N.A.	N.A.
	Draw-off connection	N.A.	N.A.
	Fire service inlet	N.A.	N.A.
	Access to tank	N.A.	N.A.
	Overhead Tank capacity	5000Liters	10000Liters.
15	Exit Signage.	Required	Provided
16	Provision of Lifts.		MR
	Pressurization of Lift Shaft	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.
	Communication in lift car	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.
	Lift Signage	N.A.	N.A.
17	Standby power supply	Required	Provided DG Set 180KVA
18	Refuge Area.		
	Total area	N.A.	N.A.
	Location	N.A.	N.A.
19	Fire Control Room		
	Detector system panel	N.A.	N.A.
	Flow switch panel	N.A.	N.A.
	PA system panel	N.A.	N.A.
	Battery backup	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.
20	Special Fire Protection systems for of special Risks, if any:	N.A.	N.A.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No.F.6/DFS/MS/EH/2011/2037, dated 19.08.2011 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Signature of the Inspecting Officer

Name : Vedpal

Designation: ADO

Divisional Officer (South)