

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No.F.6/DFS/MS/School/2014/ 52/1201

Dated: 15/09/14

FIRE SAFETY CERTIFICATE

Certified that the building of **Nav Uday Convent Sr. Sec. School**, D Block, Prem Nagar Najafgarh, New Delhi-110043 is comprised of ground floor, first floor and second floor (under construction), but the school is running at ground floor and first floor only was issued NOC by this department vide letter No. F6/DFS/MS/2011/197 dated 03.02.2011 owned/occupied by the school management was re-inspected by the officer concerned of this department on 26.08.2014 in the presence of Sh. Manoj Sharma (Vice Principal) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises (**ground floor and first floor only**) is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....15/09/14.....at New Delhi.



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Principal,
Nav Uday Convent Sr. Sec. School, D Block,
Prem Nagar, Najafgarh, New Delhi-110043.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat, New Delhi – 110054.

etc San
15/9/14

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Building comprised of Ground, First Floor & Second Floor (Under Construction) But School Running at Ground floor plus one upper floor (Nav Uday Convent Sr. Sec. School, D Block, Prem Nagar, Najafgarh, New Delhi - 110043)

INSPECTION REPORT

1. Name & address of the building : Nav Uday Convent Sr. Sec. School, D Block, Prem Nagar, Najafgarh, New Delhi-110043.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/2011/197 dated 03.02.2011
5. Fire Safety directives letter No : N/A
6. Date of inspection : 26.08.2014
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. Manoj Sharma (Vice Principal)
9. Year of Construction : G.F. and F. F. in 1998, Second Floor and admn. Block under construction.
10. Applicant's letter No. : NUCSSS/2014/260 dated 05.05.2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>Accessible</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p>	<p>4.80 & 3.70 mtrs</p> <p>4.40 & 450 mtr</p> <p style="text-align: center;">—</p>	<p>M/R, Old Case</p> <p style="text-align: center;">—</p> <p style="text-align: center;">—</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p>04 No's</p> <p>N/A</p>	<p>04 No's</p> <p>N/A</p>	<p>M/R, Old Case</p> <p>No basement</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	<p style="text-align: center;">—</p> <p>N/A</p>	<p>1.70, 1.20, 1.10 & 1.05 mtr</p> <p>N/A</p>	<p>M/R</p> <p>No basement</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p>
	d. No. of continuous staircases to terrace			
		N/A	01	N/A
	e. Width of Corridor			
		—	280 to 180 cms	M/R
	f. Door Size			
		N/A	110 cms	M/R, (students less than 45 in each class)
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	No basement

N/M

Building comprised of Ground, First Floor & Second Floor (Under Construction) But School Running at Ground floor plus one upper floor (Nav Uday Convent Sr. Sec. School, D Block, Prem Nagar, Najafgarh, New Delhi - 110043)

	<ul style="list-style-type: none"> Upper floors 	N/A	Natural Ventilation	M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	08 no's	Provided	M/R
	<ul style="list-style-type: none"> Types 	ABC/CO2 type	Provided	M/R
	<ul style="list-style-type: none"> IS marking 	ISI marked	ISI marked	M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Length of hose reel hose 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Nozzle diameter 	N/A	N/A	N/A
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooters' Location 	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Ground Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Number of hydrants per floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of Main pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual Stopping 	N/A	N/A	N/A
		N/A	N/A	N/A

Building comprised of Ground, First Floor & Second Floor (Under Construction) But School Running at Ground floor plus one upper floor (Nav Uday Convent Sr. Sec. School, D Block, Prem Nagar, Najafgarh, New Delhi - 110043)

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.	Lift not in use		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

N/6

Building comprised of Ground, First Floor & Second Floor (Under Construction) But School Running at Ground floor plus one upper floor (Nav Uday Convent Sr. Sec. School, D Block, Prem Nagar, Najafgarh, New Delhi - 110043)

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter number F6/DFS/MS/2011/197 dated 03.02.2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note :- As per the ~~Letter~~ given by the principal of school (placed on C-6), there are less than 45 students in each class and School is Running at Ground and First Floor only.

Sandeep
05/9/14

Signature of Inspecting Officer

Name:- Sandeep Duggal

Designation:- Asstt. Divisional Officer

~~Signature of Inspecting Officer~~

~~Name~~

~~Designation~~