

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2014/W2/1174

Dated: 12 / 09 / 2014

**FIRE SAFETY CERTIFICATE**

Certified that the **Nikhil Footwear Private Limited** Plot no. G-11 Udyog Nagar Industrial Area, Main Rohtak Road, New Delhi-110041, Comprised of Basement floor+G.floor+Mezz. floor & first Floor, owned/occupied by **Nikhil Footwear Private Limited** was earlier issued FSC by this deptt. vide letter No.F -5(J)/DFS/92/549 dated 26/10/1992. The premises was re-inspected by the officer concerned of this department on 26.08.2014 in the presence of **Sh. Sushil Jain (Manager)** and observed that all fire prevention and fire safety arrangements as provided in the premises found in good working condition. The Premises have therefore deemed complied with the requirement under rule 33 of Delhi Fire Service Rules, 2010 and thus the building / premises is fit for occupancy class **Industrial** with effect from 12 / 09 / 2014 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

**Following Fire Safety directives must be adhered to:**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipment and method of smooth speedy safe evacuation of occupant in case of emergency.
3. All the fire fighting equipments shall be maintained in prefect working condition all the time and lapses rendering non-functional of fire safety measures , management shall be responsible
4. Any deviation with regard to the construction, electrical installation etc may be got verified from the concerned authorities.
5. Basement shall be used as per the NBC.
6. This NOC may not be treated in any case for regularizations of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. "The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1)of rule 37] along with the copy of this certificate; six month prior to its expiry".

Issued on 12 / 09 / 14 at New Delhi by.

  
(Dr. G.C. Mishra)  
CHIEF FIRE OFFICER  
Phone:-011-23414333

Copy to :-

1. **Sh. Sushil Jain (Manager)**

Nikhil Footwear Private Limited Plot no. G-11 Udyog Nagar Industrial Area, Main Rohtak Road, New Delhi-110041

o/c

1. Name & address of the building : **Nikhil Footwear Private Limited, Plot no. G-11, Udyog Nagar, Industrial Area, Main Rohtak Road, New Delhi-110041. (Basement floor+G.floor+Mezz. floor & first Floor) ✓**
2. Type of Occupancy : **Industrial**
3. Type of Case : **Renewal**
4. Details of previous NOC : **F-5(J)/DFS/92/549/ dated 26.10.1992**
5. Fire Safety directives letter No. : **F-6/DFS/MS/BP/88/690 dated 23.05.1988**
6. Date of inspection : **26-07-2014**
7. Name of the Inspecting Officers : **A.K. Jaiswal**
8. Name and designation of officers  
From the building side : **Mr. Susil Jain (Manager)**
9. Year of Construction : **1992**
10. Applicant's letter No. : **nil dated nil**

### INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-


S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	06mtrs	Provided	M.R
	• Gate width	4.5 mtr	Provided	M.R
	• Width of internal road	3 mtr	Provided	M/R
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	Provided	M.R.
	• Basement	02	Provided	M.R.
	b. Width of staircases			
	• Upper Floors	Old case	Old case	Old case
	• Basement	Old case	Old case	Old case
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R
	• Pressurization	N.R	N.R	N.R.
	d. No. of continuous staircases to terrace	Old case	Old case	Old case
	e. Width of Corridor	N.R. (Halls only)	N.R.(Halls only)	N.R.
	f. Door size	Old case	Old case	Old case
3.	<b>Compartmentation.</b>			
	• Fire check door	Required	Provided	M.R
	• Sealing of electrical shafts	Required	Provided	M.R

	<ul style="list-style-type: none"> <li>Water Curtain</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Fire Dampers</li> </ul>	N.R.	N.R.	N.R.
4.	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	Exhaust Fan	provided	M.R.
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	N.R.	N.R.	N.R.
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	08	15	M.R.
	<ul style="list-style-type: none"> <li>Types</li> </ul>	Water CO <sub>2</sub> /Foam/CO <sub>2</sub> type	provided	M.R.
	<ul style="list-style-type: none"> <li>ISI marking</li> </ul>	ISI marked	provided	M.R.
6.	<b>First-Aid Hose Rees.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	1	1	M.R.
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	provided	M.R.
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	provided	M.R.
7.	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Hooter's Location</li> </ul>	N.R.	N.R.	N.R.
8.	MOEFA	N.R.	N.R.	N.R.
9.	<b>Public Address System.</b>	N.R.	N.R.	N.R.
10.	<b>Automatic Sprinkler system</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N.R.	N.R.	N.R.
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	N.R.	N.P.	N.R.
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	N.R.	N.P.	N.R.
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N.R.	N.P.	N.R.

12.	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N.R.	N.R.	N.R.
	• Hose Box	N.R.	N.R.	N.R.
13.	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	N.R.	N.R.	N.R.
	➤ Head of Main pump	N.R.	N.R.	N.R.
	➤ Number of main pumps	N.R.	N.R.	N.R.
	➤ Jockey Pump out put	N.R.	N.R.	N.R.
	➤ Jockey pump head	N.R.	N.R.	N.R.
	➤ Standby pump out put	N.R.	N.R.	N.R.
	➤ Standby pump Head	N.R.	N.R.	N.R.
	➤ Auto Starting/Manual stopping	N.R.	N.R.	N.R.
	➤ Pump Hose Access	N.R.	N.R.	N.R.
	<b>Terrace level</b>			
	➤ Discharge of pump	Not mentioned in recommendation	900 LPM	M.R.
	➤ Head of the pump	Not mentioned in recommendation	40 MH	M.R.
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	Not mentioned in recommendation	Provided	M.R.
14.	<b>Captive Water Storage for fire fighting.</b>			
	<b>Underground tank capacity</b>	50,000 ltrs	<del>50,000</del> 1,30,000 ltrs	M.R. <i>SLV</i>
	➤ Draw -off connection	required	provided	M.R.
	➤ Fire service inlet	required	provided	M.R.
	➤ Access to tank	required	provided	M.R.
	➤ Overhead Tank Capacity	2,000 ltr	Provided	M.R.
15	<b>Exit Signage.</b>	N.R.	N.R.	N.R.
16.	<b>Provision of Lifts</b>			
	• Pressurization of Lift Shaft	N.A.	N.R.	N.R.
	• Pressurization of Lift lobby	N.A.	N.R.	N.R.
	• Communication In lift Car	N.A.	N.R.	N.R.

	<ul style="list-style-type: none"> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N.A.	N.R.	N.R.
		N.A.	N.R.	N.R.
17.	<b>Standby power supply</b>	N.R.	100 K.V.A.	M.R
18.	<b>Refuge Area</b>	N.R.	N.R	
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R.
19.	<b>Fire Control Room</b>			
	➤ Detector System Panel	N.R.	N.R.	N.R.
	➤ Flow Switch Panel	N.R.	N.R.	N.R.
	➤ PA system Panel	N.R.	N.R.	N.R.
	➤ Battery backup	N.R.	N.R.	N.R.
	➤ Building Floor plans	N.R.	N.R.	N.R.
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	N.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC vide letter No. F-5(J)/DFS/92/549/ dated 26.10.1992 renewal under rule 35 of the Delhi Fire Service rule 2010 is recommended



Signature of the Inspecting Officer

Name : A K Jaiswal

Designation : A.D.O. (J.W.P.)