

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F-6/DFS/MS/2014/W2/1147

Dated: 05/09/2014


FIRE SAFETY CERTIFICATE

Certified that the Plot No. H-24, Udyog Nagar, Industrial Area, Rohtak Road, New Delhi-110041, comprised of Basement+G.F+Mezz.F+first Floor, owned/occupied by **Welcome Shoes Pvt. Ltd.** was earlier issued FSC by this deptt. vide letter No. F-6/DFS/MS/2011/194 dated 16.08.2011. The premises was re-inspected by the officer concerned of this department on **06/08/2014** in the presence of **Mr. Deep Sharma (Manager)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the requirement under Rule 33 of the Delhi Fire Service Rule 2010 and thus the building/premises is fit for occupancy class **Industrial** with effect from...05/09/14.....for a period of three year in accordance with rule 36 unless renewed under 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under 38 of the Delhi Fire Service Rule 2010.

Following fire safety directives must be adhered to:-

- 1) All the means of escape shall be kept free of all type of obstruction all the time.
- 2) All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3) All the fire fighting equipment shall be maintained in perfect working condition all the time and lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4) Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
- 5) Basement shall be used as per NBC.
- 6) This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
- 8) "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

Issued on...05/09/14.....at New Delhi by

  
Chief Fire Officer  
Delhi Fire Service

Copy to: **Director,**

**Welcome Shoes Pvt. Ltd.**

Plot No. H-24, Udyog Nagar, Industrial Area, Rohtak Road, New Delhi-110041.



1. Name & address of the building : Plot No. H-24, Udyog Nagar, Industrial Area, Rohtak Road, New Delhi-110041. (Basement+G+Mezz. floor & first Floor)
2. Type of Occupancy : Industrial
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DFS/MS/2011/194 dated 16.08.2011
5. Fire Safety directives letter No. : F-6/DFS/MS/BP/84/BP/652 dated 23.08.1984
6. Date of inspection : 06-08-2014
7. Name of the Inspecting Officers : A.K. Jaiswal / A.D.O. (JWP) & Sunil Chawdhary D.O. (West)
8. Name and designation of officers  
From the building side : Mr. Deep Sharma (Manager)
9. Year of Construction : 1984
10. Applicant's letter No. : Nil dated 07.07.2014

### INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-


S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	06mtrs	Provided	M.R.
	• Gate width	4.5 mtr	Provided	M.R.
	• Width of internal road	3 mtr	Provided	M/R
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	Provided	M.R.
	• Basement	02	Provided	M.R.
	b. Width of staircases			
	• Upper Floors	Old case	Old case	Old case
	• Basement	Old case	Old case	Old case
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R.
	• Pressurization	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace	Old case	Old case	Old case
	e. Width of Corridor	N.R. (Halls only)	N.R.(Halls only)	N.R.
	f. Door size	Old case	Old case	Old case
3.	<b>Compartmentation.</b>			
	• Fire check door	Required	Provided	M.R.
	• Sealing of electrical shafts	Not mentioned in recommendation	Provided	M.R.
	• Fire Rating of shaft door	N.R.	N.R.	N.R.

	Water Curtain		N.R.	N.R.	N.R.
	• Fire Dampers		N.R.	N.R.	N.R.
4.	<b>Smoke Management System.</b>				
	• Basements	Exhaust Fan	provided	M.R.	
	• Upper floors	N.R.	N.R.	N.R.	
5.	<b>Fire Extinguishers</b>				
	• Total numbers	06	10	M.R.	
	• Types	ABC & CO <sub>2</sub> type	provided	M.R.	
	• ISI marking	ISI marked	provided	M.R.	
6.	<b>First-Aid Hose Reels.</b>				
	• Total numbers on each floor	1	02	M.R.	
	• Length of hose reel hose	30 m	provided	M.R.	
	• Nozzle diameter	5 mm	provided	M.R.	
7.	<b>Automatic fire detection and alarming system.</b>				
	• Type of detectors	N.R.	N.R.	N.R.	
	• Location of Main Panel	N.R.	N.R.	N.R.	
	• Location of Repeater Panel	N.R.	N.R.	N.R.	
	• Alternate source of power	N.R.	N.R.	N.R.	
	• Hooter's Location	N.R.	N.R.	N.R.	
8.	<b>MOEFA</b>				
		N.R.	N.R.	N.R.	
9.	<b>Public Address System.</b>				
		N.R.	N.R.	N.R.	
10.	<b>Automatic Sprinkler system</b>				
	• Basement	N.R.	N.R.	N.R.	
	• Upper Floor	N.R.	N.R.	N.R.	
	• Sprinkler above false ceiling	N.R.	N.R.	N.R.	
11.	<b>Internal Hydrants</b>				
	• Size of riser/down-comer	N.R.	N.P.	N.R.	
	• Number of hydrants per floor	N.R.	N.P.	N.R.	

	• Hose Box	N.R.	N.P.	N.R.
12.	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N.R.	N.R.	N.R.
	• Hose Box	N.R.	N.R.	N.R.
13.	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	Not mentioned in recommendation	1680 LPM	M.R.
	➤ Head of Main pump	Not mentioned in recommendation	65 MH	M.R.
	➤ Number of main pumps	Not mentioned in recommendation	01	M.R.
	➤ Jockey Pump out put	Not mentioned in recommendation	220 LPM	M.R.
	➤ Jockey pump head	Not mentioned in recommendation	65 MH	M.R.
	➤ Standby pump out put	N.R.	N.R.	N.R.
	➤ Standby pump Head	N.R.	N.R.	N.R.
	➤ Auto Starting/Manual stopping	Not mentioned in recommendation	Provided	M.R.
	➤ Pump Hose Access	Not mentioned in recommendation	Accessible	M.R.
	<b>Terrace level</b>			
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.
14.	<b>Captive Water Storage for fire fighting.</b>			
	<b>Underground tank capacity</b>	50,000 ltrs	50,000 ltrs	M.R.
	➤ Draw -off connection	Not mentioned in recommendation	N.R.	N.R.
	➤ Fire service inlet	Not mentioned in recommendation	N.R.	N.R.
	➤ Access to tank	Not mentioned in recommendation	Provided	M.R.
	➤ Overhead Tank Capacity	5,000 ltrs	10,000 ltrs	M.R.
15	<b>Exit Signage.</b>	Not mentioned in recommendation	Provided	M.R.
16.	<b>Provision of Lifts</b>			
		N.A.	N R	N R

	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	N.A.	N.R.	N.R.
		N.A.	N.R.	N.R.
		N.A.	N.R.	N.R.
		N.A.	N.R.	N.R.
		N.A.	N.R.	N.R.
17.	<b>Standby power supply</b>	N.R.	100 K.V.A.	M.R
18.	<b>Refuge Area</b>	N.R.	N.R	
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R.
19.	<b>Fire Control Room</b>			
	➤ Detector System Panel	N.R.	N.R.	N.R.
	➤ Flow Switch Panel	N.R.	N.R.	N.R.
	➤ PA system Panel	N.R.	N.R.	N.R.
	➤ Battery backup	N.R.	N.R.	N.R.
	➤ Building Floor plans	N.R.	N.R.	N.R.
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	N.R.


The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC vide letter No. F-6/DFS/MS/2011/194 dated 16.08.2011 renewal under rule 35 of the Delhi Fire Service rule 2010 is recommended.



Signature of the Inspecting Officer

Name : A.K. Jaiswal

Designation : A.D.O. (J.W.P.)



Signature of the Inspecting Officer

Name : Sunil Chawdhary

Designation : D.O. (West)