

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/school/2014/w2/1144

Dated: 05/09/2014

FIRE SAFETY CERTIFICATE

Certified that Shakuntla Devi Public School, A-223, Pusta Road, Swaroop Nagar, Delhi-42 comprised of Ground + Two upper floor owned/occupied by Shakuntla Devi Public School has already been issued fire safety Certificate vide letter No F-6/DFS/MS/2006/1491 dated 06/07/2006 have complied with the fire prevention and fire safety requirements in accordance with Circular dated 01/03/2011 issued by Director of education and verified by the officer concerned of Fire Service on 25/08/2014 in the presence of Smt. Poonam (Manager) and that the building is fit for occupancy of Group Class B (Educational) with effect from 05/09/2014 for a period of Three years subject to conditions mentioned below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 05/09/14 at New Delhi by


(Dr. G. C. Mishra)
Chief Fire Officer
Ph: 011-23414333

Copy to:

The Principal, Shakuntla Devi Public School, A-223, Pusta Road, Swaroop Nagar, Delhi-42
The Director of Education, Old Secretariat, Delhi

1. Name & address of the building : Shakti Mills, Durgam Chaudhary, Pusta Rd. Swaroopnagar Delhi-42
2. Type of Occupancy : Educational
3. Type of Case : New case/Renewal
4. Details of previous NOC : F-6/025/MS/2006/1491 dt. 6.7.06
5. Fire Safety directives letter No : Dir. of Edu.
6. Date of inspection : 25.8.14
7. Name of the Inspecting Officers : AAO (BWS)
8. Name and designation of officers from the building side : smt Poonam, manager
9. Year of Construction : 2000 & 2009
10. Applicant's letter No. : Lt No. MIC dt. 1.8.14

Plot area - Previous 250 sq. yards Present 1000 sq. yards
 Covered area - 1500 sq. yards
 No's of student - 410
 No's of class room - 19
 Lux room other purpose -

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	—	—	—
	• Upper Floors	01	02	MR
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	1.50 mts	1.12 & 1.17 mts	MR
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	1 mtr	01 mtr	MR
3	Compartmentation.			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			
	• Basements	30 a/c per hour		
	• Upper floors	12 a/c per hour		
5	Fire Extinguishers			
	• Total numbers	9 ABC	9	MR
	• Types	ISI marked	ABC	MR
	• IS marking		Yes	MR
6	First-Aid Hose Reels.			

	<ul style="list-style-type: none"> Length of hose reel hose Nozzle diameter 	30 m	P	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A		
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 			
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A		
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 			
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A		
		450 LPH	P	MR ✓
		40H	P	MR ✓
		—	—	—
		—	—	—
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A		
		10,000 lts	P	MR ✓
15	Exit Signage.			
		R	P	MR ✓

	<ul style="list-style-type: none"> • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 				
17	Standby power supply				
18	Refuge Area.				
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 				
19	Fire Control Room				
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 				
20	Special Fire Protection Systems for Protection of special Risks, if any:				

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. FC/DFS/MS/2006/1491 dated 6.7.06 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]
[Handwritten Name]
[Handwritten Designation]

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]
[Handwritten Name]
[Handwritten Designation]