

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID:cfohq.dlfire@nic.in

No F 6 / DFS / MS / 2014 / EH/N02/1124

Dated 03/09/14

FIRE SAFETY CERTIFICATE

Certified that the **The 'W' Restaurant (Lodging House)** located at **G-68, 2<sup>nd</sup> & 3<sup>rd</sup> Floor, Connaught Place, New Delhi** comprises of Ground floor + 3 Upper floors but the guest house is running on 2<sup>nd</sup> & 3<sup>rd</sup> floor only (for 10 guest rooms) was granted NOC by this department vide letter No. F6/DFS/MS/GH/2010/3174 dated 15-11-2010. The premises was re-inspected by the officer concerned of this department on 28-08-2014 in the presence of Mr. Mukesh Goswami (Manager) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential , Sub Division A-1 lodging or rooming houses** for 10 guest rooms with effect from 03/08/2014 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/08/14..... at New Delhi by.

  
(Dr. G. C. Misra)  
Chief Fire Officer

Delhi fire Service  
Ph – 011-23414333

Copy to:-

1. The Joint Commissioner of Police (Lic), First Floor, P.S. Defense Colony New Delhi – 110049 w.r.t. letter No 48032/Joint C.P./Lic. (H) dated 17-09-2013
2. Mr. Mukesh Goswami (Manager) The 'W' Restaurant (Lodging House) located at G-68, 2<sup>nd</sup> & 3<sup>rd</sup> floor \, Connaught Place, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

## INSPECTION REPORT

1. Name & address of the building : The 'W' Restaurant Lodging House located at G-68, 2<sup>nd</sup> & 3<sup>rd</sup> Floor, Cannaught Place, New Delhi.
2. Type of Occupancy : Residential (Guest house) G +3 floors.
3. Type of Case : Renewal
4. Details of previous NOC : F6/MSDFS/GH/2010/3174 dated 15/11/2010
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 28/08/2014
- 7 Name of the Inspecting Officer : Sh.Rajesh Panwar Dy.CFO (NDZ) & Sh.M. K. Sharma (ADO/CC)
- 8 Name and designation of Officer  
from the building side : Mr. Mukesh Goswami (Manager)
- 9 Year of Construction : Old Haritage
10. Applicant's letter No. : 48032/Joint. C.P./Lic.(H) dated New Delhi the 17/09/2013

Old Case

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 Mtr.	16 Mtr.	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1 No.	1 No.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 Mtr.	1.50 Mtr.	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA


	<ul style="list-style-type: none"> <li>• Pressurization</li> </ul>	NA	NA	NA
	d. No of continuous staircase to terrace	1 No.	1 No.	MR
	e. Width Of Corridor	1.0 Mtr.	1.0 Mtr.	MR
	f. Door Size	1.0 Mtr.	1.0 Mtr.	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	NA	NA	NA
4	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	08 Nos.	10 Nos.	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ABC, CO <sub>2</sub> , Wco <sub>2</sub>	ABC, CO <sub>2</sub> , Wco <sub>2</sub>	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	Required	Provided	MR
6	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	01	01	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	05 MM	05 MM	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	NA	NA	NA

	Upper floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants	NA	NA	NA
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants	NA	NA	NA
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements	NA	NA	NA
	○ Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	• Head of main pump	NA	NA	NA
	• Number of main pumps	NA	NA	NA
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• auto Staring/Manual stopping	NA	NA	NA
	• Pump House Access	NA	NA	NA
	○ Terrace level	NA	NA	NA
	• Discharge of pump	450 LPM X 2	450 LPM X 2	MR
	• Head of the pump	30 Mtr.	30 Mtr.	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
4	Captive water Storage for fire fighting	NA	NA	NA
	• Under ground tank capacity	NA	NA	NA
	• Draw of connection	NA	NA	NA
	• Fire service inlet	NA	NA	NA

	<ul style="list-style-type: none"> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	Required 5,000 ltr.	Provided 5,000 ltr.	MR MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts	NA	NA	NA
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of lift lobby</li> <li>Communication in lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> <li>Total area</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Location</li> </ul>	NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> <li>Detector system panel</li> <li>Flow Switch Panel</li> <li>PA System Panel</li> <li>Batter backup</li> <li>Building Floor Plans</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/MS/DFS/GH/2010/3174 dated 15/11/2010 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended please.

  
Name :- Rajesh Panwar  
Designation :- D.C.F.O. (NDZ)

  
Name:- Sh. M. K. Sharma  
Designation :- A. D.O. (CC)