

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:-011-23412593

E-mail ID: cfohq.dlfire@nic.in

No. F6/DFS/MS/GH/2014/~~1102~~/1203

Dated 15/09/14

FIRE SAFETY CERTIFICATE

Certified that the **The "W" Restaurant** located at **G-68, outer circle, Connaught place New Delhi** comprises of Ground+ 3 upper floor was granted NOC by this department vide letter No.F6/DFS/MS/GH/2011/842 dated 09-05-2011. The premises was re-inspected by the officer concerned of this department on 22-08-2014 in the presence of Mr. Mukesh Goswami (Manager) and found that the said **"W" Restaurant** at 1st floor have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building Group-D of Sub-Division D-4** with effect from ~~15/09/2014~~ 15/09/2014 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on15/09/14..... at New Delhi by.

(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph - 011-23414333

Copy to:-

1. Medical Officer of Health, Health Department, Palika Kendra, Sansad Marg, New Delhi.
2. Mr. Mukesh Goswami (Manager) The "W" Restaurant, G-68, Outer circle, Connaught Place, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry"

INSPECTION REPORT

1. Name & address of the building : The "W" Restaurant located at, G-68, Outer Circle, Connaught Place, New Delhi
2. Type of Occupancy : Assembly Building (Ground+3 floor, Restaurant at 1st floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2011/842
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 22/08/2014
- 7 Name of the Inspecting Officer : Sh. Rajesh Panwar (Dy. CFO NDZ)
Sh. M.K. Sharma (ADO CC)
- 8 Name and designation of Officer
from the building side : Mr. Mukesh Goswami (Manager)
- 9 Year of Construction : Old Heritage
10. Applicant's letter No. : No.

Old Case

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site (PSS Area)	Remarks MR/NMR (P.S.S Area)
1.	Access of building			
	• Road width	9Mtr.	16 mt	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	02	02	MR
	• Upper floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors * 2 nd staircase of 0.80 mt from GF to Restaurant.	1.25 mt & 0.80 mt	1.75 mt & 0.80mt	MR
	• Basements	NA	NA	NA

	c..Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	01	01	MR
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	01 mt	01 mt	MR
	f. Door Size			
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	• Total numbers	06	10	MR
	• Types	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	• IS marking	YES	Provided	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30 mt	30 mt	MR
	• Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System	NA	NA	NA

	Public Address System	NA	NA	NA
	Automatic Sprinkler			
	• Basements	NA	NA	NA
	• Upper Floor	YES	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
2	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
3	Pumping Arrangements			
	○ Ground Level			
	• Discharge of main pump	NA	NA	NA
	• Head of main pump	NA	NA	NA
	• Number of main pumps	NA	NA	NA
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• auto Starting/Manual stopping	NA	NA	NA
	• Pump House Access	NA	NA	NA
	○ Terrace level	NA	NA	NA
	• Discharge of pump	450 LPM	450 LPM & 180LPM	MR
	• Head of the pump	30 mt	30 mt	MR
	• Power supply	YES	Provided	MR
	• Auto starting of pump	NA	NA	NA
14	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
		NA	NA	NA

	<ul style="list-style-type: none"> • Draw of connection • Fire service inlet • Access to tank • Overhead Tank capacity 	NA	NA	NA
15	Exit Signage	YES	Provided	MR
16	Provision of Lifts	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of lift lobby • Communication in lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
17	Standby power supply	NR	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> • Total area • Location 	NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> • Detector system panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	YES	ABC, Co ₂	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule it is recommended to grant fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010. FSC is recommended please.

Signature of the Inspecting Officer

Name:- Rajesh Panwar

Designation :- Dy.CFO (NDZ)

Signature of the Inspecting Officer

Name :- M.K. Sharma

Designation :- A. D.O. (CC)