

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:-011-23412593

E-mail ID: cfhq.dfire@nic.in

No. F6/DFS/MS/GH/2014/ 402/1211

Dated 17/09/14

FIRE SAFETY CERTIFICATE

Certified that the **M/S Ardor Restaurant** located at **No.55-56 & 88-89, Connaught Circus, New Delhi** comprises of Ground+2 upper floor Restaurant at 1st floor+2nd floor owned/occupied by of Ascot(A-Unit Hotels & Resorts Ltd.) was granted NOC by this department vide letter No.F6/DFS/MS/GH/2011/1539 dated 08-07-2011. The premises was re-inspected by the officer concerned of this department on 06-09-2014 in the presence of Mr.Varun (Manager) and found that the **Restaurant** at 1st + 2nd floor have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building Group-D of Sub-Division D-4** with effect from ~~17/08/2014~~ 17/09/2014 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ~~17/08/14~~ 17/09/14 at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333

Copy to:-

1. Medical Officer of Health, Health Department, Palika Kendra, Sansad Marg, New Delhi.
2. Sh. Varun (Manager) M/S Ardor Restaurant located at No.55-56 & 88-89, Connaught Circus, New Delhi

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry"

INSPECTION REPORT

1. Name & address of the building : Ardor Restaurant, Premises No. N-55-56 & 88-89, Connaught
Circus, New Delhi.
2. Type of Occupancy : Assembly (Restaurant) Gr+2 floors, Restaurant at 1st & 2nd floor
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2011/EH/1539 Dated 08/07/2011
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 06/09/2014
- 7 Name of the Inspecting Officer : Sh. M. K. Sharma (ADO/CC)
- 8 Name and designation of Officer
from the building side : Mr. Varun (Manager)
9. Year of Construction : old Heritage Bldg.
10. Applicant's letter No. : MOH/D/260/CSI/(Lic.)SI-1 dated 20/06/2014

Old Case

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	6 Mtr.	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	2 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	0.65 & 1.20 Mtr.	0.65 & 1.20 Mtr.	MR
		NA	NA	NA


	<ul style="list-style-type: none"> • Basements 			
	c. Protection of exits	NA	NA	NA
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization 	NA	NA	NA
	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	10 Nos.	10 Nos.	MR
	<ul style="list-style-type: none"> • Types 	ABC, CO ₂	ABC, CO ₂	MR
	<ul style="list-style-type: none"> • IS marking 	Required	Provided	MR
6	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	01	01	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	05 MM	05 MM	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	Required	Provided	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	First Floor	First Floor	MR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hooters' Location 	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	NA	NA	NA

10	Automatic Sprinkler			
	• Basements	NA	NA	NA
	• Upper floor			
	• Sprinkler above false ceiling	Required	Provided	MR
		NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	○ Ground Level			
	• Discharge of main pump	NA	NA	NA
	• Head of main pump	NA	NA	NA
	• Number of main pumps	NA	NA	NA
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• auto Staring/Manual stopping	NA	NA	NA
	• Pump House Access	NA	NA	NA
	○ Terrace level			
	• Discharge of pump	450 & 180 LPM	450 & 180 LPM	MR
	• Head of the pump	40 Mtr.	40 Mtr.	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive water Storage for fire fighting			
		NA	NA	NA
	• Under ground tank capacity	NA	NA	NA
		NA	NA	NA

	<ul style="list-style-type: none"> • Draw of connection • Fire service inlet • Access to tank • Overhead Tank capacity 	NA	NA	NA
		Required	Provided	MR
		5,000 Ltr.	15,000 Ltr.	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of lift lobby • Communication in lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> • Total area 	NA	NA	NA
	<ul style="list-style-type: none"> • Location 	NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> • Detector system panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC, Co ₂	MR

The fire protection systems provided in the building were randomly tested, checked and found non-functional at the time of inspection.

Keeping In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/2011/EH/1539 dated 08/07/2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended please.


Name:- Sh. M. K. Sharma
Designation :- A. D.O. (CC)

Dol CD - MR