

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/School/2014/W2/1240

Dated: 24/09/14

FIRE SAFETY CERTIFICATE

Certified that the **Brilliant Convent Sr. Sec. School** located at **West Enclave, Pitampura, Delhi - 110034** comprised of Ground + 02 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/2009/2466 Dated 10-08-2009. The premises was re inspected by the officer concerned of this department on 23-08-2014 in the presence of Sh. Dilbag Singh(Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 262 – 362 Dated 17-01-2005 and that the premises is fit for occupancy class "Educational" Group B with effect from 24/09/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/09/14 at New Delhi by.

(Santokh Singh)  
Chief Fire Officer  
PH 011-23414250

Copy to:

1. The Principal,  
Brilliant Convent Sr. Sec. School  
West Enclave, Pitampura, Delhi - 110034

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

- 01 Name & address of the building: Brilliant Convent Sr. Sec. School  
West Enclave, Pitampura, Delhi - 110034.
1. Type of Occupancy : Educational ( Ground + 2 Upper Floor) ✓
2. Type of Case : Renewal
3. Details of previous NOC : F6/DFS/MS/2009/2466 Dated 10-08-2009
4. Fire Safety directives Letter No. : 262-362 dated 17-01-2005
5. Date of inspection : 23-08-2014
6. Name of the Inspecting Officer : Udaivir singh, ADO (WP)
7. Name and designation of Officer  
from the building side : Sh. Sh. Dilbag Singh (Manager)
8. Year of Construction : 1999
9. Applicant's letter No. : Bcs/Fire/2014 Dated 25-07-2014

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.262-362 dated 17-01-2005	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<ul style="list-style-type: none"> <li>Accessible</li> <li>Accessible</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>Provided</li> <li>Provided</li> <li>NA</li> </ul>	<ul style="list-style-type: none"> <li>MR</li> <li>MR</li> <li>NA</li> </ul>
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases	dh old case	old case	old case dh
	• Upper floors	Old Case	Old Case	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old case	Old Case	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> </ul>	NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	NA	NA	NA
		NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	06nos. ABC & CO <sub>2</sub> ISI marked	Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	01 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	100 mm 01 01	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	NA NA	Provided Provided	NA NA



20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2009/2466 Dated 110-08-2009 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the ~~Inspecting~~ Officer

Inspecting Officer

Name Uday Vir Singh

Designation ADD/WP

Signature of the

Name

Designation