

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

Fax: 011-23412593, Email: [cfobhq.dlfire@nic.in](mailto:cfobhq.dlfire@nic.in) Ph. 011-23414333

NO. F6/DFS/MS/School/2014/ SZ/ 1241

DATED: 24/09/14

FIRE SAFETY CERTIFICATE

Certified that Deepalaya School at A-14, Kalkaji Extn. New Delhi-110019 comprised of sunken basement ground plus two upper floors was granted NOC by this department vide letter no. F6/MS/DFS/2006/3855 dated 29.12.2006. The premises was re-inspected by the officers concerned of Fire Service on 18.09.2014 in the presence of Sh. Kuriakosenj (Admin. Officer) and observed that fire safety norms as required under Rule 33 of Delhi Fire Service Rules, 2010 are deemed complied and that the building / premises is fit for occupancy class B "Educational building" with effect from 24/09/14..... for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on 24/09/14..... at New Delhi by

  
(Dr. G.C. Misra)  
Chief Fire Officer

Copy to,

1. The Director, Education, G. N.C.T Delhi, Old Secretariat, New Delhi
2. The Authorized Signatory, Deepalaya School, A-14, Kalkaji Extn. New Delhi-110019.

Conditions for the validity of fire safety certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1	Name & address of the building	Deepalaya School, A-14, Kalkaji Extn. New Delhi-110019.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal		
4	Details of previous NOC	F6/MS/DFS/2006/3855 dated 29.12.2006		
5	Fire safety directives letter No	F6/MS/DFS/BP/96/329 dated 08.03.1996		
6	Date of inspection	18.09.2014		
7	Name of the inspecting Officers :	DO D.P. Bhardwaj, ADO D.B. Mukherjee		
8	Name and designation of officers from the building side	Sh. Kuriakosenj ( Admin. Officer)		
9	Year of construction	Old		
10	Applicant's letter No.	D/DSKE/17/1070 Dated 12.08.2014	(sunken basement , ground plus two upper floors)	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	<b>Access to building</b>			
	1) Road width	6 Mtr	Provided	MR
	2) Gate width	4.5 Mtr	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	3 Nos	Provided	MR
	2. basements	3 Nos	Provided	MR
	<b>b. Width of staircase</b>			
	1. Upper floors	1.25	1.35 (2) & 1.31 Mtrs	MR
	2. basements	1.25	1.35 (2) & 1.31 Mtrs	MR
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Required	Three Provided	MR
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	1 Mtr	Provided	MR
3	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	basement	30 a/c per hour 12 a/c per hour	Exhuast Fans Provided	MR
	upper floors		Natural Vent.	MR

5	<b>Fire Extinguishers</b>			
	total numbers		20 Nos	MR
	Types		ABC, Water Co2,	MR
	ISI marking	ISI	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	Two	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	basement	Required	Provided	MR
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	100 mm	Provided	MR
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	Old Case	900 LPM & 180 LPM Provided	MR
	b. head of the pump	Old Case	35 Mtr Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	50,000 Ltrs	Provided	MR
	a. Draw-off connection	N/A	Provided	MR
	b. fire service inlet	N/A	Provided	MR
	c. Access to tank	N/A	Provided	MR
	Over head tank Capacity	20,000 Ltr	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR

	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
<b>17</b>	<b>Standby power supply</b>	N/A	N/A	N/A
<b>18</b>	<b>Refuge Area.</b>	Not Required		
	total area			
	location			
<b>19</b>	<b>Fire control room</b>			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
<b>20</b>	<b>Special Fire Protection systems for protection of special risks, if any:</b>	<b>N/A</b>		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules of NOC issued vide letter no. **F6/MS/DFS/2006/3855 dated 29.12.2006** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

Signature of the inspecting officer

Name D. P. Bhardwaj

Designation : Divisional Officer (South)

Signature of the Inspecting Officer

Name

D.B. Mukherjee

Designation-

ADO (BCP)