

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:-011-23412593

E-mail ID: cfhq.dfire@nic.in

No. F6/DFS/MS/EH/2014/ND2/1226

Dated 19/9/14

FIRE SAFETY CERTIFICATE

Certified that the **Havemore Restaurant** located at **11-12, Pandara Road Market, New Delhi** comprises of Ground floor only was granted NOC by this department vide letter No.F6/DFS/MS/EH/2011/2982 dated 15-11-2011. The premises was re-inspected by the officer concerned of this department on 03-08-2014 in the presence of Mr. Sunil Kumar (Manager) and found that the said **Restaurant** have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building Group-D of Sub-Division D-4** with effect from -----19/9/-----2014 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on19/9/14..... at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333

Copy to:-

1. Medical Officer of Health, Health Department, Palika Kendra, Sansad Marg, New Delhi. No.MOH/218/CSI(Lic.)/D/SI-VI dated 30/04/2014.
2. Sh. Sunil Kumar (Manager) Havemore Restaurant located at 11-12, Pandara Road Market, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry"

N19

INSPECTION REPORT

1. Name & address of the building : Havemore Restaurant located at 11-12, Pandara Road Market, New Delhi.
2. Type of Occupancy : Assembly building (Restaurant) Ground floor
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2011/EH/2982 Dated 15/11/2011
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 03/08/2014
- 7 Name of the Inspecting Officer : Sh. M. K. Sharma (ADO/CC)
- 8 Name and designation of Officer
from the building side : Mr. Sunil Kumar (Manager)
9. Year of Construction : 1996
10. Applicant's letter No. : MOH/218/CSI/(Lic.)/D/SI-V1 dated 30/04/2014

Old Case 1996

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks
1.	Access of building			MR/NMR
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	9 Mtr.	12 Mtr.	MR
		NA	NA	NA
		NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	NA	NA	NA
		NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	NA	NA	NA
		NA	NA	NA
	c. Protection of exits			
		NA	NA	NA


	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization 	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	NA	NA	NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	05 Nos.	07 Nos.	MR
	<ul style="list-style-type: none"> • Types 	ABC, CO ₂	ABC, CO ₂	MR
	<ul style="list-style-type: none"> • IS marking 	Required	Provided	MR
6	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Length of hose reel hose 	NA	NA	NA
	<ul style="list-style-type: none"> • Nozzle diameter 	NA	NA	NA
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8	MOEFA			
9	Public Address System			
10	Automatic Sprinkler			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA

	Upper floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	○ Ground Level			
	• Discharge of main pump	NA	NA	NA
	• Head of main pump	NA	NA	NA
	• Number of main pumps	NA	NA	NA
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• auto Staring/Manual stopping	NA	NA	NA
	• Pump House Access	NA	NA	NA
	○ Terrace level			
	• Discharge of pump	NA	NA	NA
	• Head of the pump	NA	NA	NA
	• Power supply	NA	NA	NA
	• Auto starting of pump	NA	NA	NA
14	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	• Draw of connection	NA	NA	NA
	• Fire service inlet	NA	NA	NA
	• Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA

15	Exit Signage	NA	NA	NA
16	Provision of Lifts	NA	NA	NA
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC, Co ₂	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/2011/EH/2982 dated 15/11/2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended please. (Case is prior to 1996)


 Name:- Sh. M. K. Sharma
 Designation :- A. D.O. (CC)

Do (CA) - MP