

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:-011-23412593

E-mail ID: cfhq.dfire@nic.in

No. F6/DFS/MS/GH/2014/ MD2/1214

Dated 17/08/14

**FIRE SAFETY CERTIFICATE**

Certified that the **Nirmal Mahal International** located at **1519, Sangtrashan, Pahar Ganj, New Delhi** comprises of Ground floor+4 upper floor and (Ground floor,reception + 03 Guest room), 1<sup>st</sup> floor to 3<sup>rd</sup> floor (05 guest rooms at each floor) and 4<sup>th</sup> floor (staff room & staff Kitchen) with total 18 guest rooms was granted NOC by this department vide letter No.F6/DFS/MS/GH/2011/1055 dated 02-06-2011. The premises was re-inspected by the officer concerned of this department on 23-08-2014 in the presence of Mr. Suriender Singh Uppal (Prop.) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential, Sub-Division A-1 lodging or rooming Houses of Group A** for 18 guest rooms with effect from -----17/08/14 2014 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .....17/08/14..... at New Delhi by.

  
**(Dr. G. C. Misra)**  
Chief Fire Officer  
Delhi Fire Service  
Ph – 011-23414333

Copy to:-

1. The Joint. Commissioner of Police (Lic), First Floor,P.S. Defence Colony New Delhi.
2. Mr.Suriender Singh Uppal (Prop.), 1519, Sangtrashan, Pahar Ganj, New Delhi.24412/Joint.CP/lic./(H)dated08/07/2014.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry"

## INSPECTION REPORT

1. Name & address of the building : Nirmal Mahal International at 1519, Sangtrashan, Pahar Ganj, New Delhi.
2. Type of Occupancy : Residential (Guest house) **G+4floors (18 Guest rooms)**
3. Type of Case : **Renewal**
4. Details of previous NOC : F6/DFS/MS/GH/2011/1055 dated 02/06/2011
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 23/08/2014
- 7 Name of the Inspecting Officer : M. K. Sharma (Assistant Divisional Officer)
- 8 Name and designation of Officer from the building side : Sh. Suriender Singh Uppal(Prop.)
- 9 Year of Construction : 2009
10. Applicant's letter No. : 24412/Joint.CP/Lic.(H)dated New Delhi. Dated 08/07/2014

S No	Minimum standards on fire prevention and fire safety U/R 33	Existing Requirements	Provided at site	Remarks
1.	Access of building			MR/NMR
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	<p>NA</p> <p>NA</p> <p>NA</p>	<p>6 Mtr.</p> <p>NA</p> <p>NA</p>	<p>MR</p> <p>NA</p> <p>NA</p>
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper floors</li> <li>Basements</li> </ul>	<p>1 No.</p> <p>1 No.</p>	<p>1 No.</p> <p>1 No.</p>	<p>MR</p> <p>MR</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper floors</li> <li>Basements</li> </ul>	<p>0.80Mt.</p> <p>NA</p>	<p><b>1.17mtrs.to1.35mtrs.</b></p> <p>NA</p>	<p>MR</p> <p>NA</p>
	c. Protection of exits			
	Fire check door	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>



	<ul style="list-style-type: none"> <li>• Pressurization</li> </ul>	1 No.	1 No.	MR
	d. No of continuous staircase to terrace	1.0 Mtr.	1.0 Mtr.	MR
	e. Width Of Corridor	1.0 Mtr.	1.0 Mtr.	MR
	f. Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	NA	NA	NA
4	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	1 Nos.	1 Nos.	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ABC, CO <sub>2</sub> , Wco <sub>2</sub>	ABC, CO <sub>2</sub> , Wco <sub>2</sub>	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	Required	Provided	MR
6	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	01	01	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30Mtrs.	30Mtrs.	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	05MM	05MM	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	NA	NA	NA

	Upper floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	○ Ground Level			
	• Discharge of main pump	NA	NA	NA
	• Head of main pump	NA	NA	NA
	• Number of main pumps	NA	NA	NA
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• auto Staring/Manual stopping	NA	NA	NA
	• Pump House Access	NA	NA	NA
	○ Terrace level	NA	NA	NA
	• Discharge of pump	450 LPM	450 LPM	MR
	• Head of the pump	30mm	30mm	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive water Storage for fire fighting	NA	NA	NA
	• Under ground tank capacity	NA	NA	NA
	• Draw of connection	NA	NA	NA
	• Fire service inlet	NA	NA	NA
	• Access to tank	Required	Provided	MR



	• Overhead Tank capacity	5000 ltr.	5000 ltr.	MR
15	Exit Signage	NA	NA	NA
16	Provision of Lifts			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC, Co <sub>2</sub>	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule it is recommended to grant fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010. FSC is recommended please.

Signature of the Inspecting Officer

*M.K. Sharma*

Name :- M.K. Sharma  
Designation :- A. D.O. (CC)

Do(CD) - MR