

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

NO F 6 / DFS / MS / EH / 2014 / 1236

Dated 23/09/14

FIRE SAFETY CERTIFICATE

Certified that the **Pinch of Spice Restaurant**, located at **F - 90, Vishal Enclave, Distt. Centre, New Delhi** comprised of **Basement + Ground + 1st + 2nd floor** was granted NOC by this department vide letter No **F6/DFS/MS/EH/2011/2029** dated **19.08.2011**. The premises was re-inspected by the officers concerned of this department on 08.09.2014 in the presence of **Mr. Manpreet Singh**, Partner of the restaurant and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for **Class - D (Assembly)** occupancy with effect from 23 / 09 / 2014 for a period of three years in accordance with rule 36 unless renewed under 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under 38 of the Delhi Fire Service Rule 2010.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safety evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electric installation etc may be got verified from the concerned authorities.
5. Basement shall be used as per NCB.
6. This NOC may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
8. "The owner/ occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry"

Issued on 23 / 09 / 14 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Ph: - 011-23414250

Copy to: -

Mr. Manpreet Singh,
Pinch of Spice, F-90, Vishal Enclave,
District. Centre New Delhi

sv
Ang

- 2/4.
1. Name & address of the building : Pinch of Spice, F-90 Vishal Enclave, Distt. Centre New Delhi.
 2. Type of Occupancy : (Assembly) B + G + Ist + 2nd floor
 3. Type of Case : Renewal
 4. Details of previous NOC : F6/DFS/MS/EH/2011/2029 dated 19-08-2011
 5. Fire Safety directives letter No. : Nil
 6. Date of inspection : 08-09-2014
 7. Name of the Inspecting Officers : Divisional Officer Sunil Chawdhary
 8. Name and designation of officers
From the building side : Mr. Manpreet Singh
 9. Year of Construction : 1987
 10. Applicant's letter No. : nil

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Old case	Old case	Old case
	• Gate width	5 mtr	Provided	M/R
	• Width of internal road	N.A.	N.A.	N.A.
2.	<u>Number, Width, Type & Arrangement of Exits</u>			
	a. Number of staircases			
	• Upper Floors	2	Provided	M.R
	• Basement	2	Provided	M.R
	b. Width of staircases			
	• Upper Floors	1.5 mtr & 1. mtrs	1.5 mtr. & 1.20 mtr	M.R.
	• Basement	1.5 mtr & 1. mtrs	Provided	M.R
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R
	• Pressurization	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	Old case	Old case	Old case
	f. Door size	Old case	Old case	Old case
3.	Compartmentation.			

	<ul style="list-style-type: none"> • Fire Rating of shaft door 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> • Water Curtain 	N.R.	NR.	N.R.
	<ul style="list-style-type: none"> • Fire Dampers 	N.R.	N.R.	N.R.
<u>4.</u>	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	Required	Provided	M.R ✓
	<ul style="list-style-type: none"> • Upper floors 	Required	Provided	M.R ✓
<u>5.</u>	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	8Nos.	11	M.R ✓
	<ul style="list-style-type: none"> • Types 	ABC & CO ₂	provided	M.R.
	<ul style="list-style-type: none"> • IS marking 	required	provided	M.R
<u>6.</u>	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	1	Provided	M.R ✓
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m Required	Provided	M.R
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm Required	Provided	M.R.
<u>7.</u>	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> • Location of Main Panel 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> • Alternate source of power 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> • Hooter's Location 	N.R.	N.R.	N.R.
<u>8.</u>	MOEFA	Required	Provided	M.R ✓
<u>9.</u>	Public Address System.	Required	Provided	M.R
<u>10.</u>	Automatic Sprinkler system			
	<ul style="list-style-type: none"> • Basement 	N.R.	Provided	M.R ✓
	<ul style="list-style-type: none"> • Upper Floor 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	N.R.	N.R.	N.R.
<u>11.</u>	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100 mm	Provided	M.R ✓

	<ul style="list-style-type: none"> Hose Box 	1	Provided	M.R
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N.R.	N.R.	N.R
	<ul style="list-style-type: none"> Hose Box 	N.R.	N.R.	N.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump			
	➤ Head of Main pump			
	➤ Number of main pumps			
	➤ Jockey Pump out put			
	➤ Jockey pump head			
	➤ Standby pump out put			
	➤ Standby pump Head			
	➤ Auto Starting/Manual stopping			
	➤ Pump Hose Access			
	Terrace level			
	➤ Discharge of pump	900 lpm	Provided 900lpm +180 lpm	M.R.
	➤ Head of the pump	40 mtr.	Provided	MR
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	Required	Provided	M.R.
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity			
	➤ Draw -off connection			
	➤ Fire service inlet			
	➤ Access to tank			
	➤ Overhead Tank Capacity	10000 ltr.	15000 ltr	M.R.
15	Exit Signage.	Required	Provided	M.R.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.R.	N.R.	N.R.
	• Pressurization of Lift lobby	N.R.	N.R.	N.R.
	• Communication In lift Car	N.R.	N.R.	N.R.
	• Fireman's Grounding Switch	N.R.	N.R.	N.R.

17.	Standby power supply	Required	Provided	M.R
18.	Refuge Area			
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R.
19.	Fire Control Room			
	➤ Detector System Panel	N.R.	N.R.	N.R.
	➤ Flow Switch Panel	N.R.	N.R.	N.R.
	➤ PA system Panel	N.R.	N.R.	N.R.
	➤ Batter backup	N.R.	N.R.	N.R.
	➤ Building Floor plans	N.R.	N.R.	N.R.
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	N.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC vide letter No. F6/DFS/MS/EH/2011/2029 dated 19-08-2011 renewal under rule 35 of the Delhi Fire Service rule 2010 is recommended.

Signature of the Inspection Officer

Name Sunil Chawdhary

Designation DO (W)

Signature of the Inspection Officer

Name

Designation