

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO.F.6/DFS/MS/School/WZ/ 2014/848

Dated: 10 / 07 /2014

FIRE SAFETY CERTIFICATE

Certified that New Ways Concept School, Plot no-4, Behind CNG Pump, Near DDA Sector B-2, Narela, Delhi-110040 Comprised of Ground Floor Only owned/occupied by New Ways Concept School have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 23/06/2014 in the presence of Sh. Yesh pal Singh (Manager) and that the building / premises is fit for occupancy of Educational building with effect from ____ / ____ /2014 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on _____ at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250

Copy to:

1. The Principal, New Ways Concept School, Plot no-4, Behind CNG Pump, Near DDA Sector B-2, Narela, Delhi-110040
2. The Director of Education, Old Sectt. Delhi for information

Gr+floor only.

INSPECTION REPORT

1. Name & address of the building : *New ways Concept School, Plot No. 4, Behind CHS 6 Pump, Near DDA Sec-B-2 Narela Delhi-40*
2. Type of Occupancy : *Educational*
3. Type of Case : *New case/ Renewal*
4. Details of previous NOC : *N/A*
5. Fire Safety directives letter No : *Dir. of Edu. Circular - 01.03.2011*
6. Date of inspection : *23-6-14*
7. Name of the Inspecting Officers : *ADO (BW)*
8. Name and designation of officers from the building side : *Sh. Yeshpal Singh, Manager*
9. Year of Construction : *2013*
10. Applicant's letter No. : *lt No. Nil dt. 21.5.14*

Plot area-*1800 Sq. yards* Covered area-*800 Sq. yards* No's of student- *165* No's of class room- *09*

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<i>Accessable</i>	<i>Accessable</i>	<i>MR</i> ✓
	• Gate width	<i>-do-</i>	<i>-do-</i>	<i>MR</i> ✓
	• Width of internal road	<i>-</i>	<i>-</i>	<i>-</i>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			<i>N/A</i>
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	<i>1 m²</i>	<i>1.25 m²</i>	<i>MR</i> ✓
3	Compartmentation.			
	• Fire check door			<i>N/A</i>
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			
	• Basements	30 a/c per hour		<i>N/A</i>
	• Upper floors	12 a/c per hour		
5	Fire Extinguishers			

6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One at each floor 30 m 5 mm		

7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 			

8	MOEFA			
---	--------------	--	--	--

9	Public Address System.			
---	-------------------------------	--	--	--

10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 			

11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 			

12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 			


13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			

14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 			

	<ul style="list-style-type: none"> ➤ Access to tank • Overhead Tank capacity 			
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			N/A
17	Standby power supply			
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....NIL.....



Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]
[Handwritten Signature]
 1/7/14

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]
 28/6/14
 ADO (BW)

712
 7/14
 7/14