

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/EH/2014/1402/925

Dated: 24/07/14


FIRE SAFETY CERTIFICATE

Certified that the Restaurant/Eating House at Swaminarayan Akshardham, N.H.24, Off.Nizammuddin Bridge, Akshardham Setu, Delhi 92, owned/occupied by M/s Suvasini Charitable Trust, comprised of ground plus one upper floor was granted fire safety certificate vide letter no. F.6/DFS/MS/EH/2011/1532 dated 08.07.2011. The Restaurant was inspected by the officers concerned of this department on 14.07.2014 in the presence of Sh.Jayesh Gadhia, and found that the Restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group D Assembly Building "Restaurant" with effect from 24/07/14..... for a period of three years, subject to conditions printed overleaf.

Issued on 24/07/14..... at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Ph.011-23414333



To,

1. Sh.Jayesh Gadhia
M/s Suvasini Charitable Trust,
Swaminarayan Akshardham, N.H.24,
Off.Nizammuddin Bridge, Akshardham Setu,
Delhi 92
2. Dy.Health Officer
EDMC Health Department
Shahadra (South Zone)
Karkardooma, Shahadra, Delhi.

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : Restaurant /Eating House at Swaminarayan Akshardham N.H.24,Off.Nizammuddin Bridge, Akshardham Setu,Delhi- 92
2. Building Comprised of :Ground + one upper floor
2. Type of Occupancy : Assembly (Restaurant/ Eating House)
3. Type of Case : Renewal
4. Details of Previous FSC : F.6/DFS/MS/EH/2014/1532 Dated 08.07.2011
5. Fire Safety directives No : NBC Part IV
6. Date of Inspection : 17/07/2014
7. Name of the Inspecting Officer :DO Virendra Singh
8. Name of the designation of Officer
From the building side : Sh.Jayesh Gadhia (Manager)
9. Year of Construction : 2009
- 10.Applicant's letter No : Dated 23/06/2014

Sl.no.	Minimum Standards on fire prevention and fire safety U/R33	NBC Part IV Requirement	Provided at Site	Remarks
1	Access to building			MR/NMR
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12 Mtrs N/A N/A	30 Mtrs. N/A N/A	MR N/A N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	02 Nos N/A	03 Nos. N/A	MR N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	1.5 M N/A	1.35 ,1.46 M N/A	❖ MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	2.0 M	3.0 M	MR
	h. Door Size	2.0 Mtr.	3.0 M ,1.8 M	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	N/A Required N/A N/A N/A	N/A Sealed N/A N/A N/A	N/A MR N/A N/A N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A Required	N/A Provided	N/A MR
5.	Fire Extinguisher			
	<ul style="list-style-type: none"> • Total numbers • types • IS marking 	08 nos. ABC & Co2 ISI marked	12 Nos. ABC & Co2 ISI marked	MR MR MR

❖ The width of staircases had accepted earlier.

Note

6	First-aid-Hose Reels.			
	• Total numbers of each floor	2 nos.	3 nos.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	Heat & smoke	MR
	• Location of main panel	N/A	Provided	MR
	• Location of repeater panel	N/A	Provided	MR
	• Alternate source of power	N/A	Provided	MR
	• Hooters's location	N/A	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	• upper floors	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 MM	100 MM	MR
	• Number of hydrants r	2 Nos.	3 Nos.	MR
	• Hose Box	2 Nos.	3 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 M	40M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Auto	MR
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	1,00,000 Ltrs.	MR
	➤ Draw-off connection	N/A	Provided	MR
	➤ Fire service inlet	N/A	Provided	MR
	➤ Access to tank	N/A	Provided	MR
	• Overhead Tank capacity	10,000 ltrs.	35,000 ltrs.	MR
15	Exit Signage.	Required	Provided	MR

N/6

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

Fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measure as required under the rules. The fire safety certificate issued vide letter no. F.6/DFS/MS /EH/2011/1532 dated 08.07.2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name:-Virendra Singh
 Designation :- DO (ED)

