

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

No. F6/DFS/MS/2014/M02/1295

Dated: 17/10/14

FIRE SAFETY CERTIFICATE

Certified that the Community Hall at plot no.6, Karkardooma Institutional area, Delhi-92, owned/occupied by M/s Raj Priya Welfare Society, comprised of basement, ground plus two upper floors was granted NOC vide letter no.F6/DFS/MS/2006/3573 dated 08.12.2006. The Community hall building was inspected by the officer concerned of this department on 27.09.2014 in the presence of Sh.Bal Krishan Juneja (Owner) and found that the Community hall building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group D Assembly Building "Community Hall" with effect from ...17/10/14... for a period of three years, subject to conditions printed overleaf.

Issued on ...17/10/14... at New Delhi by



(Dr.G.C.Misra)  
Chief Fire Officer  
Ph.011-23414333



To,  
Sh.Bal Krishan Juneja  
Plot no.6, Karkardooma Institutional area,  
Delhi-92

### CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. Basement shall be used as per BBL.
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

1. Name & address of the building : Community Hall at plot no. 06,  
Karkardooma Institutional Area, Delhi
2. Building is comprised of : Basement, Ground + 2 upper floors.
3. Type of Occupancy : Assembly (Community Hall)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/2006/3573 dated 08.12.2006
6. Fire Safety direction letter No : F.6/MS/DFS/BP/2004/49 Dated 08.01.2004.
7. Date of Inspection : 27.09.2014
8. Name of the Inspecting officers : DO Virendra Singh
9. Name and designation of Officer  
from the building side : Sh. Bal Krishan Juneja (Owner)
10. Year of Construction : 2004
11. Applicant's letter No : 08.09.2014

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	NBC/BBL Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	12 Mtrs.	24 Mtr,	MR
		4.5 Mtrs.	4.5 Mtrs.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road			
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	02 Nos.	02 Nos.	MR
	• Upper Floor	2 nos.	02 Nos.	MR
	• Basement	2 nos.	02 Nos.	MR
	B. Width of Staircases			
	• Upper Floor	1.5 Mtrs.	1.5 M & 1.2 M	MR
	• Basement	1.5 Mtrs.	1.5 M each	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	1 no.	1 no.	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.5 M	1.5 M	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire rating of shaft door	0 2 hrs.	0 2 hrs.	MR
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	Required	Provided	MR
	• Upper floor	N/A	N/A	N/A



5.	Fire Extinguisher			
	• Total numbers	08 nos.	10 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	• Total numbers of each floor	1 no.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Heat or smoke	smoke	MR
	• Location of main panel	Control room	Ground floor	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooters's location	Staircase	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	1 no.	1 no.	MR
	• Hose Box	1 no.	1 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	900 LPM	900 LPM	MR
	➤ Head of Main Pump	39 Mtrs.	39Mtrs.	MR
	➤ Number of main pumps	1 No.	1No.	MR
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	Required	Auto	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	39 Mtrs.	39Mtrs.	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Auto	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	50,000 Ltrs.	50,000 Ltrs.	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	5,000 Ltrs.	10,000 Ltrs.	MR

NTG

15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	Required	Provided	MR
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC issued vide letter no. F.6/DFS/MS /2006/3573 dated 08.12.2006 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended for fire safety certificate .

Virendra Singh  
10/07/14

Signature of the Inspecting Officer

Name:-Virendra Singh

Designation :- DO (ED)