

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO.F.6./DFS/MS/School/WZ/ 2014/1273

Dated: 13 / 10 / 2014

FIRE SAFETY CERTIFICATE

Certified that Devraji Narayan Public School, Plot No. 12, E- Block, Swami Shradha Nand, Colony, Bhalswa Dairy, Delhi- 110042 is comprised of Two Blocks Ground Floor Only owned/occupied by Devraji Narayan Public School have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 01/10/2014 in the presence of Sh. Vikash Singh Chauhan and that the building / premises is fit for occupancy of Educational building with effect from 13 / 10 / 2014 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 13 / 10 / 14 at New Delhi


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
Email id: - cfowz.dlfire@nic.in

Copy to:

1. The Principal, Devraji Narayan Public School, Plot No. 12, E-Block, Swami Shradha Nand Colony, Bhalaswa Dairy, Delhi – 110042.
2. The Director of Education, Old Sectt. Delhi for information.

N/6
Two Blocks - Both G.F. only.

INSPECTION REPORT

1. Name & address of the building : Devrajji Marayan Public School, Plot No
2. Type of Occupancy : 12, E-Block, Swami Shradha Nand Colony, Bhalswa
3. Type of Case : New Case/ Renewal Educational
4. Details of previous NOC : Letter No. Dated:
5. Fire Safety directives letter No : circular of the director of Edn dt 01-3-11
6. Date of inspection : 01-10-14
7. Name of the Inspecting Officers : N.P. Sharma
8. Name and designation of officers
from the building side : Sh. V.S. Chauhan
9. Year of Construction : 2004
10. Applicant's letter No. : DMPS/Fire/002 dt 22-9-14
PA. 1200 Sqm. C.A. 400 sqm. No's - 270 approx. NOCR-10

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Dir. Of Edu/ dt NBC 1-3-11 | Provided at site | Remarks MR/NMR |
|--------|---|-------------------------------|------------------|-------------------|
| 1 | Access to building | | | |
| | • Road width | Accessible | Accessible | MR ✓ |
| | • Gate width | — | — | — |
| | • Width of internal road | — | — | — |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | — | — | — |
| | • Upper Floors | — | — | — |
| | • Basements | — | — | — |
| | b. Width of staircases | — | — | — |
| | • Upper Floors | — | — | — |
| | • Basements | — | — | — |
| | c. Protection of exits | — | — | — |
| | • Fire check door | — | — | — |
| | • Pressurization | — | — | — |
| | e. No. of continuous staircases to terrace | — | — | — |
| | g. Width of Corridor | — | — | — |
| | h. Door Size | one meter | one meter | MR ✓ |
| | | — | — | — |

N/7

| | | | | |
|----|--|-----------------|----------|------|
| 3 | Compartmentation. | NA | | |
| | • Fire check door | — | — | — |
| | • Sealing of electrical shafts | — | — | — |
| | • Fire Rating of shaft door | — | — | — |
| | • Water Curtain | — | — | — |
| | • Fire Dampers | — | — | — |
| 4 | Smoke Management System. | NA | | |
| | • Basements | 30 a/c per hour | — | — |
| | • Upper floors | 12 a/c per hour | — | — |
| 5 | Fire Extinguishers | | | |
| | • Total numbers | 04 | 04 | MR ✓ |
| | • Types | | ABC type | MR ✓ |
| | • IS marking | ISI marked | yes | MR ✓ |
| 6 | First-Aid Hose Reels. | NA | | |
| | • Total numbers on each floor | — | — | — |
| | • Length of hose reel hose | 30 m | — | — |
| | • Nozzle diameter | 5 mm | — | — |
| 7 | Automatic fire detection and alarming system. | NA | | |
| | • Type of detectors | — | — | — |
| | • Location of Main Panel | — | — | — |
| | • Location of Repeater Panel | — | — | — |
| | • Alternate source of power | — | — | — |
| | • Hooters' Location | — | — | — |
| 8 | MOEFA | — | — | — |
| 9 | Public Address System. | — | — | — |
| 10 | Automatic Sprinkler System. | NA | | |
| | • Basement | — | — | — |
| | • Upper Floor | — | — | — |
| | • Sprinkler above false ceiling | — | — | — |

N/S

| | | | | |
|----|---|-----|---|---|
| 11 | Internal Hydrants | N A | | |
| | <ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box | — | — | — |
| | | — | — | — |
| | | — | — | — |
| 12 | Yard Hydrants. | N A | | |
| | <ul style="list-style-type: none"> • Total number of hydrants • Hose Box | — | — | — |
| | | — | — | — |
| 13 | Pumping Arrangements. | N A | | |
| | <ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump | — | — | — |
| | | — | — | — |
| | | — | — | — |
| | | — | — | — |
| | | — | — | — |
| | | — | — | — |
| | | — | — | — |
| | | — | — | — |
| | | — | — | — |
| | | — | — | — |
| | | — | — | — |
| | | — | — | — |
| | | — | — | — |
| | | — | — | — |
| | | — | — | — |
| 14 | Captive Water Storage for fire fighting. | N A | | |
| | <ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity | — | — | — |
| | | — | — | — |
| | | — | — | — |
| | | — | — | — |
| 15 | Exit Signage. | — | — | — |

119

| | | | | |
|----|--|----|---|---|
| 16 | Provision of Lifts. | NA | | |
| | • Pressurization of Lift Shaft | — | — | — |
| | • Pressurization of Lift lobby | — | — | — |
| | • Communication In lift Car | — | — | — |
| | • Fireman's Grounding Switch | — | — | — |
| | • Lift Signage | — | — | — |
| 17 | Standby power supply | — | — | — |
| 18 | Refuge Area. | NA | | |
| | ➤ Total Area | — | — | — |
| | ➤ Location | — | — | — |
| 19 | Fire Control Room | NA | | |
| | • Detector System Panel | — | — | — |
| | • Flow Switch Panel | — | — | — |
| | • PA System Panel | — | — | — |
| | • Batter backup | — | — | — |
| | • Building Floor Plans | — | — | — |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | — | — | — |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer 02-10-14

Signature of the Inspecting Officer

Name M.P. Sharma

Name

Designation AD.O.R.

Designation

DOP/W

See DFA is Deced at C-4 in this file A.
 Please put up fresh DFA with amended date of inspection.

Guish
21/11/14



CPD/996
10/10/14