

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593


No.F.6/DFS/MS/School/2014/ *sz/1259*

Dated: *07/10/14*

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Co-ed. Sr. Sec. School**, Kazipur, New Delhi -110073 comprised of ground floor plus one upper floor and there are two blocks namely old block & new block, having total 27 rooms (Including Class Rooms, Offices & CAL Lab. etc.) was issued NOC by this department vide letter F.6/DFS/MS/School/2011/3556 dated 16.12.2011. The School building was re-inspected by the officer concerned of this department on 30.08:2014 in the presence of Sh Anil Solanki (Teacher) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....*07/10/14*..... at New Delhi.



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

*ok sm
30/9/14*

Copy to:-

1. The Principal,
Govt. Co-ed. Sr. Sec. School, Kazipur,
New Delhi -110073.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

School is having two blocks namely Old block and New Block each is comprised of Ground floor plus one upper floor (Govt. Co-ed. Sr. Sec. School, Kazipur, New Delhi -110073)

INSPECTION REPORT

1. Name & address of the building : Govt. Co-ed. Sr. Sec. School, Kazipur, New Delhi -110073.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/School/2011/3556 dated 16.12.2011
5. Fire Safety directives letter No : N/A
6. Date of inspection : 30.08.2014
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Sh Anil Solanki (Teacher)
9. Year of Construction : Old Block 1994-95 & New Block 2004-05
10. Applicant's letter No. : KZPR/2014-2015/25/26 dated 16.08.2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible — —	06 mtrs 3.6 mtr —	M/R — —
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	02 No's(Each Block) N/A	02 No's(Each Block) N/A	M/R No basement
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	— N/A	Old Block (137 cms each & New Block (155 cms each) N/A	M/R, Old Case No basement
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace			
	e. Width of Corridor			
		—	152 cms each	M/R
	f. Door Size	N/A	96 cms each (Double doors)	M/R, Old Case
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	N/A	N/A	No basement

2/5

School is having two blocks namely Old block and New Block each is comprised of Ground floor plus one upper floor (Govt. Co-ed. Sr. Sec. School, Kazipur, New Delhi -110073)

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.	No Lift		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

N/6

School is having two blocks namely Old block and New Block each is comprised of Ground floor plus one upper floor (Govt. Co-ed. Sr. Sec. School, Kazipur, New Delhi -110073)

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter number F.6/DFS/MS/School/2011/3556 dated 16.12.2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Sandeep
19/12/14

Signature of Inspecting Officer

Name:- Sandeep Duggal


Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

~~Signature of Inspecting Officer~~

~~Name~~

~~Designation~~



Renewal F.S.C. for G+1 floor school bldg. is put up for signature please.

Retomer
22/12/14

121