

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

Fax: 011-23412593, Email: [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in), Ph. 011-23414333


No. F.6/DFS/MS/EH/2014/SZ/ 1269

Dated: 09/10/14

**FIRE SAFETY CERTIFICATE**

Certified that M/s The Great Kabab Factory Restaurant at shop no. 38, MGF Metropolitan Mall, Saket, New Delhi running at 1<sup>st</sup> floor of the building comprised of two tier basement, ground plus seven upper floors was granted NOC by this department vide letter No. F6/DFS/MS/EH/2011/1995 dated 16.08.2011. The premises was re-inspected by the officer concerned of Delhi Fire Service on 22.09.2014 in the presence of Sh. Chander Shekhar (Manager ) of the restaurant and observed that fire safety norms as required under Rule 33 of Delhi Fire Service Rules, 2010 have deemed complied and that the building / premises is fit for occupancy class-D "Assembly building Restaurant" with effect from 09/10/14 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on .....09/10/14..... at New Delhi by



(Dr. G.C. Misra)  
Chief Fire Officer

Copy to: -

1. The DHO(South Zone), Office of Deputy Health Officer, M.C.D. Health Department South Zone, Green Park, New Delhi,
2. The Manager, M/s The Great Kabab Factory Restaurant at shop no. 38, 1<sup>st</sup> Floor, MGF Metropolitan Mall, Saket, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
2. Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The Basement shall be used strictly as per the provisions of Building Bye Laws.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1	Name & address of the building	M/s The Great Kabab Factory Restaurant at shop no. 38, 1st floor, MGF Metropolitan Mall, Saket, New Delhi-110017		
2	Type of Occupancy	Assembly Building "D" Restaurant		
3	Type of case	Renewal		
4	Details of previous NOC	No. F6/DFS/MS/EH/2011/1995 dated 16.08.2011		
5	Fire safety directives letter No	Nil		
6	Date of inspection	22.09.2014		
7	Name of the inspecting Officers :	D.O. (South) D.P. Bhardwaj , ADO D.B. Mukherjee		
8	Name and designation of officers	Sh. Chander Shekhar (Manager)		
	from the building side			
9	Year of construction			
10	Applicant's letter No.	Nil, Dated 08.09.2014	(Restaurant running at 1st floor shop no. 38)	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	<b>Access to building</b>			
	1) Road width	Required	10 Mtr Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	2 Nos	2 Nos. Near Restaurant Provided by Mall	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.5 Mtrs	1.5 & 1.42 Mtrs Provide by Mall	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Required	Provided by Mall	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Two Exit	2.3Mtr , 1.3 Mtr & 0.70 Mtr (3 Nos.) Provided	MR
3	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	basement	30 a/c per hour	N/A	N/A
		12 a/c per hour	Mech. Ventilation Provided by Mall	MR
	upper floors			
5	<b>Fire Extinguishers</b>			
	total numbers		6 Nos	MR
	Types		ABC, Water Co2	MR
	ISI marking	ISI	Yes	MR

<b>6</b>	<b>First-Aid Hose Reels.</b>	<b>Provided &amp; Maintain by Mall</b>		
	total numbers on each floor	do	do	do
	Length of Hose reel hose	do	do	do
	Nozzle Diameter	do	do	do
<b>7</b>	<b>Automatic fire detection and alarming system:-</b>	<b>Provided &amp; Maintain by Mall</b>		
	Type of detectors	do	do	do
	location of Main Panel	do	do	do
	location of Repeater panel	do	do	do
	Alternate source of power	do	do	do
	hooter's location	do	do	do
<b>8</b>	<b>MOEFA</b>	<b>Provided &amp; Maintain by Mall</b>		
<b>9</b>	<b>Public Address System.</b>	<b>Provided &amp; Maintain by Mall</b>		
<b>10</b>	<b>Automatic Sprinkler System.</b>	<b>Provided &amp; Maintain by Mall</b>		
	basement	do	do	do
	upper floors	do	do	do
	sprinkler above false ceiling	do	do	do
<b>11</b>	<b>Internal Hydrants</b>	<b>Provided &amp; Maintain by Mall</b>		
	Size of riser/down-corner	do	do	do
	Number of Hydrants per floor	do	do	do
	hose Box	do	do	do
<b>12</b>	<b>Yard Hydrants.</b>	<b>Provided &amp; Maintain by Mall</b>		
	total number of hydrants	do	do	do
	hose box	do	do	do
<b>13</b>	<b>Pumping arrangements</b>	<b>Provided &amp; Maintain by Mall</b>		
	<b>1. Ground level</b>			
	a. Discharge of main Pump	do	do	do
	b. Head of main pump	do	do	do
	c. Number of main pumps	do	do	do
	d. jockey pump out put	do	do	do
	e. jockey pump head	do	do	do
	f. Standby Pump output	do	do	do
	g. Stanby Pump head	do	do	do
	h. Auto Starting/Manual stopping	do	do	do
	pump house access	do	do	do
	<b>2. Terrace level</b>	do	do	do
	a. Discharge of pump	do	do	do
	b. head of the pump	do	do	do
	c. Power supply	do	do	do
	d. Auto starting of pump	do	do	do
<b>14</b>	<b>Captive water storage for fire fighting</b>	<b>Provided &amp; Maintain by Mall</b>		
	1. Underground tank capacity	do	do	do
	a. Draw-off connection	do	do	do
	b. fire service inlet	do	do	do
	c. Access to tank	do	do	do
	Over head tank Capacity	do	do	do
<b>15</b>	<b>Exit Signage.</b>	do	do	do
<b>16</b>	<b>Provision of lifts.</b>	<b>Provided &amp; Maintain by Mall</b>		
	a. Pressurization of lift shaft	do	do	do
	b. pressurization of lift lobby	do	do	do
	c. communication in lift car	do	do	do
	d. Fireman's grounding switch	do	do	do
	e. Lift signage	do	do	do

	<b>Standby power supply</b>	<b>Provided &amp; Maintain by Mall</b>		
8	<b>Refuge Area.</b>	<b>Provided &amp; Maintain by Mall</b>		
	total area	do	do	do
	location	do	do	do
19	<b>Fire control room</b>	<b>Provided &amp; Maintain by Mall</b>		
	a. detector system Panel	do	do	do
	b. Flow switch Panel	do	do	do
	c. PA system Panel	do	do	do
	d. Batter backup	do	do	do
	e. Building floor plans	do	do	do
20	<b>Special Fire Protection systems for protection of special risks, if any: N/A</b>			

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules of NOC issued vide letter no. **No. F6/DFS/MS/EH/2011/1995 dated 16.08.2011** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

Signature of the Inspecting Officer  
 Name D.P. BHARDWAJ  
 Designation:- D.O. (South)

25/9/14

Signature of the Inspecting Officer  
 Name D.B. Mukherjee  
 Designation:- A.D.O.

25/9/2014