

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

Fax: 23412593, Tel: 011-23414333

NO.F6/DFS/MS/EH/2014/ 52/1234

Dated: 22/08/14

FIRE SAFETY CERTIFICATE

Certified that KFC, (a unit of M/s Yum! Restaurants India Private Limited) located at ground & first floor of property no. F-4, Kalkaji, New Delhi-110019 owned/ occupied by M/s Yum! Restaurants India Private Limited. The building is comprised of basement, stilt, ground and three upper floors. The premises was inspected by the officers concerned of this department on 29/08/14 in the presence of Mr. Brij (Project Supervisor) and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Assembly (Restaurant) with effect from ~~22/08/14~~ or a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ~~22/08/14~~ at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer

Copy to:

1. Dy. Health Officer,
SDMC, health Department Central Zone,
Jal Vihar, Lajpat Nagar, New Delhi.
2. The Director
KFC, (a unit of Yum! Restaurant India Pvt. Ltd)
Property No. F-4, Kalkaji, New Delhi-110019.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of NBC
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form " [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

211

INSPECTION REPORT

1. Name & address of the building:- KFC, (a unit of M/s Yum ! Restaurants India Private Limited) ,ground & first floor of property no. F-4, Kalkaji, New Delhi-110019
2. Type of occupancy:- Assembly, Group – D, Restaurant
3. Type of case:- New
4. Details of previous NOC:- Nil
5. Fire safety directives No.- Nil
6. Date of inspection:-12/09/2014
7. Name of the inspecting officer:- D.P.Bhardwaj, D.O (South) & D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer from the building side:- Mr.Brij (Project Supervisor)
9. Year of construction:- 2013
10. Applicant's letter no:- Letter from Dy. Health Officer, Central Zone, SDMC and party letter dt.30/07/2014
Building is comprised of basement, stilt, ground & three upper floors.
Restaurant is at ground and first floor.


S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 m	Provided	MR
	2) Gate width	4.5m	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 nos.	Provided	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.50 mtrs.	1.50 mtrs & 1.25 mtrs.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	Provided	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2 mtr.	Provided two exits having width of 2 mtrs. & 1.5 mtrs.	MR
3.	Compartmentation			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	N/A	N/A
	2) Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	06 nos.	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	One	Provided	MR
	2) Length of hose reel hose	30 m	Provided	MR

7.	Automatic Fire Detection & Alarming System- Not required but provided			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System- Not required but provided			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	Provided	MR
	2) Number of hydrants per floor	01	Provided	MR
	3) Hose box	01	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	Provided	MR
	b) Head of pump	40 m	Provided	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 Ltrs.	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided DG Set	MR
18.	Refuge Area			
	Total area	N/A	N/A	N/A
	location	N/A	N/A	N/A

19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the restaurant were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010. Accordingly DFA is prepared and put up for perusal and sign please.


15/9/14

Signature of the inspecting officer
Name :- D.P.Bhardwaj.
Designation :- Div. Officer (South).


15/9/14

Signature of the inspecting officer
Name :- D.B. Mukherjee.
Designation :- Assitt. Div. Officer (BCP).