

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/2014/School/w2/1274

Dated: 13/10/2014

FIRE SAFETY CERTIFICATE

Certified that New Sky land Public School, B-Block, Avantika, Sector-1, Rohini, Delhi-110085 comprised of Ground + Two upper floors owned / occupied by New Sky land Public School has already been issued fire safety certificate vide this office letter No F-6/DFS/MS/School/2011/3033 dated 17/11/2011. The premise was re-inspected by the officer concerned and all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 25/09/2014 in the presence of Mrs. Anita Sharma and that the building / premises is fit for occupancy of Group Class B (Educational) with effect from 13/10/2014 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 13/10/14 at New Delhi by


13/10
(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Principal, New Sky land Public School, B-Block, Avantika, Sector-1, Rohini, Delhi-110085
2. The Director of Education, Old Secretariat, Delhi-110054

n/6

one Block of G F + FF + 2nd FF

INSPECTION REPORT

1. Name & address of the building : New sky land public school, B-Block.
2. Type of Occupancy : Arantika, Sector-1 Rohini, Delhi's educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F-6/DPS/MS/school/2011/3033 Dated: 17-11-11
5. Fire Safety directives letter No : Circular of The director of Edn dt/01-3-11
6. Date of inspection : 25-9-14
7. Name of the Inspecting Officers : N.P. Sharma
8. Name and designation of officers from the building side : Ms Amila Sharma
9. Year of Construction : 2000
10. Applicant's letter No. : NSPS/ND/2014-2015/63 dt 13-9-14
PA 200 Syds. CA 160 Syds, Nos-198, No CR-9.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu/ NBC	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	-	-	-
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	P	MR
	• Upper Floors	01	02	MR
	• Basements	-	-	-
	b. Width of staircases	R	P	MR
	• Upper Floors	1.5mts	1- 1.35mts 2- 1.10mts	MR
	• Basements	-	-	-
	c. Protection of exits	-	-	-
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	one metr	one metr	MR
		-	-	-

N/D

3	Compartmentation.	NA		
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4	Smoke Management System.	NA		
	• Basements	30 a/c per hour	—	—
	• Upper floors	12 a/c per hour	—	—
5	Fire Extinguishers			
	• Total numbers	one @ 300m ² 02	06	MR ✓
	• Types	ISI marked	ABC type	MR ✓
	• IS marking		yes	MR ✓
6	First-Aid Hose Reels.			
	• Total numbers on each floor	one @ each floor	P	MR ✓
	• Length of hose reel hose	30 m	P	MR ✓
	• Nozzle diameter	5 mm	P	MR ✓
7	Automatic fire detection and alarming system.	NA		
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8	MOEFA	—	—	—
9	Public Address System.	—	P	—
10	Automatic Sprinkler System.	NA		
	• Basement	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—

11	Internal Hydrants	NA		
	• Size of riser/down-comer	-	-	-
	• Number of hydrants per floor	-	-	-
	• Hose Box	-	-	-
12	Yard Hydrants.	NA		
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13	Pumping Arrangements.			
	• Ground Level	-	-	-
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/ Manual stopping	-	-	-
	➤ Pump House Access	-	-	-
	• Terrace level			
	➤ Discharge of pump	450 lpm	P	MR
	➤ Head of the pump	40 m	P	MR
	➤ Power Supply	-	-	-
	➤ Auto Starting of pump	-	-	-
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	-	-	-
	➤ Draw-off connection	-	-	-
	➤ Fire service inlet	-	-	-
	➤ Access to tank	-	-	-
	• Overhead Tank capacity	10000	10000	MR
15	Exit Signage.	-	P	-

N/9

16	Provision of Lifts.	NA		
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	Standby power supply	—	—	—
18	Refuge Area.	NA		
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room	NA		
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/DPS/MS/School/2011/3033 dated 17-11-11 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer *(Signature)*
25-9-14

Name N. P. Sharma

Designation ADO R,

Signature of the Inspecting Officer

Name

Designation

(Signature)
(Signature)

