

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/dfs/ms/2014/w2/1287

Dated: 17/10/2014


FIRE SAFETY CERTIFICATE

Certified that the Plot No. E-1, Udyog Nagar, Industrial Area, Rohtak Road, New Delhi-110041 comprised of Basement+G+02 upper Floors, owned/occupied by . E-1, Udyog Nagar, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 23-09-2014 in the presence of Mr. Riekey and that the building/premises is fit for Class Industrial occupancy with effect from ...17/10/14..... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Following fire safety directives must be adhered to:-

- 1) All the means of escape shall be kept free of all type of obstruction all the time.
- 2) All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3) All the fire fighting equipment shall be maintained in perfect working condition all the time and lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4) Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
- 5) Basement shall be used as per NBC.
- 6) This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
- 8) "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

Issued on.....17/10/14..... at New Delhi by


Santokh Singh
Chief Fire Officer
Delhi Fire Service

E-mail : cfowz.dlfire@nic.in
Phone : 011-23414250

Copy to: Mr. Anurag Chawla

Plot No. E-1, Udyog Nagar, Industrial Area, Rohtak Road, New Delhi-110041: 

N/8

1. Name & address of the building : Plot No. E-1, Udyog Nagar, Industrial Area, Rohtak Road, New Delhi-110041. (Basement+G+02 upper Floors)
2. Type of Occupancy : Industrial
3. Type of Case : Addition/Altration (Industrial) *NEW /*
4. Details of previous NOC : F-6/DFS/MS/98/680 dated 30.03.98
5. Fire Safety directives letter No. : F-6/DFS/MS/BP/2008/971 dated 07.04.2008
6. Date of inspection : 23-09-2014
7. Name of the Inspecting Officers : Sunil Chawdhary D.O. (West)
8. Name and designation of officers
From the building side : Mr. Riekey
9. Year of Construction : 2008
10. Applicant's letter No. : Nil dated Nil

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06mtrs	Provided ✓	M.R
	• Gate width	4.5 mtr	Provided ✓	M.R
	• Width of internal road	N.A.	N.A.	N.A.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided ✓	M.R.
	• Basement	02	Provided ✓	M.R.
	b. Width of staircases			
	• Upper Floors	1.25 mtr	P 1.60 mtr app.	M.R.
	• Basement	1.25 mtr	Provided " "	M.R.
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R
	• Pressurization	N.R	N.R	N.R.
	d. No. of continuous staircases to terrace	01	Provided	M.R.
	e. Width of Corridor	N.A.	N.A.	N.A.
	f. Door size	1.25 mtr	Provided	M.R.

4. Details of previous NOC : F-6/DFS/MS/98/680 dated 30.03.98
5. Fire Safety directives letter No. : F-6/DFS/MS/BP/2008/971 dated 07.04.2008
6. Date of inspection : 23-09-2014
7. Name of the Inspecting Officers : Sunil Chawdhary D.O. (West)
8. Name and designation of officers
- From the building side : Mr. Riekey
9. Year of Construction : 2008
10. Applicant's letter No. : Nil dated Nil

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06mtrs	Provided ✓	M.R
	• Gate width	4.5 mtr	Provided ✓	M.R
	• Width of internal road	N.A.	N.A.	N.A.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided ✓	M.R.
	• Basement	02	Provided ✓	M.R.
	b. Width of staircases			
	• Upper Floors	1.25 mtr	P 1.60 mtr app.	M.R.
	• Basement	1.25 mtr	Provided " "	M.R.
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R.
	• Pressurization	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace	01	Provided	M.R.
	e. Width of Corridor	N.A.	N.A.	N.A.
	f. Door size	1.25 mtr	Provided	M.R.
3.	Compartmentation.			
	• Fire check door	Required	Provided	M.R. ✓
	• Sealing of electrical shafts	Required	Provided	M.R.
	• Fire Rating of shaft door	Required	Provided	M.R.
	• Water Curtain	N.R.	N.R.	N.R.

N/10

13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	2280 LPM	provided	M.R
	➤ Head of Main pump	40MH	provided	M.R
	➤ Number of main pumps	02	provided	M.R
	➤ Jockey Pump out put	180 LPM	provided	M.R
	➤ Jockey pump head	40 MH	provided	M.R
	➤ Standby pump out put	2280 LPM	provided	M.R
	➤ Standby pump Head	40MH	provided	M.R
	➤ Auto Starting/Manual stopping	Required	provided	M.R
	➤ Pump Hose Access	Required	provided	M.R
	Terrace level			
	➤ Discharge of pump	N.R.	N.R.	N.R.
	➤ Head of the pump	N.R.	N.R.	N.R.
	➤ Power supply	N.R.	N.R.	N.R.
	➤ Auto Starting of pump	N.R.	N.R.	N.R.
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	1,00000 ltrs	Provided	M.R.
	➤ Draw -off connection	Required	provided	M.R
	➤ Fire service inlet	Required	provided	M.R
	➤ Access to tank	Required	provided	M.R
	➤ Overhead Tank Capacity	20,000 ltrs	provided	M.R
15	Exit Signage.	Required	provided	M.R
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.R.	N.R.	N.R.
	• Pressurization of Lift lobby	N.R.	N.R.	N.R.
	• Communication In lift Car	Required	provided	M.R
	• Fireman's Grounding Switch	Required	provided	M.R
	• Lift Signage	Required	provided	M.R
17.	Standby power supply	Required	provided	M.R
18.	Refuge Area			
	➤ Total Area	N.A.	N.A.	N.A.

N/11

	➤ Flow Switch Panel	N.A.	N.A.	N.A.
	➤ PA system Panel	N.A.	N.A.	N.A.
	➤ Battery backup	N.A.	N.A.	N.A.
	➤ Building Floor plans	N.A.	N.A.	N.A.
	20. Special Fire Protection Systems for Protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC vide letter No. F-6/DFS/MS/98/680 dated 30.03.98 renewal under rule 35 of the Delhi Fire Service rule 2010 is recommended.

Signature of the Inspecting Officer

Name : Sunil Chawdhary

Designation : D.O. (West)

Signature of the Inspecting Officer

Name :

Designation :

	➤ Head of Main pump	40MH	provided	M.R
	➤ Number of main pumps	02	provided	M.R
	➤ Jockey Pump out put	180 LPM	provided	M.R
	➤ Jockey pump head	40 MH	provided	M.R
	➤ Standby pump out put	2280 LPM	provided	M.R
	➤ Standby pump Head	40MH	provided	M.R
	➤ Auto Starting/Manual stopping	Required	provided	M.R
	➤ Pump Hose Access	Required	provided	M.R
	Terrace level			
	➤ Discharge of pump	N.R.	N.R.	N.R.
	➤ Head of the pump	N.R.	N.R.	N.R.
	➤ Power supply	N.R.	N.R.	N.R.
	➤ Auto Starting of pump	N.R.	N.R.	N.R.
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	1,00000 ltrs	Provided	M.R.
	➤ Draw -off connection	Required	provided	M.R
	➤ Fire service inlet	Required	provided	M.R
	➤ Access to tank	Required	provided	M.R
	➤ Overhead Tank Capacity	20,000 ltrs	provided	M.R
15	Exit Signage.	Required	provided	M.R
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.R.	N.R.	N.R.
	• Pressurization of Lift lobby	N.R.	N.R.	N.R.
	• Communication In lift Car	Required	provided	M.R
	• Fireman's Grounding Switch	Required	provided	M.R
	• Lift Signage	Required	provided	M.R
17.	Standby power supply	Required	provided	M.R
18.	Refuge Area			
	➤ Total Area	N.A.	N.A.	N.A.
	➤ Location	N.A.	N.A.	N.A.
19.	Fire Control Room			
	➤ Detector System Panel	N.A.	N.A.	N.A.