

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/2014/M02/1296

Dated: 17/10/14

FIRE SAFETY CERTIFICATE

Certified that the S.K.Eastend Party Hall running at ground floor level of a building comprised of basement, ground plus two upper floors at Star City Mall, Mayur Vihar-1, Delhi-91, owned/occupied by M/s S.K.Eastend Party Hall, was granted FSC vide letter no.F6/DFS/MS/2011/3036 dated 17.11.2011. The Banquet hall building was inspected by the officer concerned of this department on 01.10.2014 in the presence of Sh. Inder Sharma (GM) and found that the banquet hall building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group D Assembly Building "Banquet Hall" with effect from ..17/10/14... for a period of three years, subject to conditions printed overleaf.

Issued on17/10/14..... at New Delhi by



(Dr. G. C. Misra)
Chief Fire Officer
Ph.011-23414333



To,

Sh. Satish Kapur
M/s S.K.Eastend Party Hall
Star City Mall, Mayur Vihar-1,
Delhi -91.

Copy to:-

The Dy. Health Officer,
East Delhi Municipal Corporation, Health Department,
Shahdara (South) Zone, Karkardooma, Shahdara, Delhi

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. Basement shall be used as per BBL.
7. "The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

N/10

1. Name & address of the building : S.K .Eastend Party Hall at Grade Level, Star City Mall ,
Mayur Vihar-1, Delhi -91.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal
4. Details of Previous FSC : F.6/DFS/MS/2011/3036 dated 17.11.11.
5. Fire Safety directives No : F.6/DFS/MS/2011/2167 Dated 06.09.11
6. Date of Inspection : 01.10.2014
7. Name of the Inspecting Officer : ADO Suresh Singh
8. Name of the designation of Officer
From the building side : Sh.A.K.Kapoor(Manager)
9. Year of Construction : 2006
10. Applicant's letter No : NIL

	Minimum Standards on fire prevention and fire safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	06 Mtrs	06 Mtrs.	MR
	• Gate width	N/A	6 Mtrs.	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	B. Width of Staircases	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	2.0 Mtrs	2.0 Mtrs	MR
	h. Door Size	2.0 Mtrs.	2.0 Mtrs.	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire rating of shaft door	2 hrs.	2 hrs.	MR
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	Required	Provided	MR
4	Smoke Management System.			
	• Basement	30a/c per hour	Provided	MR
	• Upper floor	12 a/c per hour	Provided	MR

❖ Basement & upper floors are not part of banquet hall

N/11

5.	Fire Extinguisher			
	• Total numbers	06 no.	06 No.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	• Total numbers of each floor	1 no.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Heat & smoke	Provided	MR
	• Location of main panel	Control Room	Provided	MR
	• Location of repeater panel	Security Room	Provided	MR
	• Alternate source of power	Battery & DG Set	Provided	MR
	• Hooters's location	Different Location	Different Location	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	provided	MR
10	Automatic Sprinkler System.	Required	Provided	MR
	❖ Basement	Required	Provided in entire basement	MR
	• upper floor	Required	Provided	MR
	• sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	• size of riser/down-comer	150 mm	150 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose Box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	1 no.	1 no.	MR
	• Hose Box	1 no.	1 no.	MR
13	❖ Pumping Arrangements	Provided for entire mall building		
	• Ground Level	Required	Provided	MR
	➤ Discharge of main Pump	2850 LPM	2850 LPM	MR
	➤ Head of Main Pump	70 Mtrs.	70 mtrs	MR
	➤ Number of main pumps	2 nos.	2 nos.	MR
	➤ Jockey pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	70 Mtrs.	70 mtrs.	MR
	➤ Standby pump out put	2850 LPM	2850 LPM	MR
	➤ Standby pump Head	70 Mtrs	70 Mtrs.	MR
	➤ Auto Starting /Manual stopping	Auto	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	39 M	39 M	MR
	➤ Power supply	Auto	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

❖ Water tank & all pumps are on terrace.

N/12

14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	2,00,000 Ltrs.	2,00,000 Ltrs.	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	2,50,000 Ltrs.	2,50,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage			
17	Standby power supply	Required	1000 KVA	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	Required	Provided	MR
	• Flow switch panel	Required	Provided	MR
	• PA system panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	Required	Provided	MR
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested checked and found functional at the time of inspection. The FSC for entire mall was renewed vide this office letter no. F.6/DFS/MS/2014/806 Dated 30.06.2014.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no. F.6/DFS/MS/2011/3036 dated 17.11.2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended fire safety certificate.

Singh
9.10.14

Signature of the Inspecting Officer
Name:-Suresh Singh
Designation :- ADO (Shah.)

DO (ED)

Submitted for approval please.

12/10/14

