

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/SCHOOL/2014/w2/1256

Dated: 07/10/14

**FIRE SAFETY CERTIFICATE**

Certified that the **S.G.N. Public School** at **H-243, Kunwar Singh Nagar, New Delhi-110041** comprised of **Ground + one upper floor** only owned / occupied by **Sadguru Consciousness Society (Regd.)** has already been issued NOC / FSC by this department vide letter **No. F.6/DFS/MS/10/44 dated 06.01.2010**. The premises was re-inspected by the officer concerned of this department on **16/9/2014** in the presence of **Sh. Raj Kumar (Principal)** and observed that Fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by **Director of Education, GNCT of Delhi vide letter No. 262-362 dated 17.01.2005** and that the building / premises is fit for occupancy class **Educational** (Group B) with effect from **07/10/14**...for a period of three years subject to conditions printed below.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
3. The trained fire- fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)
- 8.

Issued on 07/10/14 at New Delhi by.

(SANTOKH SINGH)

**CHIEF FIRE OFFICER,**  
**Phone:-23414250**

E-mail: cfowz.dlfire@nic.in.

**Copy to :-**

1. Raj Kumar(Principal), S.G.N. Public School, H-243, Kunwar Singh Nagar, Nangloi, Delhi-11041
2. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi-110054.

N/A

## INSPECTION REPORT

1. Name & address of the building: SGN Public school H-243Kunwar Singh Nagar  
Nangloi Delhi- 110041
2. Type of Occupancy : Educational (G+1)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No- F6/DFS/MS/10/44 Dated 06/01/10
5. Fire Safety directives Letter No. : DOE Circular Dated 17/01/2005
6. Date of inspection : 16/9/2014
7. Name of the Inspecting Officer : A. K.-Jaiswal
8. Name and designation of Officer  
from the building side : Raj Kumar (Principal)
9. Year of Construction : 2006
10. Applicant's letter No. : -SGN/PS/2014/20 Dated 01/09/2014

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE. Circ. Dated 17/01/2005 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	No basement	N/A	N/A
	b. Width of staircases			
	• Upper floors	Old Case	Old Case	Old Case
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	Old Case	Old Case	Old Case
	e. Width Of Corridor	Old Case	Old Case	Old Case
	f. Door Size	Old Case	Old Case	Old Case
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	30 a/c per hour	N/A	N/A

5. Fire Safety directives Letter No. : DOE Circular Dated 17/01/2005

6. Date of inspection : 16/9/2014

7. Name of the Inspecting Officer : A. K.-Jaiswal

8. Name and designation of Officer

from the building side : Raj Kumar (Principal)

9. Year of Construction : 2006

10. Applicant's letter No. : -SGN/PS/2014/20 Dated 01/09/2014

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE. Circ. Dated 17/01/2005 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	No basement	N/A	N/A
	b. Width of staircases			
	• Upper floors	Old Case	Old Case	Old Case
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	Old Case	Old Case	Old Case
	e. Width Of Corridor	Old Case	Old Case	Old Case
	f. Door Size	Old Case	Old Case	Old Case
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	6	7	M/R
	• Types	ISI marked ABC/CO <sub>2</sub>	Provided	M/R
	• IS marking	Required	Provided	M/R

6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	M/R
	• Length of hose reel hose	30 mtr	Provided	M/R
	• Nozzle diameter	5 mm	Provided	M/R
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater	N/A	N/A	N/A
	• Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	N/A		
	➤ Discharge of pump	220 LPM	Provided	M/R
	➤ Head of the pump	40 MH	Provided	M/R
	➤ Power supply	Required	Provided	M/R

	• Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	N/A		
	➤ Discharge of pump	220 LPM	Provided	M/R
	➤ Head of the pump	40 MH	Provided	M/R
	➤ Power supply	Required	Provided	M/R
	➤ Auto starting of pump	Required	Provided	M/R
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	2500 Ltr	Provided	M/R

N/16

15	Exit Signage	Required	Provided	M/R
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/10/44 Dated 06/01/10 renewal under rule 35 of the Delhi Fire Service Raules 2010 is recommended.

*Ak Jaiswal*  
16/9/14

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation : A.D.O. (Jwala Puri)



D.O. (CO)

*dy*  
23/9

Res = n23/9