

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/2014/School/WZ/ 1270

Dated: 09/10/2014

FIRE SAFETY CERTIFICATE

Certified that Shri Krishna Public School, Kh. No 72/8, Jaswant Colony, Budh Vihar, Phase-II, Delhi- 110086 comprised of Ground floor only owned/occupied by Shri Krishna Public School, has already been issued fire safety certificate vide letter no. F-6/DFS/MS/2011/106 dated 20/01/2011. The premises was re-inspected by the officer from this department on dated 26/07/2014 in the presence of Sh. Umesh Bhardwaj and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have there fore deemed complied with the requirements of Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 09/10/2014 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The certificate is not valid for regularization of any unauthorized construction.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 09/10/14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250



Copy to:-

1. The Principal, Shri Krishna Public School, Kh. No 72/8, Jaswant Colony, Budh Vihar, Phase-II, Delhi- 110086
2. The Director of Education, Old Secretariat, Delhi

N-1

G-F only

INSPECTION REPORT

1. Name & address of the building: Shri Krishna Public School, K.H.No. 72/8 (Opp
Shri Krishna Mandir) Saswan Colony, Badli, New Delhi
2. Type of Occupancy: Educational
3. Type of Case: Renewal
4. Details of previous NOC: P-6/DPS/MS/2011/106 dt-2011-11
5. Fire Safety directives letter No: Circular of the Director of Fire & Safety
6. Date of inspection: 26-7-14
7. Name of the Inspecting Officers: N.P. Sharma A.D.O.
8. Name and designation of officers from the building side: Sh. U. Bhardwaj
9. Year of Construction: 2006
10. Applicant's letter No: -

Plot area: 1234 Sqd Covered area: 500 Sqd No.'s of students: 275 No's of classrooms: 11

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	-	-	-
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	-	-	-
	• Basements	-	-	-
	b. Width of staircases	-	-	-
	• Upper Floors	-	-	-
	• Basements	-	-	-
	c. Protection of exits	-	-	-
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	old case	old case	old case

N 8

12

3	Compartmentation.	NA		
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4	Smoke Management System.	NA		
	• Basements	30 a/c per hour	—	—
	• Upper floors	12 a/c per hour	—	—
5	Fire Extinguishers			
	• Total numbers	03	04	MR
	• Types	ISI marked	ABC	MR
	• IS marking		yes	MR
6	First-Aid Hose Reels.	NA		
	• Total numbers on each floor	—	—	—
	• Length of hose reel hose	30 m	—	—
	• Nozzle diameter	5 mm	—	—
7	Automatic fire detection and alarming system.	NA		
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hocters' Location	—	—	—
8	MOBEFA	—	—	—
9	Public Address System.	—	—	—
10	Automatic Sprinkler System.	NA		
	• Basement	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11	Internal Hydrants	NA		
	• Size of riser/down-comer	—	—	—
	• Number of hydrants per floor	—	—	—
	• Hose Box	—	—	—

12	Yard Hydrants.	NA		
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—

13	Pumping Arrangements.	NA		
	• Ground Level			
	> Discharge of main Pump			
	> Head of Main pump			
	> Number of main pumps			
	> Jockey Pump out put			
	> Jockey pump head			
	> Standby Pump out put			
	> Standby Pump Head			
	> Auto Starting/ Manual stopping			
	> Pump House Access			
	• Terrace level			
	> Discharge of pump			
	> Head of the pump			
	> Power Supply			
	> Auto Starting of pum			

14	Captive Water Storage for fire fighting.	NA		
	• Underground tank capacity	—	—	—
	> Draw-off connection	—	—	—
	> Fire service inlet	—	—	—
	> Access to tank	—	—	—
	• Overhead Tank capacity	—	—	—

15	Exit Signage.	—	—	—
----	----------------------	---	---	---

16	Provision of Lifts.	NA		
	• Pressurization of Lift Shaft			
	• Pressurization of Lift lobby			
	• Communication In lift Car			
	• Fireman's Grounding Switch			
	• Lift Signage			

17	Standby power supply	—	—	—
----	-----------------------------	---	---	---

N-10

Refuge Area.			
➤ Total Area	NA	—	—
➤ Location	—	—	—
Fire Control Room			
• Detector System Panel	—	—	—
• Flow Switch Panel	—	—	—
• PA System Panel	—	—	—
• Batter backup	—	—	—
• Building Floor Plans	—	—	—
Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and safety measures as required under the rules the NOC issued vide letter no. F-6/DPS/ms/2011/106.....Dated.20.01.2011. Renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer *(Signature)* 26-7-14

Name N.P. Sharma
Designation ADD R

(Signature) *(Signature)*

Signature of the Inspecting Officer

Name
Designation

Recd today on 9/9/14