

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**

NEW DELHI- 110 001


No. *F6/DPS/MS/school/2014/52/1248*

Dated: *07/10/14*

FIRE SAFETY CERTIFICATE

Certified that The Ardee School, located at Maharishi Ramana Marg, Sujan Singh Park, New Delhi-110003, comprises of ground and first floor (first floor pota cabin) owned/occupied by The Ardee School, have complied with the fire prevention and fire safety requirements in accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and verified by the officer concerned of this department on 01.09.14 in the presence of Sh. Manoj Goel Public Relation officer of the school and found that the building is fit for occupancy class B 'Educational Building' with effect from *07/10/14* for a period of three years, subject to conditions printed overleaf.

Issued on *07/10/14* at New Delhi by



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333



To,

The Principal
The Ardee School,
Maharishi Ramana Marg,
Sujan Singh Park, New Delhi-110003

Copy to:-

1. The Director of Education
South Delhi Municipal Corporation,
Dr. SPM Civic Centre, JLN Marg, N.Delhi.

Conditions for the validity of fire safety certificate are overleaf:-

CONDITIONS:


1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

M/1

INSPECTION REPORT

1. Name & address of the building : **The Ardee School** located at Maharishi Ramana Marg, Sujan Singh Park, New Delhi-110003.
2. Building is comprised of : G+1 (first floor is pota cabins).
3. Type of Occupancy : Education
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398 , Dated- 01.03.11.
7. Date of Inspection : 01.09.14.
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of Officer from the building side : Sh. Manoj Goel (Public Relation Officer)
10. Year of Construction : 2003.
11. Applicant's letter No : Letter dated 13.8.14

S.No	Minimum Standards on fire prevention and fire safety as per circular no.3298-3398 Dated01.03.11	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	6 m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	02nos.	02nos.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	1.5 m	90cm& 92cm	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
g. Width of Corridor	1.5 m	1.5 m	MR	
	h. Door Size	1 m	1m	MR
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	12 a/c per hour	N.A.	N.A.



A

M/2

The Ardee School located at Maharishi Ramana Marg, Sujan Singh Park, New Delhi-110003.

5	Fire Extinguisher			
	Total numbers	04 nos.	08 nos.	MR
	types	CO ₂ & ABC	ABC Type	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	N.A.	N.A.	N.A.
	Length of hose reel hose	N.A.	N.A.	N.A.
	Nozzle diameter	N.A.	N.A.	N.A.
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	➤ Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	➤ Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.

M3

The Ardee School located at Maharishi Ramana Marg, Sujan Singh Park, New Delhi-110003.

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.			
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply			
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:			
		N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety systems required under Director of Education circular No.3298-3398 dated 1.03.2013. It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

It is also submitted that there is an Electric Sub Station of NDMC situated in one compartment of the same school building and it is segregated by a nine inch brick wall and also having separate exit/entrance from the school.

D.O. (South)



579/14

Signature of the Inspecting Officer
Name: Vedpal
Designation: ADO