

(11)

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. f6/dfs/ms/school/2014/w2/1331

Dated: 24/10/2014

FIRE SAFETY CERTIFICATE

Certified that M C Primary Boys Model School, Avantika (IInd Shift) Sector-2, Rohini, Delhi- 110085 comprised of Two Blocks – Block One, Ground Floor and Block two, Ground + First Floor owned/occupied by M C Primary Boys Model School have complied with the fire prevention and fire safety requirements in accordance with the Circular issued by Director of Education Letter No 262-362 dated 17/01/2005 issued by Director of Education and verified by the officer concerned of Fire Service on 24/09/2014 in the presence of Sh. J. K. Madan (Principal) and that the building / premises is fit for occupancy of Educational building with effect from 24/10/2014 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 24/10/14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Principal, M C Primary Boys Model School, Avantika (IInd Shift) Sector-2, Rohini, Delhi- 110085
2. The Addl. Director of Education, NMCD, Civic Centre, New Delhi.

W-7

Two Blocks, one - G.F. another G.F + FF

INSPECTION REPORT

1. Name & address of the building : M.C. Bry. Boys Model School, Avantika
 2. Type of Occupancy : Rohini. Sector-2, Delhi 85. Educational
 3. Type of Case : New Case/ Renewal
 4. Details of previous NOC : Letter No. — Dated: —
 5. Fire Safety directives letter No : Circular of the director of Edm
 6. Date of inspection : 24-9-14
 7. Name of the Inspecting Officers : N.P. Sharma
 8. Name and designation of officers from the building side : Sh. J. K. Madan (Principal)
 9. Year of Construction : 2002
 10. Applicant's letter No. : —
- PA - 6288m². CA - 1500m² - Nos - 2 no, NoCR - 21

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu/ NBC	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	P	MR
	• Upper Floors	01	02	MR
	• Basements	—	—	—
	b. Width of staircases	R	P @	MR
	• Upper Floors	1.5mtr	1 - 2.15mtr 2 - 1.20mtr	MR
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	—	—	—
		One metr	1.2 metr x 2	MR

N-8

3	Compartmentation.	NA		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.	NA		
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	—	—
		12 a/c per hour	—	—
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	one @ 30m ² 06	06 ABC ✓	MR ✓ MR ✓
		ISI marked	yes	MR ✓
6	First-Aid Hose Reels.	NA		
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	— 30 m 5 mm	— — —	— — —
7	Automatic fire detection and alarming system.	NA		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8	MOEFA	—	—	—
9	Public Address System.	—	—	—
10	Automatic Sprinkler System.	NA		
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	— — —	— — —	— — —

11	Internal Hydrants	NA		
	<ul style="list-style-type: none"> • Size of riser/down-comer 	—	—	—
	<ul style="list-style-type: none"> • Number of hydrants per floor 	—	—	—
	<ul style="list-style-type: none"> • Hose Box 	—	—	—
12	Yard Hydrants.	NA		
	<ul style="list-style-type: none"> • Total number of hydrants 	—	—	—
	<ul style="list-style-type: none"> • Hose Box 	—	—	—
13	Pumping Arrangements.	NA		
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	/		
14	Captive Water Storage for fire fighting.	NA		
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	/		
15	Exit Signage.	+	—	—

N-10

16	Provision of Lifts.	NA		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply	—	—	—
18	Refuge Area.	NA		
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
19	Fire Control Room	NA		
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer *[Signature]* 24-9-14

Signature of the Inspecting Officer

Name N.P. Sharma

Name

Designation ADO R.

Designation

[Signature]
29/9/14

CFR/1007
15/10/14

