

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/2014 / *School/w2/1335*

Dated: *24 / 10 / 2014*

FIRE SAFETY CERTIFICATE

Certified that North Delhi M C Primary Boys School, Madan pur Dabas, Delhi-110081 comprised of two blocks Ground & Ground+One Upper Floor owned/occupied by North Delhi M C Primary Boys School has already been issued fire safety certificate vide letter no. F-6/DFS/MS/School/2011/2655 dated 21/10/2011. The premises was re-inspected by the officer from this department on dated 22/09/2014 in the presence of Mr. Balram Mathur (Principal) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 24 / 10 / 2014 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 24/10/14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Principal, North Delhi M C Primary Boys School, Madan pur Dabas, Delhi-110081
2. The Addl. Director of Education, NMCD, Civic Centre, New Delhi.

N-9

1st Block Gr. + 1st floor, 2nd Blk. Gr. floor.

INSPECTION REPORT

- 1. Name & address of the building : North Delhi-M.C. Primary Boys School, Madan Pur Dabas, Delhi-81
 - 2. Type of Occupancy : Educational
 - 3. Type of Case : New case/ Renewal
 - 4. Details of previous NOC : F-6/DFS/MS/School/2011/2655 dt. 21.10.11
 - 5. Fire Safety directives letter No : Dir. of Edu. Cir. 01.3.2011
 - 6. Date of inspection : 22.9.14
 - 7. Name of the Inspecting Officers : ADO (BIO)
 - 8. Name and designation of officers from the building side : Mr. Balsam Mathur, Principal
 - 9. Year of Construction : 2011
 - 10. Applicant's letter No. : D/138/M.C.D(Boys)/296 dt. 12.8.14
- Plot area- 5622 m² Covered area- 2098 m² No's of student- 371 No's of class room- 12
 3 room for other purpose -

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessable	Accessable	MR
	• Gate width	- do -	- do -	MR
	• Width of internal road	- do -	- do -	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	2	MR
	• Basements	-	-	-
	b. Width of staircases			
	• Upper Floors	1.50mts	2 x 1.50mts	MR
	• Basements	-	-	-
	c. Protection of exits			
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	1 mtr	1st Blk - 2 x 1 mtr + 2nd Blk - 1 mtr	MR
3	Compartmentation.			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			
	• Basements	30 a/c per hour		
	• Upper floors	12 a/c per hour		

8. Name and designation of officers
from the building side :

Mr. Balsam Mathar, Principal

9. Year of Construction : 2011

10. Applicant's letter No.

: D/138/Me.D(Boys)/2016

dt. 12.8.14

Plot area-

5622 m²

Covered area-

2098 m²

No's of student-

371

No's of class room-

12

3 room for other purpose.

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	-do-	-do-	MR
	• Width of internal road	-do-	-do-	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	2	2	MR
	• Basements	-	-	-
	b. Width of staircases	-	-	-
	• Upper Floors	1.5mts	2 x 1.5mts	MR
	• Basements	-	-	-
	c. Protection of exits			
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	1 mtr	1st blk - 2 x 1 mtr & 2nd blk - 1 mtr	MR
3	Compartmentation.			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			
	• Basements	30 a/c per hour		
	• Upper floors	12 a/c per hour		
5	Fire Extinguishers			
	• Total numbers	8 ABC	8	MR
	• Types	ISI marked	ABC	MR
	• IS marking		yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	One at each floor	-	-

N-10

	<ul style="list-style-type: none"> • Length of hose reel hose • Nozzle diameter 	30 m 5 mm			
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 				
8	MOEFA				
9	Public Address System.				
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 				
11	Internal Hydrants				
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 				
12	Yard Hydrants.				
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 				
13	Pumping Arrangements.				
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 				
14	Captive Water Storage for fire fighting.				
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 				

8	MOEFA				
9	Public Address System.				
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 				
11	Internal Hydrants				
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 				
12	Yard Hydrants.				
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 				
13	Pumping Arrangements.				
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 				
14	Captive Water Storage for fire fighting.				
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 				
15	Exit Signage.				
16	Provision of Lifts.				
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 				

N-11

	<ul style="list-style-type: none"> • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply			N/A
18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/DFP/45/School/2011/2655 dated 21.10.11 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

[Signature]
[Signature]
 25/9/14

Signature of the Inspecting Officer

Name

Designation

[Signature]
 24/9/14
 ADO (B/W)