

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.

E-mail:- cfohq.dfire@nic.in

Fax:- 011-23412593

No. F.6/DFS/MS/EH/2014/52/1372

Dated: 05/11/14

FIRE SAFETY CERTIFICATE

Certified that the **Berco's Restaurant**, R-2, Janak Place, District, Centre, Janak Puri, New Delhi 110058 is running at ground floor of the Janak Place owned/occupied by M/S Berco's Melody House. The Restaurant building was re-inspected by the officers concerned of this department on 10.10.2014 in the presence of Sh. Prabhakar (Manager) and found that the M/S Berco's Melody House have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant building (**at ground floor only**) is fit for occupancy class Group D assembly building w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....05/11/14.....at New Delhi.



(Dr. G. C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph. :- 23414333

ex. Com
05/11/14

Copy to:-

1. The Manager,
Berco's Restaurant (Berco's Melody House),
R-2, ground floor only, Janak Place, District Centre,
Janak Puri, New Delhi 110058.
2. Dy. Health Officer (West Zone)
South Zone Municipal Corporation,
Public Health Department, West Zone,
Vishal Enclave, New Delhi.
(D.1272/DHO/WZ/2014 dt.05.06.14)

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per the building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: Berco's Restaurant, R-2, ground floor only, Janak Place, District Centre, Janak Puri, New Delhi 110058.
2. Type of Occupancy : Group D (Assembly)
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/EH/2011/725 dated 21.04.2011.
5. Fire Safety directives letter No : Nil.
6. Date of inspection : 10.10.2014
7. Name of Inspecting Officer : D.O. S.K. Tomar and A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. Prabhakar (Manager)
9. Year of Construction : 2002
10. Applicant's letter No. : Nil dated 12.09.2014 and D.1272/DHO/WZ/2014 dt.05.06.14

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible — —	12 mtrs 1.5 & 1.5 mtrs. —	M/R M/R —
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	—	—	(Restaurant at Ground Floor only)
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	—	—	(Restaurant at Ground Floor only)
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	—	—	(Restaurant at Ground Floor only)
	d. No. of continuous staircases to terrace	—	—	(Restaurant at Ground Floor only)
	e. Width of Corridor	—	Opening in hall	—
	f. Door Size	—	100 cms	M/R
3.	Compartmentation (Restaurant at Ground Floor only)			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4.	Smoke Management System			
	Basements	—	—	(Restaurant at Ground Floor only)

Berco's Restaurant (A unit of Berco's Melody House) located at R-2 (**Ground Floor only**), Janak Place, District Centre, Janak Puri, New Delhi 110058.

	Upper floors	—	—	(Restaurant at Ground Floor only)
5.	Fire Extinguishers (Restaurant at Ground Floor only)			
	Total numbers	Seven no's / floor	Provided	M/R
	Types	ABC/CO2	Provided	M/R
	IS marking	ISI marked	ISI marked	M/R
6.	First-Aid Hose Reels (Restaurant at Ground Floor only)			
	Total numbers on ground floor	one	Provided	M/R
	Length of hose reel hose	30 mtrs	Provided	M/R
	Nozzle diameter	5 mm	Provided	M/R
7.	Automatic fire detection and alarming system (Restaurant at Ground Floor only)			
	Type of detectors	Smoke & Heat	Provided	M/R
	Location of Main Panel (Common with Janak Place)	—	G. Floor	M/R
	Location of Repeater Panel	—	—	—
	Alternate source of power	—	Provided	M/R
	Hooters' Location	Required	Near exits	M/R
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	Required	Provided	M/R
10.	Automatic Sprinkler System			
	Basement	—	—	(Restaurant at Ground Floor only)
	Ground Floor	Required	Provided	M/R
	Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants (Restaurant at Ground Floor only)			
	Size of riser/down-comer	100mm	Provided	M/R
	Number of hydrants	One	Provided	M/R
	Hose Box	One	Provided	M/R
12.	Yard Hydrants			
	Total number of hydrants	—	one	M/R
	Hose Box	—	one	M/R
13.	Pumping Arrangements (common with Janak Place)			
	Ground Level			
	Discharge of main Pump	2850 LPM	Provided	M/R
	Head of Main pump	70 mtrs	Provided	M/R
	Number of main pumps	01	Provided	M/R
	Jockey Pump out put	220 LPM	Provided	M/R
	Jockey pump head	70 mtrs	Provided	M/R
	Standby Pump out put	2850 LPM	Provided	M/R
	Standby Pump Head	70 mtrs	Provided	M/R
	Auto Starting/Manual Stopping	Required	Provided	M/R
	Pump House Access	Required	Provided	M/R

N/10

Berco's Restaurant (A unit of Berco's Melody House) located at R-2 (Ground Floor only), Janak Place, District Centre, Janak Puri, New Delhi 110058.

	Terrace level			
	Discharge of pump	N/A	N/A	N/A
	Head of the pump	N/A	N/A	N/A
	Power Supply	N/A	N/A	N/A
	Auto Starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for fire fighting (common with Janak Place)			
	Underground tank capacity	22500 Ltrs <i>Same</i>	Provided	M/R
	Draw-off connection	Required	Provided	M/R
	Fire service inlet	Required	Provided	M/R
	Access to tank	Required	Provided	M/R
	Overhead Tank capacity	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts.	(Restaurant at Ground Floor only)		
	Pressurization of Lift Shaft	N/A	N/A	N/A
	Pressurization of Lift lobby	N/A	N/A	N/A
	Communication In lift Car	N/A	N/A	N/A
	Fireman's Grounding Switch	N/A	N/A	N/A
	Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	M/R
18.	Refuge Area.			
	Total Area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19.	Fire Control Room			
	Detector System Panel	N/A	N/A	N/A
	Flow Switch Panel	N/A	N/A	N/A
	PA System Panel	N/A	N/A	N/A
	Battery backup	N/A	N/A	N/A
	Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

N/11

Berco's Restaurant (A unit of Berco's Melody House) located at R-2 (**Ground Floor only**), Janak Place, District Centre, Janak Puri, New Delhi 110058.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F6/DFS/MS/EH/2011/725 dated 21.04.2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note :-Restaurant is having common fire fighting system with the Janak Place Building and restaurant manager has submitted the undertaking letter given by the Executive Engineer (E), Electrical Division -12 to them regarding the efficient working of fire fighting system placed at C -24.


S.K. Tomar
20/10/14

Signature of Inspecting Officer

Name:- S.K. Tomar

Designation:- Divisional Officer


Sandeep
29/10/14

Signature of Inspecting Officer

Name:- Sandeep Duggal

Designation:- Asstt. Divisional Officer

FIRE