

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

Fax: 23412593, E-mail: cfohq.dlfire@nic.in, Tel:- 011-23414333

NO.F6/DFS/MS/2014/ *Enroll/52/1376*

Dated:

07/11/14

FIRE SAFETY CERTIFICATE

Certified that **M/s Dolphin International Pvt Ltd, located at Plot No. B-210, Okhla Industrial Area, Phase-I, New Delhi-110020** comprised of basement, stilt, ground plus two upper floors was inspected by the officer concerned of this department on 29-09-2014 in presence of Mr. Lalit (Accounts Officer) and found that the said building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class Industrial with effect from *07/11/14* for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on *07/11/14* at New Delhi by.



(Dr. G.C. MISRA)
CHIEF FIRE OFFICER

Copy to: -

1. The Authorized Signatory, M/s Dolphin International Pvt. Ltd, Plot No. B-210, Okhla Industrial Area, Phase-I, New Delhi-110020.

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: M/s. Dolphin International Pvt. Ltd, Plot No. B-210, Okhla Industrial Area, Phase-I, New Delhi-110020.
2. Type of Occupancy : Industrial
3. Type of Case : New Case
4. Details of previous NOC : N/A
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2014/100 dated 09-04-2014.
6. Date of inspection : 29.09.2014
7. Name of the Inspecting Officers : M.K Chattopadhyay, ADO (M. Road)
8. Name and designation of officers from the building side : Mr. Lalit (Accounts Officer)
9. Year of Construction : 2011-12
10. Applicant's letter No. : nil dated 08- 09-2014

Building is comprised of basement, stilt, ground plus two upper floors

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	02	provided	MR
	• Basements	02	Provided	MR
	b. Width of staircases	-	-	-
	• Upper Floors	1.5 mts each	Provided	MR
	• Basements	1.5 mts each	Provided	MR
	c. Protection of exits	-	-	-
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	02	02	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.5 mts	Provided	MR
3	Compartmentation.			

178

	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required	Provided	MR
		Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	Provided	MR
		12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	15	Provided	MR
		ABC type	Provided	MR
		ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Required	Provided(Smoke)	MR
		Ground floor	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	100 mm	Provided	MR
		01	Provided	MR
		01	Provided	MR



12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	Required(02)	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	Required(02)	Provided	MR
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	----	----	----
		2280 LPM	Provided	MR
		60 mts	Provided	MR
		01	Provided	MR
		180 LPM	Provided	MR
		60 mts	Provided	MR
		2280 LPM	Provided	MR
		60 mts	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		-	-	-
		900 LPM	Provided	MR
		60 mts	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	75,000 lts	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20, 000 lts	Provided 20,000 lts	MR
15	Exit Signage.			
		Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch 	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR
		Required	Provided	MR

26/10


	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	Required	Provided	MR
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any	Required	Provided (02 ABC type fire extinguishers near electric panel)	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

The management has rectified all the shortcomings issued by this department vide letter No. F6/DFS/MS/2014/1868 dated 22.08.2014.

In view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to grant fire safety certificate under rule 35 of the Delhi Fire Service rules 2010.

DFA is put up for approval & signature please.



Signature of the Inspecting Officer
 Name M.K.CHATROPADHYAY
 Designation: - Asstt. Div. Officer (M.Rd)

Pl special