

B I D

1002/371

FORM 'H'

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001


No. F-6/DOS/ms/School/2011/2639

Dated : 21/10/11

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls Sr. Sec School at School Block Shakar Pur, Delhi-92. Comprised of ground plus one upper floor owned/occupied by Govt. Girls Sr. Sec School have complied with the fire prevention and fire safety requirements in accordance with with the circular issued by the Director of Education dtd.01.03.2011 and verified by the officer concerned of Fire Service on 23.09.2011 in the presence of Smt. Amardayal Kaur, Principal, of the school and that the building is fit for occupancy class B' Educational Building' with effect from 21/10/11..... for a period of three years ,subject to conditions printed overleaf.

Issued on 21/10/11 at New Delhi by



Chief Fire Officer
Delhi Fire Service

To,
Principal
Govt. Girls Sr. Sec School
School Block Shakar Pur, Delhi-92

- Copy:-
1. The Joint Director of Education
(Land & Estate)
Directorate of Education,
Lucknow Road, Delhi -54.
 2. Principal
Govt. Boys Sr. Sec School
School Block Shakar Pur, Delhi-92

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

N/2

File collected from EPW to inspect school premises.
During inspection, it was appraised by Principal that
School bldg. have already been issued ESC, copy of the
same placed on file.

Hence file can be attached with original file
in EPW. submitted for info. P. hardmal

DO(E)

DO (E) 22/10
King
27/10/14


ASO (LN)



- N/1 -


May kindly peruse the letter dated 11/09/12 received from the VICE PRINCIPAL of Rajkiya Sarvodaya Bal Vidyalaya located at School Block Shakar Pur Delhi - 92 regarding issuance of NOC from fire safety point of view for running the said school in the said premises. In this connection it is submitted that the school building was visited by A.D.O. (LN), on 18/2/10 with a view to see the fire safety arrangements in the school building. The VICE PRINCIPAL was also available there. During the course of visit it was noticed that the building is comprising of Ground +1. The management has not provided fire safety arrangements in the school building as per requirement.

In view of the above, the school building can not be considered safe from fire safety point of view at this stage in the interest of public safety for running the school in the said building. FT letter on the similar lines has been prepared i.e. asking the applicant to provide the fire safety arrangements as per circular No. 262-362 dated 17.1.05 issued by the Director Education for school buildings and placed on opposite side of the file for approval and signature please.


A.D.O. (LN)

~~DO (LN)~~ ~~BD~~

~~DC/ET~~


24/2

MS ceo