

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DF5/MS/2014/W2/1371

Dated 05/11/14

FIRE SAFETY CERTIFICATE

Certified that a Restaurant on ground floor and basement for storage in the name of Haldiram at A-17 Industrial Area, Najafgarh Road, Moti Nagar, New Delhi 110015 of a premises comprised of basement + ground floor + 2 upper floor only owned / occupied by Gagandeep Mahindru have complied with the fire prevention and fire safety requirement in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 22.09.2014 in the presence of Sh. Awasthi (G.M.) and that the building/premises is fit for occupancy Assembly excluding first and second floor with effect from 05/11/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire service rule, 2010.

Issued on05/11/14.....at New Delhi by


(Santokh Singh)
Chief Fire Officer
Tel. No. 23414250
cfowz.dlfire@nic.in

Copy to:

1. Gagandeep Mahindru
B-2, Kirti Nagar, New Delhi

dc h

Following fire safety directives must be adhered to:-

- 1) All the means of escape shall be kept free of all type of obstruction all the time.
- 2) All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3) All the fire fighting equipment shall be maintained in perfect working condition all the time and lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4) Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
- 5) Basement shall be used as per NBC.
- 6) This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
- 8) "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

Basement – Storage,

G.F.- Restaurant

Second Floor = Office purpose *Not yet ready for inspection*

1. Name & address of the building : A-17 Industrial Area, Najafgarh Road, Moti Nagar, New Delhi-15
2. Type of Occupancy : Assembly – Restaurant at GF and basement for storage in the name of Haldiram's of Sons
3. Type of Case : New ✓
4. Details of previous NOC : Nil
5. Fire Safety directives letter No. : F6/DFS/MS/BP/2014/ 1702 dated 25.07.14 ✓
6. Date of inspection : 22.09.2014
7. Name of the Inspecting Officers : D.O. (WZ) Sunil Chawdhary
8. Name and designation of officers
From the building side : Sh. Awasthi (G.M.)
9. Year of Construction : 2010
10. Applicant's letter No. : nil dated 27. 08. 2014

NOC for ground floor only (Assembly)**INSPECTION REPORT**

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	09mtrs	60 mtr	M.R.
	• Gate width	4.5 mtr	Provided	M.R.
	• Width of internal road	As per section plan	Provided	M.R.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	2	M.R.
	• Basement	2	2	M.R.
	b. Width of staircases			
	• Upper Floors	N.R.	N.R.	N.R.
	• Basement	N.R.	N.R.	N.R.
	c. Protection of exits			
	• Fire check door	required	Provided	M.R.
	• Pressurization	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	1.5 mtr.	Halls only	M.R.
	f. Door size	2x2 mtr for Restaurant	Provided	M.R.
3.	Compartmentation.			
	• Fire check door	Required	Provided	M.R.
	• Sealing of electrical shafts	Required	Provided	M.R.
	• Fire Rating of shaft door	Required	Provided	M.R.

	• Fire Dampers	N.R.	N.R.	N.R.
4.	Smoke Management System.			
	• Basements	Required	Provided	M.R.
	• Upper floors	Required	Provided	M.R.
5.	Fire Extinguishers			
	• Total numbers	10 for Basement + ground floor only	12	M.R.
	• Types	ABC & CO ₂ type	Provided	M.R.
	• IS marking	ISI marks required	Provide	M.R.
6.	First-Aid Hose Rees.			
	• Total numbers on each floor	02	02	M.R.
	• Length of hose reel hose	30 m required	Provided	M.R.
	• Nozzle diameter	5 mm required	Provided	M.R.
7.	Automatic fire detection and alarming system.			
	• Type of detectors	Required	Provided	M.R.
	• Location of Main Panel	G.Floor	Provided	M.R.
	• Location of Repeater Panel	N.R.	N.R.	N.R.
	• Alternate source of power	Required	Provided	M.R.
	• Hooter's Location	Required	Provided	M.R.
8.	MOEFA	Required	Provided	M.R.
9.	Public Address System.	Required	Provided	M.R.
10.	Automatic Sprinkler system			
	• Basement	Required	Provided	M.R.
	• Upper Floor	N.R.	N.R.	N.R.
	• Sprinkler above false ceiling	Required if basement have ceiling	No ceiling in basement	M.R.
11.	Internal Hydrants			
	• Size of riser/down-comer	150 m.m.	Provided	M.R.
	• Number of hydrants per floor	2	2	M.R.
	• Hose Box	2	2	M.R.
12.	Yard Hydrants.			
	• Total number of hydrants	04	Provided	M.R.
	• Hose Box	04	Provided	M.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	2280 LPM	Provided	M.R.
	➤ Head of Main pump	50 mtr	Provided	M.R.

	➤ Number of main pumps	02	02	M.R.
	➤ Jockey Pump out put	180 LPM	Provided	M.R.
	➤ Jockey pump head	50 mtr	Provided	M.R.
	➤ Standby pump out put	2280 LPM	Provided	M.R.
	➤ Standby pump Head	50 mtr	Provided	M.R.
	➤ Auto Starting/Manual stopping	required	Provided	M.R.
	➤ Pump Hose Access	Required	Provided	M.R.
	Terrace level			
	➤ Discharge of pump	900 LPM	Provided	M.R.
	➤ Head of the pump	50 mtr	Provided	M.R.
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	required	Provided	M.R.
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	50,000 ltrs	Provided	M.R.
	➤ Draw -off connection	Required	Provided	M.R.
	➤ Fire service inlet	Required	Provided	M.R.
	➤ Access to tank	Required	Provided	M.R.
	➤ Overhead Tank Capacity	10,000 ltrs	Provided	M.R.
15	Exit Signage.	Required	Provided	M.R.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.R.	N.R.	N.R.
	• Pressurization of Lift lobby	N.R.	N.R.	N.R.
	• Communication In lift Car	N.R.	N.R.	N.R.
	• Fireman's Grounding Switch	N.R.	N.R.	N.R.
	• Lift Signage	N.R.	N.R.	N.R.
17.	Standby power supply	Required	Provided	M.R.
18.	Refuge Area			
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R.
19.	Fire Control Room			
	➤ Detector System Panel	Required	Provided	M.R.
	➤ Flow Switch Panel	Required	Provided	M.R.
	➤ PA system Panel	Required	Provided	M.R.
	➤ Batter backup	Required	Provided	M.R.
	➤ Building Floor plans	Required	Provided	M.R.

N/R

20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	N.R.
-----	---	------	------	------

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/.



Signature of the Inspection Officer

Name Sunil Chawdhary

Designation D.O. (M.N.)



Signature of the Inspection Officer

Name

Designation

D-4470 -