

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2014/W2/1357

Dated: 31/10/2014


FIRE SAFETY CERTIFICATE

Certified that the **Mohan Leela Eating House/restaurant** located at 1st floor of A-8/3, Wazirpur Ind. Area, Delhi in a building comprised of basement + G + 2 upper floors, owned/occupied by **Mohan Leela** was earlier issued FSC by this dept. vide letter No. F.6/DFS/MS/EH/2011/1127 dated 08/06/2011. The premises was re-inspected by the officer concerned of this department on **17/09/2014** in the presence of **Mr. Sameer Mittal** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the requirement under Rule 33 of the Delhi Fire Service Rule 2010 and thus the building/premises is fit for occupancy class **Assembly** with effect from.....31/10/14.....for a period of three year in accordance with rule 36 unless renewed under 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under 38 of the Delhi Fire Service Rule 2010.

Following fire safety directives must be adhered to:-

- 1) All the means of escape shall be kept free of all type of obstruction all the time.
- 2) All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3) All the fire fighting equipment shall be maintained in perfect working condition all the time and lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4) Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
- 5) Basement shall be used as per NBC.
- 6) This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
- 8) "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

Issued on.....31/10/14.....at New Delhi by


(Santokh Singh)
Chief Fire Officer
Delhi Fire Service

E-mail : cfowz.dlfire@nic.in

31/10
dh

Copy to: Mr. Sameer Mittal,
Mohan Leela Eating House/restaurant
A-8/3, Wazirpur Ind. Area, Delhi

- Renewal-
1. Name & address of the building : Mohan Leela Eating House/restaurant at First floor, A-8/3, Wazirpur Ind. Area, Delhi (basement+G+ 2 upper floors)
 2. Type of Occupancy : Class D (Assembly)
 3. Type of Case : New Renewal
 4. Details of previous NOC : F.6/DFS/MS/EH/2011/1127 dated 08/06/2011
 5. Fire Safety directives letter No. : Nil
 6. Date of inspection : 17-09-2014
 7. Name of the Inspecting Officers : ADO (W.P) & DO (M.N.)
 8. Name and designation of officers
- From the building side : Mr. Sameer Mittal
9. Year of Construction : 1990
 10. Applicant's letter No. : Nil dated Nil

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06mtrs	Provided	M/R
	• Gate width	required	Provided	M/R
	• Width of internal road	N.A.	N.A.	N.A.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Two	Provided	M/R
	• Basement	Two	Provided	M/R
	b. Width of staircases			
	• Upper Floors	Old case	Old case	Old case
	• Basement	Old case	Old case	Old case
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R.
	• Pressurization	N.A.	N.A.	N.A.
	d. No. of continuous staircases to terrace	one	Provided	M/R
	e. Width of Corridor	required	Open hall	M.R
	f. Door size	Old case	Old case	M.R.
3.	Compartmentation.			
	• Fire check door	N.A.	N.A.	N.A.
	• Sealing of electrical shafts	N.A.	N.A.	N.A.
	• Fire Rating of shaft door	N.A.	N.A.	N.A.
	• Water Curtain	N.A.	N.A.	N.A.
	• Fire Dampers	N.A.	N.A.	N.A.
4.	Smoke Management System.			
	• Basements	30 a/c per hour	Exhaust fans	M.R
	• Upper floors	12 a/c per hour	Provided	M.R.
5.	Fire Extinguishers			
	• Total numbers	17	Provided	M.R
	• Types	ABC -5 kg & CO ₂ 4.5 kg	Provided	M R
	• IS marking			

- From the building side : Mr. Sameer Mittal
 9. Year of Construction : 1990
 10. Applicant's letter No. : Nil dated Nil

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06mtrs	Provided	M/R
	• Gate width	required	Provided	M/R
	• Width of internal road	N.A.	N.A.	N.A.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Two	Provided	M/R
	• Basement	Two	Provided	M/R
	b. Width of staircases			
	• Upper Floors	Old case	Old case	Old case
	• Basement	Old case	Old case	Old case
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R.
	• Pressurization	N.A.	N.A.	N.A
	d. No. of continuous staircases to terrace	one	Provided	M/R
	e. Width of Corridor	required	Open hall	M.R
	f. Door size	Old case	Old case	M.R.
3.	Compartmentation.			
	• Fire check door	N.A.	N.A.	N.A.
	• Sealing of electrical shafts	N.A.	N.A.	N.A.
	• Fire Rating of shaft door	N.A.	N.A.	N.A.
	• Water Curtain	N.A.	N.A.	N.A.
	• Fire Dampers	N.A.	N.A.	N.A.
4.	Smoke Management System.			
	• Basements	30 a/c per hour	Exhaust fans Provided	M.R
	• Upper floors	12 a/c per hour	Provided	M.R.
5.	Fire Extinguishers			
	• Total numbers	17	Provided	M.R
	• Types	ABC -5 kg & CO ₂ 4.5 kg	Provided	M.R
	• IS marking	ISI marked	Provided	M.R
6.	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	M.R
	• Length of hose reel hose	30 m required	Provided	M.R

	• Nozzle diameter	5 mm	Provided	M.R
7.	Automatic fire detection and alarming system.			
	• Type of detectors	N.R.	N.R.	N.R.
	• Location of Main Panel	N.R.	N.R.	N.R.
	• Location of Repeater Panel	N.R.	N.R.	N.R.
	• Alternate source of power	N.R.	N.R.	N.R.
	• Hooter's Location	N.R.	N.R.	N.R.
8.	MOEFA	Required	Provided	M.R
9.	Public Address System	Required	Provided	M.R
10.	Automatic Sprinkler system	Required	Provided	M.R
	• Basement	Required	Provided	M.R
	• Upper Floor	Required	Provided	M.R
	• Sprinkler above false ceiling	N.R.	N.R.	N.R.
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	provided	M.R
	• Number of hydrants per floor	two	provided	M.R.
	• Hose Box	two	provided	M.R
12.	Yard Hydrants.			
	• Total number of hydrants	N.R.	N.R.	N.R.
	• Hose Box	N.R.	N.R.	N.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N.A.	N.A.	N.A.
	➤ Head of Main pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey Pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting/Manual stopping	N.A.	N.A.	N.A.
	➤ Pump Hose Access	N.A.	N.A.	N.A.
	Terrace level			
	➤ Discharge of pump	450 LPM & 225 LPM	Provided	M.R.
	➤ Head of the pump	40 mtr	Provided	M.R.
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	Required	Provided	M.R

	• Hooter's Location			
8.	MOEFA	Required	Provided	M.R
9.	Public Address System	Required	Provided	M.R
10.	Automatic Sprinkler system	Required	Provided	M.R
	• Basement	Required	Provided	M.R
	• Upper Floor	Required	Provided	M.R
	• Sprinkler above false ceiling	N.R.	N.R.	N.R.
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	provided	M.R
	• Number of hydrants per floor	two	provided	M.R.
	• Hose Box	two	provided	M.R
12.	Yard Hydrants.			
	• Total number of hydrants	N.R.	N.R.	N.R.
	• Hose Box	N.R.	N.R.	N.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N.A.	N.A.	N.A.
	➤ Head of Main pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey Pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting/Manual stopping	N.A.	N.A.	N.A.
	➤ Pump Hose Access	N.A.	N.A.	N.A.
	Terrace level			
	➤ Discharge of pump	450 LPM & 225 LPM	Provided	M.R.
	➤ Head of the pump	40 mtr	Provided	M.R.
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	Required	Provided	M.R
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	➤ Draw -off connection	N.A.	N.A.	N.A.
	➤ Fire service inlet	N.A.	N.A.	N.A.
	➤ Access to tank	N.A.	N.A.	N.A.
	➤ Overhead Tank Capacity	5,000 ltrs	Provided	M.R

15	Exit Signage.	required	Provided	M.R.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.R.	N.R.	N.R.
	• Pressurization of Lift lobby	N.R.	N.R.	N.R.
	• Communication In lift Car	N.R.	N.R.	N.R.
	• Fireman's Grounding Switch	N.R.	N.R.	N.R.
	• Lift Signage	N.R.	N.R.	N.R.
17.	Standby power supply	Required	Provided	M.R
18.	Refuge Area			
	➤ Total Area	N.A	N.A	N.A
	➤ Location	N.A	N.A	N.A
19.	Fire Control Room			
	➤ Detector System Panel	N.R.	N.R.	N.R.
	➤ Flow Switch Panel	N.R.	N.R.	N.R.
	➤ PA system Panel	N.R.	N.R.	N.R.
	➤ Batter backup	N.R.	N.R.	N.R.
	➤ Building Floor plans	N.R.	N.R.	N.R.
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	N.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC vide letter No. F.6/DFS/MS/EH/2011/1127 dated 08/06/2011 renewal under rule 35 of the Delhi Fire Service rule 2010 is recommended.

Signature of the Inspection Officer

Name Uday Vir Singh

Designation ADO (W.P.)

Signature of the Inspection Officer

Name Sunil Chawdhary

Designation DO (W)