

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/school/2014/52/1353

Dated: 30/10/14

FIRE SAFETY CERTIFICATE

Certified that the N.P.Co-Ed. Secondary School, Lodhi Estate, New Delhi-110003. comprised of ground plus two floors, owned/occupied by New Delhi Municipal Council was granted NOC by this department vide letter No. F6/DFS/MS/2011/1070, dated 02-06-2011. The premises was re-inspected by the officer concerned of this department on 11-09-2014 in the presence of Sh. Sajjan Kumar (Fire Officer) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 and that the premises is fit for occupancy class "B" educational building with effect from...2014 for period of three years.

Issued...2014 at New Delhi by.

30/10/14


30/10
(Santokh Singh)

Chief Fire Officer
T.No.011-23414250

To,
The Principal
N.P.Co-Ed. Secondary School, Lodhi Estate,
New Delhi-110003.



Copy to:-

The Director of Education
South Delhi Municipal Corporation
Dr. SPM Civic Centre, JLN Marg, N.D

Conditions for the validity of fire safety certificate are overleaf:-

INSPECTION REPORT


1. Name & address of the building : N.P.Co-Ed. Secondary School, Lodhi Estate, New Delhi-110003.
2. Building is comprised of : G+2
3. Type of Occupancy : Education
4. Type of Case : Renewal
5. Details of Previous NOC : No.F6/DFS/MS/2011/1070, Dated 02.06.2011.
6. Fire Safety direction letter No : Circular No.262-362, dated 17.01.2005.
7. Date of Inspection : 11.09.14.
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of Officer from the building side : Sh. Sajjan Kumar(Fire Officer)
10. Year of Construction : 1990
11. Applicant's letter No : Form "J", dated 22.09.14

S.No	Minimum Standards on fire prevention and fire safety as per circular no.262-362, Dated 17.01.2005	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	6 m	
	Gate width	N.A.	N.A.	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	Upper Floor	02nos.	02staircases upto terrace+01 Staircase upto 1 st floor.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	1.5 m	1.5m, 1.65m & 1.50m	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
	g. Width of Corridor	01no.	02nos.	MR
	h. Door Size	1.5 m	1.5 m	MR
3	Compartmentation			
	Fire check door	1 m	1m	MR
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	12 a/c per hour	N.A.	N.A.

5.	Fire Extinguisher			
	Total numbers	06 nos.	06nos.	MR
	types	CO ₂ & ABC	DCP Type	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	01no.	01no.	MR
	Length of hose reel hose	30m	30m	MR
	Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	Required	Provided	MR
9	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100mm	100mm	MR
	Number of hydrants per floor	01no.	01no.	MR
	Hose Box	01no.	01no	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	➤ Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	➤ Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	Required	Provided	MR
		450LPM	450LPM+180 LPM Jockey	MR
	➤ Head of the Pump	40m	40m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
15	Overhead Tank capacity	N.A.	N.A.	N.A.
	Exit Signage.	5000Liters	5000Liters.	MR
16	Provision of Lifts.	N.A.	N.A.	N.A.
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.	N.A.	N.A.	N.A.
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room	N.A.	N.A.	N.A.
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the NOC issued vide letter No: F6/DFS/MS/2011/1070, dated 02.06.2011, renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.



[Handwritten signature]
14/10/14

[Handwritten signature] 13/10/14
Signature of the Inspecting Officer
Name: Vedpal
Designation: ADO