

INSPECTION REPORT

1. Name & address of the building : Carvan Cosmetiss, O-9 Sec-5
2. Type of Occupancy : Industrial (G-2) DSIDC Bawana
3. Type of Case : New Case/ Renewal Delhi-39
4. Details of previous NOC : Letter No. _____ FSC for G₂ + one floor
Dated: _____
5. Fire Safety directives letter No : NBC Part IV
6. Date of inspection : ~~1.9.14~~ 3.9.14
7. Name of the Inspecting Officers : AD0 (RW)
8. Name and designation of officers
from the building side : Sh. Ravi Chopra - Prop.
9. Year of Construction : 2008-09
10. Applicant's letter No. : lt No. Mii dt. 30.7.14

PA - 200 m²

CA - 480 m²

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<p>Accessible</p> <p>—</p> <p>—</p>	<p>Accessible</p> <p>—</p> <p>—</p>	<p>MR</p> <p>—</p> <p>—</p>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>FSC for G₂ + one floor only</u>		
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p>02</p> <p>02</p>	<p>02</p> <p>02</p>	<p>MR</p> <p>MR</p>
	b. Width of staircases	—	—	—
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<p>1.25 m^{ts}</p> <p>1.25 m^{ts}</p>	<p>2 x 1.25 m^{ts}</p> <p>2 x 1.25 m^{ts}</p>	<p>MR ✓</p> <p>MR</p>
	c. Protection of exits	—	—	—
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	2 x 1 m ^{ts}	P	MR

Requirement as Bldg. Plan attached

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No.

F-1/DFS/MS/2014/W2/1326

Dated

28/10/14

FIRE SAFETY CERTIFICATE

Certified that **Caravan Cosmetics, 0-9, Sector-5, DSIDC, Bawana, Delhi-110039** located on ground floor and first floor of a premises comprised of Basement Ground + One upper floor owned / occupied by **Caravan Cosmetics** have complied with the fire prevention and fire safety requirement in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **14.08.2014** in the presence of **Sh. Ravi Chopra (Prop.)** and that the building/premises is fit for occupancy Industrial G- (1) building with effect from 28 / 10 / 2014 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire service rule, 2010.

Conditions for the validity of Fire Safety Certificate:

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the restaurant are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This report may not in any way be treated as regularization of unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this fire Safety Certificate of the Director of Form "J" [sub rule (1)of rule 37] along with a copy of this Certificate ,six months prior to its expiry
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 28/10/14 at New Delhi by


Santokh Singh
Chief Fire Officer
Delhi Fire Service

E-mail : cfowz.dfire@nic.in

Copy to :-

1. M/S Caravan Cosmetics, 0-9, Sector-5, DSIDC, Bawana, Delhi 110039
2. The Assistant Drugs Controller & Licensing Authority , Govt .of NCT of Delhi , F-17, Karkardooma, New Delhi-110032.

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
N/A				
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		
N/A				
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	7 ABC ISI marked	7 ABC 7-10	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	R 30 m 5 mm	P P P	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
N/A				
8	MOEFA			
9	Public Address System.			
N/A				
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	R R —	P P —	MR MR —
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 			
N/A				

12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	N/A		
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A		
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A		
15	Exit Signage.	R	P	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A		
17	Standby power supply			

18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....N/A.....

Signature of the Inspecting Officer

Name

Designation

SO (W)

Signature of the Inspecting Officer

Name

Designation

19.9.14

ASO (W)