

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110 001

No. F6/dfs/ms/school/2014/52/1351

Dated: 30/10/14

FIRE SAFETY CERTIFICATE

Certified that Ganesh Shankar Vidhyarthi Govt. Sarvodaya Bal Vidyalaya No.1, Sarojani Nagar, New Delhi-23, comprises of ground and first floor owned/occupied by Directorate of Education, have complied with the fire prevention and fire safety requirements in accordance with the circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and verified by the officer concerned of this department on 13.10.14 in the presence of Sh. K.P.Singh, Principal of the school and found that the building is fit for occupancy class B 'Educational Building' with effect from 30/10/14 for a period of three years, subject to conditions printed overleaf.

Issued on 30/10/14 at New Delhi by


(Santokh Singh)

Chief Fire Officer

T.No.01123414250

97c


To,

The Principal

Ganesh Shankar Vidhyarthi Govt. Sarvodaya Bal

Vidyalaya No.1, Sarojani Nagar, New Delhi-23.

Copy to:-

The Director of Education

Old Secretariat, Civil Lines,

Delhi-52.

Conditions for the validity of fire safety certificate are overleaf:-

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Ganesh Shankar Vidhyarthi Govt. Sarvodaya Bal Vidyalaya No.1, Sarojani Nagar, New Delhi-23.
2. Building is comprised of : G+1(Two Blocks).
3. Type of Occupancy : Education
4. Type of Case : New.
5. Details of Previous NOC : Nil.
6. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398
Dated- 01.03.11
7. Date of Inspection : 13.10.14
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of Officer from the building side : Sh. K.P.Singh (Principal)
10. Year of Construction : 1953 and 2014.
11. Applicant's letter No : Nil, dated 13.10.14.


S.N	Minimum Standards on fire prevention and fire safety as per circular no.3298-3398 Dated01.03.11.	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			MR
	Road width	6 m	9 m	N.A.
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases	.		
	Upper Floor	2nos.in each block	02nos.in each block	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	1.5 m(each)	1.5m(each)in one block 2m& 1.2m in 2 nd block	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits	N.A.	N.A.	N.A.
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	1no.in each block	1no.in each block	MR
	g. Width of Corridor	1.5 m	1.5 m	MR
	h. Door Size	1 m	1m	MR
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	12 a/c per hour	N.A.	N.A.

Ganesh Shankar Vidhyarthi Govt. Sarvodaya Bal Vidyalaya No.1, Sarojani Nagar, New Delhi

5.	Fire Extinguisher			
	Total numbers	14 nos.	26 nos.	MR
	types	CO ₂ & ABC	CO ₂ and ABC Type	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	N.A.	N.A.	N.A.
	Length of hose reel hose	N.A.	N.A.	N.A.
	Nozzle diameter	N.A.	N.A.	N.A.
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	stage of auditorium	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor in each block	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	➤ Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	➤ Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety systems required under Director of Education circular No.3298-3398 dated 1.03.2013. It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.


 Signature of the Inspecting Officer

Name: Vedpal

Designation: ADO

D.O. (South)

