

No.F.6/DFS/MS/2014/school/2014/w2/1370

Dated: 05/11/2014

FIRE SAFETY CERTIFICATE

Certified that the **Jeevan Public School at Pratap Vihar, Part-II, Kirari Extension, New Delhi-110086** comprised of **Ground + Two Upper Floors** only owned / occupied by **Jeevan Public School** was issued Fire Safety Certificate by this department vide letter No. **F6/DFS/MS/2863 dated 01/10/2010**. A new block comprising Ground + Two Upper Floors was also found constructed now. The Fire Safety Requirements in accordance with Director of Education circular no. 262-362 dated 17/01/2005 for old block and Delhi Fire Service act 2007 & rules 2010 for new block, have found provided and verified by the officer concerned of Fire Service on 27/08/2014 in presence of Sh. Jagbir Singh (Manager) and both the blocks in the premises are fit for occupancy class **Educational** (Group-B) with effect from 05/11/2014 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
3. The trained fire- fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 05/11/14 **at New Delhi by.**


(SANTOKH SINGH)
CHEF FIRE OFFICER.
Phone:-23414250

Copy to :-

1. The Principal, Jeevan Public School, Partap Vihar, Part-II, Kirari Extn., Delhi-110086.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.

INSPECTION REPORT

1. Name & address of the building: **Jeevan Public School, at Partap Vihar, Part-II, Kirari Extn., Delhi-110086.**
2. Type of Occupancy : **Educational** (As one more G+2 block is added separately in the same campus in which existing G+2 building is situated)
3. Type of Case : **New**
4. Details of previous NOC : **F6/DFS/MS/2863 dated 01/10/2010**
(for existing G+2 building)
5. Fire Safety directives Letter No. : **NBC Part-IV (For New G+2 Block)**
6. Date of inspection : **27/8/2014**
7. Name of the Inspecting Officer : **A. K. Jaiswal**
8. Name and designation of Officer
from the building side : **Sh. Jagbir Singh**
9. Year of Construction : **1998 (Old G+2 Building), 2013 (New G+2 Building).**
10. Applicant's letter No. : **JPS/07/14/1937 Dated 21/07/2014**

| S No | Minimum standards on fire prevention and fire safety U/R 33 | NBC/ Part-IV Requirements | Provided at site | Remarks MR/NMR |
|------|---|------------------------------------|--|---------------------------|
| 1. | Access of building | | | |
| | • Road width | Accessible | Provided | MR |
| | • Gate width | Accessible | Provided | MR |
| | • Width of internal road | N/A | N/A | N/A |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 2 | 2 | MR |
| | • Basements | No basement | N/A | N/A |
| | b. Width of staircases | | | |
| | • Upper floors | I) 1.50mtr. II) Old Case | 1.83X2 (New Bldg) Old Case (Old Bldg) | MR Old Case |
| | • Basements | N/A | N/A | N/A |
| | c. Protection of exits | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Pressurization | N/A | N/A | N/A |
| | d. No of continuous staircase to terrace | I) 1 II) Old Case | 1 (New Bldg) Old Case | MR Old Case (Old Bldg) |
| | e. Width Of Corridor | I) 1Mtr.(New Bldg) II) Old Case | Provided Old Case (Existing Bldg) | MR Old Case |
| | f. Door Size | I) 1.50 Mtr. II) Old Case | Provided(New Bldg) Old Case | MR Old Case (Old Bldg) |
| 3. | Compartmentation | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Sealing of electrical shafts | N/A | N/A | N/A |
| | • Fire Rating of shaft door | N/A | N/A | N/A |
| | • Water Curtain | N/A | N/A | N/A |
| | • Fire Dampers | | | |
| 4. | Smoke managements System | | | |
| | • Basements | N/A | N/A | N/A |
| | • Upper floors | N/A | N/A | N/A |

| N/g | | | | |
|-----|--|-----------------------------------|-------------------------|-----|
| 6. | First – Aid Hose Reels | | | |
| | • Total numbers on each floor | 1 in each block at each floor | Provided | MR |
| | • Length of hose reel hose | 30 Mtr. | Provided | MR |
| | • Nozzle diameter | 5 mm | Provided | MR |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detector | N/A | N/A | N/A |
| | • Location of Main Panel | N/A | N/A | N/A |
| | • Location of Repeater | N/A | N/A | N/A |
| | • Panel | N/A | N/A | N/A |
| | • Alternate source of power | N/A | N/A | N/A |
| | • Hooters' Location | N/A | N/A | N/A |
| 8. | MOEFA | N/A | N/A | N/A |
| 9. | Public Address System | I) NR | I) Provided (Old Block) | NR |
| | | II) NR | II) NP (New Block) | NR |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | N/A | N/A | N/A |
| | • Upper Floor | N/A | N/A | N/A |
| | • Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down-comer | i) 100mm (Old Bldg.) | Provided | MR |
| | | II) NR (New Bldg) | Not Provided | NR |
| | • Number of hydrants per floor | i) 1 at each floor(Old Bldg.) | Provided | MR |
| | | II) NR (New Bldg.) | NP | NR |
| | • Hose Box | i) 1 at each floor(Old Bldg.) | Provided | MR |
| | | II) NR (New Bldg.) | NP | NR |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose Box | N/A | N/A | N/A |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | N/A | | |
| | • Discharge of main pump | N/A | N/A | |
| | ➤ Head of main pump | N/A | N/A | N/A |
| | ➤ Number of main pumps | N/A | N/A | N/A |
| | ➤ Jockey pump out put | N/A | N/A | N/A |
| | ➤ Jockey pump head | N/A | N/A | N/A |
| | ➤ Standby Pump out put | N/A | N/A | N/A |
| | ➤ Standby Pump Head | N/A | N/A | N/A |
| | ➤ Auto Starting/Manual stopping | N/A | N/A | N/A |
| | ➤ Pump House Access | N/A | N/A | N/A |
| | • Terrace level | | | |
| | ➤ Discharge of pump | I) 450 LPM & 220 LPM (Old Buldg.) | Provided | MR |
| | | II) 450 LPM (New Bldg) | Provided | MR |
| | ➤ Head of the pump | 40 MTR | Provided | MR |
| | ➤ Power supply | Required | Provided | MR |
| | ➤ Auto starting of pump | Required | Provided | MR |
| 14. | Captive water Storage for fire fighting | | | |
| | • Underground tank | N/A | N/A | N/A |

| 15 | Exit Signage | Required | Provided | MR |
|-----|--|----------|----------|-----|
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | N/A | N/A | N/A |
| | ➤ Pressurization of lift lobby | N/A | N/A | N/A |
| | ➤ Communication in lift Car | N/A | N/A | N/A |
| | ➤ Fireman's Grounding Switch | N/A | N/A | N/A |
| | ➤ Lift Signage | N/A | N/A | N/A |
| 17. | Standby power supply | N/A | N/A | N/A |
| 18. | Refuge Area | N/A | N/A | |
| | ➤ Total area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | N/A | N/A | N/A |
| | ➤ Flow Switch Panel | N/A | N/A | N/A |
| | ➤ PA System Panel | N/A | N/A | N/A |
| | ➤ Batter backup | N/A | N/A | N/A |
| | ➤ Building Floor Plans | N/A | N/A | N/A |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | N/A | N/A | N/A |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note:- I) There is an existing G+2 Bldg which has already been issued FSC by this dept. Vide letter No. F6/DFS/MS/2863 dated 1/10/2010. All the fire safety measures provided in the old (G+2 Bldg) were checked and found functional.

II) A new G+2 Bldg has been constructed in the same campus and all the fire safety measures required as per NBC Part-IV has been provided.

II) Old G+2 Block and newly added G+2 Block are not connected to each other.

Ashok Kumar Jaiswal

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/2014/school/2014/w2/1370

Dated: 05/11/2014

FIRE SAFETY CERTIFICATE

Certified that the **Jeevan Public School at Pratap Vihar, Part-II, Kirari Extension, New Delhi-110086** comprised of **Ground + Two Upper Floors** only owned / occupied by **Jeevan Public School** was issued Fire Safety Certificate by this department vide letter No. **F6/DFS/MS/2863 dated 01/10/2010**. A new block comprising Ground + Two Upper Floors was also found constructed now. The Fire Safety Requirements in accordance with Director of Education circular no. 262-362 dated 17/01/2005 for old block and Delhi Fire Service act 2007 & rules 2010 for new block, have found provided and verified by the officer concerned of Fire Service on 27/08/2014 in presence of Sh. Jagbir Singh (Manager) and both the blocks in the premises are fit for occupancy class **Educational (Group-B)** with effect from 05/11/2014 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
3. The trained fire- fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 05/11/14 **at New Delhi by.**


(SANTOKH SINGH)
CHEF FIRE OFFICER.
Phone:-23414250

Copy to :-

1. The Principal, Jeevan Public School, Partap Vihar, Part-II, Kirari Extn., Delhi-110086.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-110054.