

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/EH/2014/W2/1303

Dated: 20/10/14

FIRE SAFETY CERTIFICATE

Certified that the **McDonald's Family Restaurant by M/s Connaught Plaza Restaurant Pvt. Ltd.** located at **Ground Floor, Vishal Cinema Complex, Rajouri Garden, New Delhi - 110027** was issued FSC vide Letter No. F6/DFS/MS/EH/2011/2558 dated 14-10-2011. The premises was inspected by the officers concerned of this department on 12-09-2014 in the presence of Mr. Prashant Yadav (Deputy Manager - Facility) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 20/10/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/10/14..... at New Delhi by.


(Santokh Singh)
Chief Fire Officer,
Ph: 011-23414250

Copy to:

1. Sh. Shailendra Pandey,
Connaught Plaza Restaurants Pvt. Ltd.,
13A, Jor Bagh Market, New Delhi - 110003.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: McDonald's Family Restaurant by M/s
Connaught Plaza Restaurants Pvt. Ltd., Ground Floor, Vishal Cinema Complex,
Rajouri Garden, New Delhi – 110027.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal (Situated in Cinema Complex already
issued NOC vide letter no. F6/DFS/MS/Cinema/2014/1164 dated 29-05-2014)
4. Details of previous NOC : Letter No. F6/DFS/MS/EH/2011/2558 dated
14-10-2011
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 05-09-2014
7. Name of the Inspecting Officer : Mukesh Verma, ADO (MN)
8. Name and designation of Officer
from the building side : Sh. Prashant Yadav (Deputy Manager –
Facility)
9. Year of Construction : 2011
10. Applicant's letter No. : Nil Dated 26-08-2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> 6 m NA NA 	<ul style="list-style-type: none"> Provided NA NA 	<ul style="list-style-type: none"> MR NA NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> 2 NA 	<ul style="list-style-type: none"> Provided NA 	<ul style="list-style-type: none"> MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> Old Case NA 	<ul style="list-style-type: none"> Old Case NA 	<ul style="list-style-type: none"> MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old Case	Old Case	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	02 nos. each	Provided	MR
	<ul style="list-style-type: none"> • Types 	type	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ABC & CO ₂ ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	1	Provided	MR
		30 m	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	5 mm	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 			
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	Smoke	Provided	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hooters' Location 	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	Not Applicable	Not Applicable	Not Applicable
	<ul style="list-style-type: none"> • Upper Floor 			
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
11.	Internal Hydrants: Common with the Vishal Cinema			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	150 mm	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 			
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 			
13.	Pumping Arrangements: Common with the Vishal Cinema			

	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump 	NA	Common with the cinema	NA
	➤ Head of main pump	NA	Common with the cinema	NA
	➤ Number of main pumps	NA	Common with the cinema	NA
	➤ Jockey pump out put	NA	Common with the cinema	NA
	➤ Jockey pump head	NA	Common with the cinema	NA
	➤ Standby Pump out put	NA	Common with the cinema	NA
	➤ Standby Pump Head	NA	Common with the cinema	NA
	➤ Auto Starting/Manual stopping	NA	Common with the cinema	NA
	➤ Pump House Access	NA	Common with the cinema	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm	Common with the cinema	MR
	➤ Head of the pump	40 m	Common with the cinema	MR
	➤ Power supply	Required	Common with the cinema	MR
	➤ Auto starting of pump	Required	Common with the cinema	MR
	14.	Captive water Storage for fire fighting: Common with the Vishal Cinema		
	• Under ground tank capacity	NA	2,00,000 litres	NA
	➤ Draw off connection	NA	Provided	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	10, 000 litres	35, 000 Litres Provided	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2011/2558 dated 14-10-2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name **MUKESH VERMA**

Designation **ADD (MN)**

Signature of the Inspecting Officer

Name

Designation

