

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/2014/ School/w2/1375

Dated: 07/11/2014

FIRE SAFETY CERTIFICATE

Certified that Skyland Public School, E-9, Vijay Vihar, Phase – II, Rohini, Delhi-110085 school running at Ground + Two upper floors of a buildings comprised of Ground + Three upper floors owned / occupied by Skyland Public School has already been issued fire safety certificate vide this office letter No F-6/DFS/MS/School/2011/2926 dated 09/11/2011. The premise was re-inspected by the officer concerned and all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance with Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 17/10/2014 in the presence of Sh. Gagan Bindal (Manager) and that the building / premises is fit for occupancy of Group Class B (Educational) with effect from 07/11/2014 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The third floor sealed by the school management shall not be used for school purposes.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 07/11/14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250



Copy to:

1. The Principal, Skyland Public School, E-9, Vijay Vihar, Phase – II, Rohini, Delhi-110085
2. The Director of Education, Old Secretariat, Delhi-110054

INSPECTION REPORT

1. Name & address of the building: Skyland Public School, E-9, Vijay Vihar, Phase, Phase-II, Rohini.
2. Type of Occupancy : Educational (G + Three upper floor, School running on
3. Type of Case : Renewal (G + 2 upper floors, 3rd floor affidavit enclosed)
4. Details of previous NOC : **F-6/DFS/MS/School/2011/2926 dated 09/11/2011**
5. Fire Safety directives letter No : Director of Education
6. Date of inspection : 17/10/2014
7. Name of the Inspecting Officers : DO (NW)
8. Name and designation of officers
from the building side : Sh. Gagan Bindal (Manager)
9. Year of Construction : 2000
10. Applicant's letter No. : SPS/Rohini/SKY 39 dated 15/09/2014

P A 206 sq. yds

CA-206 Sq. yds

NOS- 310

CR-11

	Minimum Standards on fire prevention and fire safety U/R 33	NBC/Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	M/R ✓
	• Gate width	Accessible	Accessible	M/R ✓
	• Width of internal road	--	--	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	M/R ✓
	• Basements	--	--	--
	b. Width of staircases			
	• Upper Floors	Old case	Old case	Old case ✓
	• Basements	--	--	--
	c. Protection of exits			
	• Fire check door	--	--	--
	• Pressurization	--	--	--
	e. No. of continuous staircases to terrace	Old case	Old case	Old case ✓

	g. Width of Corridor h. Door Size (single door of)	Old case 01 mtr	Old case 105 cms	Old case M/R
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	• Total numbers	04	08	M/R
	• Types		ABC	M/R
	• IS marking	ISI marked	Yes	M/R
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01 at each floor	P	M/R
	• Length of hose reel hose	30 m	P	M/R
	• Nozzle diameter	5 mm	P	M/R
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	NR	P	M/R
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A

11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	R	P	M.R
	➤ Pump House Access	R	P	M.R
	• Terrace level			
	➤ Discharge of pump			
	➤ Head of the pump	450 LPM	P	M/R
	➤ Power Supply	40 Mtr	P	M/R
	➤ Auto Starting of pump	R	P	M.R
		R	P	M.R
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10000 ltr	10000 ltr	M/R
15	Exit Signage.	NR	P	M/R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A

	<ul style="list-style-type: none"> • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F-6/DFS/MS/School/2011/2926 dated 09/11/2011** Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

Depo (w)

Signature of the Inspecting Officer

Name

Designation

Depo
22/1/14
(w)