

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
(Refer sub-rule (1) of rule 35)
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F61DFS/MS/2014/W2/1384

Dated 12/11/14

FIRE SAFETY CERTIFICATE

Certified that the **Club 100 Nights (A Unit of Delhi Township Pvt. Ltd.)** located at **301, 3rd floor, D Mall, Netaji Subhash Place, Pitampura, New Delhi - 110034** in a building comprised of 3 Basement + Ground + 12 Upper Floors owned / occupied by **Club 100 Nights (A Unit of Delhi Township Pvt. Ltd.)** have complied with the fire prevention and fire safety requirement in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 16.10.2014 in the presence of Mr. Nitin (Senior Manager) and found that the said premises is fit for occupancy class "Assembly" Group D with effect from 12/11/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire service rule, 2010.

Issued on 12/11/2014 at New Delhi by.


(Santokh Singh)
Chief Fire Officer
Delhi Fire Service
Tel.No. - 23414250

Copy to:

1. Sh. Nitin (Senior Manager), 301, D Mall, 3rd floor, Netaji Subhash Place, Pitampura, Delhi-34.
2. The Joint Commissioner Police, Licensing, 1st Floor, PS, Defence Colony, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N-25

INSPECTION REPORT

1. Name & address of the building: Club 100 Night Restaurant, Shop no. 301, 3rd floor, D Mall Netaji Subhash Place, Pitampura, Delhi – 110034.
2. Type of Occupancy : Assembly
3. Type of Case : New (Situated in Mall already issued NOC vide letter no. F6/DFS/MS/2012/2059 dated 06-06-2012)
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : FSC Issued to the mall
6. Date of inspection : 16-10-2014
7. Name of the Inspecting Officer : Udaivir Singh, ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Nitin(Senior Manager)
9. Year of Construction : 2014
10. Applicant's letter No. : Nil dated 16-08-2014

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	30m Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	Old Case	Old Case	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1X2 m & 1X1m	2 mtrs & 1 mtrs	MR ✓
3.	Compartmentation			

	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA.
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	NA	NA
		12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	02 nos. each type DCP & CO2 ISI marked	Provided	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	1	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Smoke Required NA Required Required	Provided Provided at GF NA Provided Provided at entrance	MR MR NA MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Upper Floor • Sprinkler above false ceiling 	Not Required Required Required	NR Provided Provided	NR MR MR
11.	Internal Hydrants: Common with the mall			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	150 mm 1 Required	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	NA NA	NA NA	NA NA

13.	Pumping Arrangements: Common with the mall			
	Ground Level	NA	Common with the mall	MR
	• Discharge of main pump	NA	Common with the mall	MR
	➤ Head of main pump	NA	Common with the mall	MR
	➤ Number of main pumps	NA	Common with the mall	MR
	➤ Jockey pump out put	NA	Common with the mall	MR
	➤ Jockey pump head	NA	Common with the mall	MR
	➤ Standby Pump out put	NA	Common with the mall	MR
	➤ Standby Pump Head	NA	Common with the mall	MR
	➤ Auto Staring/Manual stopping	NA	Common with the mall	MR
	➤ Pump House Access	NA	Common with the mall	MR
	• Terrace level			
	➤ Discharge of pump	900 lpm	Common with the mall	MR
		40 m	Common with the mall	MR
	➤ Head of the pump	Required	Common with the mall	MR
	➤ Power supply	Required	Common with the mall	MR
	➤ Auto starting of pump			
14.	Captive water Storage for fire fighting: Common with the mall			
	• Under ground tank capacity	NA	2,50,000 litres	MR
	➤ Draw off connection	NA	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	Provided	MR
	• Overhead Tank capacity	10, 000 litres	50, 000 Litres	MR
			Provided	
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			

N-28

	• Overhead Tank capacity		Provided	
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers Nil



Signature of the Inspecting Officer


Signature of the Inspecting Officer

Name Uday Vir Singh

Name

Designation ASO/WP

Designation

DO/W

 3/1/15

CFD/1077
 11/11/14