

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID: cfohq.dlfire@nic.in

No. F6/MS/DFS/2014/ *club/NO2/1430*

Dated *20/11/14*

FIRE SAFETY CERTIFICATE

Certified that the **Delhi Golf Club Limited** located at **Dr. Zakir Hussain Road, New Delhi** comprised **Basement and Ground floor** was granted NOC by this department vide letter No.F6/MS/DFS/2011/2013 dated 19/08/2011 The premises was re-inspected by the officer concerned of this department on 27-09-2014 in the presence of Sh. Surjeet (Mant. Eng.) and found that the said club have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and the building is fit for occupancy class **Group D "Assembly Building" Sub Division D-3** with effect from ----- *20/11/14* for period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on *20/11/14* at New Delhi by.

[Signature]
19/11/14
(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333

Copy to:-

1. Asstt. Commissioner (Excise), Govt. of NCT of Delhi, officer of the Commissioner Excise, L&N Block, Vikas Bhawan, New Delhi.
2. The Secretary, Delhi Golf Club Limited, Dr. Zakir Hussain Road, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry"

INSPECTION REPORT

1. Name & address of the building : Delhi Golf Club Limited, Dr. Zakir Hussain Road, New Delhi.
2. Type of Occupancy : Assembly Building (Basement and Ground floor)
3. Type of Case : **Renewal**
4. Details of previous NOC : F6/DFS/MS/2011/2013 dated 19/08/2011
5. Fire Safety directives Letter No. : NA
6. Date of inspection : **27/09/14**
7. Name of the Inspecting Officer : Sh. Rajesh Panwar (DCFO/NDZ)
Sh. G.S. Chauhan (DO/CD)
Sh. M.K. Sharma (ADO/CC)
8. Name and designation of Officer
from the building side : Mr. Surjeet Singh (Mant. Eng.)
9. Year of Construction : Old
10. Applicant's letter No. : Delhi Golf Club Ltd. dated 27/10/2014.

Old Case

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 Mtr.	16 Mtr.	MR
	• Gate width	05 Mtr.	05 Mtr.	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01	02	MR
	• Basements	01	01	MR
	b. Width of staircases			
	• Upper floors	1.5 mt. & 1 mt.	1.5 mt. & 1.10 mt.	NA
	• Basements	1 Mt.	0.93 Mt. Old case	MR
	c..Protection of exits			
		NA	NA	NA

	• Fire check door	Required	Provided	MR
	Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2mt.	2mt.	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	20	24	MR
	• Types	ABC, Co2, Wco2	ABC, Co2, Wco2	MR
	• IS marking	Required	Provided	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	02	02	MR
	• Length of hose reel hose	30 mt	30 mt	MR
	• Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler			
	• Basements	Required	Provided	MR

	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 mm	100 mm	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	02	02	MR
	<ul style="list-style-type: none"> Hose Box 	02	02	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	02	02	MR
	<ul style="list-style-type: none"> Hose Box 	02	02	MR
13	Pumping Arrangements			
	○ Ground Level			
	• Discharge of main pump	1620 LPM	1620 LPM	MR
	• Head of main pump	40 mt.	40 mt.	MR
	• Number of main pumps	02	02	MR
	• Jockey pump out put	280 LPM	280 LPM	MR
	• Jockey pump head	40 mt.	40 mt.	MR
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	40 mt.	40 mt.	MR
	• auto Starting/Manual stopping	Required	Provided	MR
	• Pump House Access	Required	Provided	MR
	○ Terrace level	NA	NA	NA
	• Discharge of pump	NA	NA	NA
	• Head of the pump	NA	NA	NA
	• Power supply	NA	NA	NA
	• Auto starting of pump	NA	NA	NA
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Under ground tank capacity 	20,000 ltrs	20,000 ltrs	MR
	<ul style="list-style-type: none"> Draw of connection 	Required	Provided	MR
	<ul style="list-style-type: none"> Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	10,000 ltrs	10,000 ltrs	MR


2/21


15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	YES	ABC, Co ₂	MR


The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, renewal of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010, is recommended please.



Signature of the Inspecting Officer

 Name :- Sh. Rajesh Panwar
 Designation :- DCFO (NDZ)

Signature of the Inspecting Officer

 Name :- G.S Chauhan
 Designation :- DO (CD)

Signature of the Inspecting Officer

 Name :- M.K. Sharma
 Designation :- A. D.O. (CC)