

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2014/MD2/1417

Dated: 18/11/14

FIRE SAFETY CERTIFICATE

Certified that the EDMC Nigam Pratibha Vidyalaya, South Anarkali, Delhi, comprised of ground floor plus one upper floor was granted FSC by this department vide Letter No-F.6/DFS/MS/School/2011/2418 dated 04.10.2011. School building was re-inspected by the officer concerned of this department on 16.10.2014 in the presence of Principal of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular No. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and found that the building is fit for occupancy Group B "Educational Building" with effect from ..18/11/14.. renewed for a period of three years, subject to conditions printed overleaf.

Issued on.....18/11/14.....at New Delhi by



(Dr. G.C. Misra)

Chief Fire Officer

Ph -011- 23414333

OK

To,
The Principal (1st Shift)
EDMC Nigam Pratibha Vidyalaya, South Anarkali, Delhi

Copy to:-

1. The Director of Education,
East Delhi Municipal Corporation,
419, Udyog Sadan, Patparganj Industrial Area, Delhi-92
2. The Principal (2nd Shift)
EDMC Nigam Pratibha Vidyalaya, South Anarkali, Delhi

INSPECTION REPORT

1. Name & address of the building : EDMC Nigam Pratibha Vidyalaya, South Anarkali, Delhi
2. Building is comprised of : G+1
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC : F.6/DFS/MS/School/2011/2418 dated 04.10.2011
6. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11
7. Date of Inspection : 16.10.2014
8. Name of the Inspecting Officers: : Suresh Singh (ADO)
9. Name of the designation of Officer from the building side : Principal
10. Year of Construction : 2005
11. Applicant's letter No : dated 26.09.2014

S.No	Minimum Standards on fire safety requirements as per circular no. 3298 to 3398 Dated. 01.03.11	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	6 m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	02 no.	02 no.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	1.5 m	1.5 m each	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	N.A.	N.A.	N.A.
g. Width of Corridor	1.5 m	2.6 m	MR	
h. Door Size	1 m	1 m	MR	
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	N.A.	N.A.	N.A.
	Upper floor	N.A.	N.A.	N.A.

5.	Fire Extinguisher			
	Total numbers	04 no.	04 no.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	N.A.	N.A.	N.A.
	Length of hose reel hose	N.A.	N.A.	N.A.
	Nozzle diameter	N.A.	N.A.	N.A.
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters's location	N.A.	N.A.	N.A.
8	MOEFA	N.A.	Provided	MR
9	Public address System.	N.A.	Provided	MR
10	Automatic Sprinkler System.			
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.

N/9

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.	N.A.	N.A.	N.A.
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules the FSC issued vide letter no. F.6/DFS/MS/School/2011/2418 dated 04.10.2011 renewal under the circular No. 3298 to 3398 dated 01.03.11 is recommended.

Singh
20.10.14

Signature of the Inspecting Officer

Name Suresh Singh

Designation ADO (Shah)

DO (EAST)

Submitted for approval please.

Handwritten signature