

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001


No. FG/D/S/M/72014/52/1386

Dated: 13/11/14

FIRE SAFETY CERTIFICATE

Certified that Georgi Stoikov Rakovski, Govt. Sarvodaya Kanya Vidyalaya, C-Block, Defence Colony, New Delhi-24, comprises of ground plus two upper floors (one block) and ground floor only (one block), owned/occupied by Directorate of Education, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on dated 28.10.14 in the presence of Mrs. Renu Bashin, Principal of the school and found that the building is fit for occupancy class B 'Educational Building' with effect from 13.11.14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules, 2010.

Issued on 13.11.2014 at New Delhi by



(Dr.G.C.Misra)

Chief Fire Officer

T.No.011-23414333

To,

The Principal
Georgi Stoikov Rakovski,
Govt. Sarvodaya Kanya Vidyalaya,
C-Block, Defence Colony, New Delhi-24.



Copy to:-

The Director of Education
Old Secretariat, Civil Lines,
Delhi-52.

Conditions for the validity of fire safety certificate are overleaf:-

INSPECTION REPORT

1. Name & address of the building : Georgi Stoikov Rakovski, Govt. Sarvodaya Kanya Vidyalaya, C-Block, Defence Colony, New Delhi-24.
2. Building is comprised of : G+2(One Block) and Ground floor only (One Block).
3. Type of Occupancy : Education
4. Type of Case : New.
5. Details of Previous NOC : Nil.
6. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398
Dated- 01.03.11
7. Date of Inspection : 28.10.14
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of Officer from the building side : Renu Bashin (Principal)
10. Year of Construction : 1962.
11. Applicant's letter No : GSR/SKV/2014/2773, dated 28.10.14.

S.N	Minimum Standards on fire prevention and fire safety as per circular no.3298-3398 Dated01.03.11.	Requirement	Provided at Site	Remarks
0				MR/NMR
1	Access to building			
	Road width	6 m	9 m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases	.		
	Upper Floor	2nos.	02nos.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases			
	Upper Floor	1.5 m(each)	1.65m(each)	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	1no.	1no.	MR
	g. Width of Corridor	1.5 m	1.5 m	MR
	h. Door Size	1 m	1m	MR
3	Compartmentation			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	12 a/c per hour	N.A.	N.A.

N/4

Georgi Stoikov Rakovski, Govt. Sarvodaya Kanya Vidyalaya, C-Block, Defence Colony.

5.	Fire Extinguisher			
	Total numbers	18 nos.	20 nos.	
	types	CO ₂ & ABC	CO ₂ and ABC Type	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			MR
	Total numbers of each floor	02nos.	02nos.	MR.
	Length of hose reel hose	30m	30m	MR.
	Nozzle diameter	5cm	5cm	MR.
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.	N.A.	N.A.	N.A.
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	stage of auditorium	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of down-comer	N.A.	100mm	N.A.
	Number of hydrants per floor in each block	N.A.	02nos.	N.A.
	Hose Box	N.A.	02nos.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	➤ Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	➤ Terrace Level	01no.	01no.	MR.
	➤ Discharge of pump	450LPM	450LPM(Two)	MR
	➤ Head of the Pump	40m	40m(Each)	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

N/S

Georgi Stoikov Rakovski, Govt. Sarvodaya Kanya Vidyalaya, C-Block, Defence Colony.

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	10000 liters	10000Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.



D.O. (South)

Handwritten signature and date: 5/11/14

Handwritten signature and date: 31/11/14

Signature of the Inspecting Officer

Name: Vedpal

Designation: ADO