

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593


No.F.6/DFS/MS/School/2014/SZ.1383

Dated: 11/11/14

FIRE SAFETY CERTIFICATE

Certified that the building of **Govt. Girls Senior Secondary School No. 1**, Subhash Nagar, New Delhi 110027 is comprised of ground plus one upper floor. The school is running at ground floor and first floor only, having total 48 rooms (Including Class Rooms, Lab's staff Room, Library & Office etc.) owned/occupied by the school management was inspected by the officer concerned of this department on 30.10.2014 in the presence of Smt. Sharda Tanwar (Vice Principal) and found that the school management have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the school building/ premises fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on..... 11-11-14 at New Delhi.



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Principal,
Govt. Girls Senior Secondary School No. 1, Subhash Nagar,
New Delhi 110027.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi - 110054.

o/c sam
11/11/14

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Govt. Girls Senior Secondary School No. 1, Subhash Nagar, New Delhi 110027.
2. Type of Occupancy : Educational
3. Type of Case : New
4. Details of Previous NOC : Nil
5. Fire Safety directives letter No : N/A
6. Date of inspection : 30.10.2014
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Smt. Sharda Tanwar (Vice Principal)
9. Year of Construction : 1960 and 2014
10. Applicant's letter No. : GGSSSN.1/SN/2014/1101 dated 23.08.2014

10.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
Access to building				
	Road width	Accessible	10 mtrs	M/R
	Gate width	—	6.0 , 3.80 &	—
	Width of internal road	—	3.80 mtrs	—
Number, Width, Type & Arrangement of Exits				
	a. Number of staircases			
	• Upper Floors	OB : 03 No's & NB : 05 No's	OB : 03 No's & NB : 05 No's	M/R
	• Basements	N/A	N/A	No basement
	b. Width of staircases			
	• Upper Floor	1.5 mtrs	OB : 186,183,150 cms & NB : 153 cms each(05 No's)	M/R
	• Basements	N/A	N/A	No basement
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	01(Each Block)	N/A
	e. Width of Corridor	150 cms	OB : 210 cms & NB : 175cms	M/R
	f. Door Size	N/A	110 cms (Double door)	M/R
Compartmentation				
	Fire check door	N/A	N/A	N/A
	Sealing of electrical shafts	N/A	N/A	N/A
	Fire Rating of shaft door	N/A	N/A	N/A
	Water Curtain	N/A	N/A	N/A
	Fire Dampers	N/A	N/A	N/A
Smoke Management System				
	Basements	N/A	N/A	No basement

Two Blocks, Old Block (OB) and New Block (NB) :- (Ground Floor plus one upper Floor each)
Govt. Girls Senior Secondary School No. 1, Subhash Nagar, New Delhi 110027.

	Upper floors	N/A	Natural Ventilation	M/R
5.	Fire Extinguishers	30 no's ABC/CO2 type ISI marked	Provided	M/R
	Total numbers		Provided	M/R
	Types		ISI marked	M/R
	IS marking			
6.	First-Aid Hose Reels	N/A	N/A	N/A
	Total numbers on each floor	N/A	N/A	N/A
	Length of hose reel hose	N/A	N/A	N/A
	Nozzle diameter			
7.	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	Location of Main Panel	N/A	N/A	N/A
	Location of Repeater Panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	Provided	N/A
9.	Public Address System			
10.	Automatic Sprinkler System			
	Basement	N/A	N/A	N/A
	Ground Floor	N/A	N/A	N/A
	Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	Size of riser/down-comer	N/A	N/A	N/A
	Number of hydrants per floor	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	Total number of hydrants	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	Ground Level	N/A	N/A	N/A
	Discharge of main Pump	N/A	N/A	N/A
	Head of Main pump	N/A	N/A	N/A
	Number of main pumps	N/A	N/A	N/A
	Jockey Pump out put	N/A	N/A	N/A
	Jockey pump head	N/A	N/A	N/A
	Standby Pump out put	N/A	N/A	N/A
	Standby Pump Head	N/A	N/A	N/A
	Auto Starting/Manual Stopping	N/A	N/A	N/A
	Pump House Access	N/A	N/A	N/A

	Terrace level			
	Discharge of pump	N/A	N/A	N/A
	Head of the pump	N/A	N/A	N/A
	Power Supply	N/A	N/A	N/A
	Auto Starting of pump	N/A	N/A	N/A
	Captive Water Storage for fire fighting			
	Underground tank capacity	N/A	N/A	N/A
	Draw-off connection	N/A	N/A	N/A
	Fire service inlet	N/A	N/A	N/A
	Access to tank	N/A	N/A	N/A
	Overhead Tank capacity	N/A	N/A	N/A
	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.		No Lift	
	Pressurization of Lift Shaft	N/A	N/A	N/A
	Pressurization of Lift lobby	N/A	N/A	N/A
	Communication In lift Car	N/A	N/A	N/A
	Fireman's Grounding Switch	N/A	N/A	N/A
	Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	Total Area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19.	Fire Control Room			
	Detector System Panel	N/A	N/A	N/A
	Flow Switch Panel	N/A	N/A	N/A
	PA System Panel	N/A	N/A	N/A
	Battery backup	N/A	N/A	N/A
	Building Floor Plans	N/A	N/A	N/A
	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

N/9

Two Blocks, Old Block (OB) and New Block (NB) :- (Ground Floor plus one upper Floor each)
Govt. Girls Senior Secondary School No. 1, Subhash Nagar, New Delhi 110027.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Sandeep
03/11/14

Signature of Inspecting Officer

Signature of Inspecting Officer

Name:- Sandeep Duggal

Name

Designation:- Asstt. Divisional Officer

Designation

