

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

Fax:- 011-23412593

E-mail ID: cfohq.dlfire@nic.in

No F 6 / DFS / MS / GH / 2014 / **NO2/1413**

Dated **17/11/14**

FIRE SAFETY CERTIFICATE

Certified that **M/S Haldi Ram Product Pvt. Ltd.** at **L-3 & 4 Connaught Place, New Delhi** comprised of **Ground floor + 2 floor and Restaurant at ground floor + Mezzanine floor** was granted NOC by this department letter No.F6/DFS/MS/E.H./2011/85 dated 17/01/2011. The premises was re-inspected by the officers from this department 26-09-2014 in the presence Sh. Udit Awasthi (GM) restaurant and found that the said Restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and the said building / premises is fit for occupancy **Class Group D Assembly Building** with effect from **17/11/2014** for period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.
Issued on **17/11/14** at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333

1. Sh. Udit Awasthi (GM) M/S Haldi Ram Product Pvt. Ltd. at L-3 & 4 Connaught Place, New Delhi.
2. Medical Officer of Health (Health Department) Palika Kendra, Sansad Marg, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry"

INSPECTION REPORT

1. Name & address of the building : M/S HaldiRam Product Pvt. Ltd. located at L-3 & 4 ,Connaught Place, Circus, New Delhi
2. Type of Occupancy : Assembly Building (Ground+ 2nd floor and Restaurant at ground floor +Mezzanine floor)
3. Type of Case : **Renewal**
4. Details of previous NOC : F6/DFS/MS/EH/2011/85 dated 17/01/2011
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 26/09/2014
- 7 Name of the Inspecting Officer : Sh. Rajesh Panwar (DCFO NDZ), Sh. G.S Chauhan (DO CD)
Sh. M.K. Sharma (ADO CC)
- 8 Name and designation of Officer
from the building side : Sh. Udit Awasthi (G.M.)
- 9 Year of Construction : Old Heritige
10. Applicant's letter No. : No. CIN-U15490DL 1996PTC081504 dated 09/09/2014.

Old Case

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9Mtr.	9Mtr.	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases (Mezzanine)	02	02	MR
	• Upper floors	02	02	MR
	• Basements	NA	NA	NA
	b.Width of staircases			
	• Upper floors (Mezzanine)	1 mt each	1.01 mt.& 1.20mt.	MR
	• Basements	NA	NA	NA
	c..Protection of exits			

<ul style="list-style-type: none"> • Fire check door • Pressurization d. No of continuous staircase to terrace e. Width Of Corridor f. Door Size	NA	NA	NA
	NA	NA	NA
	01	01	MR
	NA	NA	NA
	NA 02 mt	02 mt	MR
Compartmentation			
<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
Smoke managements System			
<ul style="list-style-type: none"> • Basements • Upper floors 	NA	NA	NA
	12 ACPH	NATURAL	MR
Fire Extinguishers			
<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	20	24	MR
	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	YES	Provided	MR
First – Aid Hose Reels			
<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01	01	MR
	30 mt	30 mt	MR
	05 mm	05mm	MR
Automatic fire detection and alarming system			
<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Required	Provided	MR
	Ground floor	Ground floor	MR
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
MOEFA	Required	Provided	MR
Public Address System	NA	NA	NA
Automatic Sprinkler			

<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	NA	NA
	Required	Provided	MR
	NA	NA	NA
Internal Hydrants			
<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100mm	100mm	MR
	01	01	MR
	02	02	MR
Yard Hydrants			
<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
	NA	NA	NA
Pumping Arrangements			
<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 			
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	NA	NA	NA
	450 LPM	450LPM&180LPM	MR
	30 mt	30 mt	MR
	Required	Provided	MR
	NA	Provided	NA
Captive water Storage for fire fighting			
<ul style="list-style-type: none"> Under ground tank capacity Draw of connection Fire service inlet 	NA	NA	NA
	NA	NA	NA
	NA	NA	NA

N/A

	<ul style="list-style-type: none"> Access to tank Overhead Tank capacity 	NA 5,000 ltrs	NA 5,000 ltrs	NA MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts	NA	NA	NA
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	NA	NA	NA
		NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> Detector system panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC, Co ₂	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, renewal of fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / is recommended please.

Signature of the Inspecting Officer

Name :- Sh. Rajesh Panwar
Designation :- DCFO (NDZ)

Signature of the Inspecting Officer

Name :- G.S Chauhan
Designation :- DO (CD)

Signature of the Inspecting Officer

Name :- M.K. Sharma
Designation :- A. D.O. (CC)